

# City of Troy District Energy

Final Report | Report Number 23-13 | November 2021



**NYSERDA**

## **NYSERDA's Promise to New Yorkers:**

NYSERDA provides resources, expertise, and objective information so New Yorkers can make confident, informed energy decisions.

### **Our Vision:**

New York is a global climate leader building a healthier future with thriving communities; homes and businesses powered by clean energy; and economic opportunities accessible to all New Yorkers.

### **Our Mission:**

Advance clean energy innovation and investments to combat climate change, improving the health, resiliency, and prosperity of New Yorkers and delivering benefits equitably to all.

# City of Troy District Energy

*Final Report*

Prepared for:

**New York State Energy Research and Development Authority**

Albany, NY

Scott Smith  
Program Manager

Prepared by:

**CHA Consulting**

Colonie, NY

Mitchell DeWein  
Energy & Renewable Team Leader

## Notice

---

This report was prepared by CHA Consulting, Inc., on behalf of the City of Troy and Siemens Smart Infrastructure in the course of performing work contracted for and sponsored by the New York State Energy Research and Development Authority (hereafter “NYSERDA”). The opinions expressed in this report do not necessarily reflect those of NYSERDA or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation of endorsement of it. Further, NYSERDA, the State of New York, and the contractor make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any process, methods, or other information contained, described, disclosed, or referred to in this report. NYSERDA, the State of New York, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately owned rights and will assume no liability for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

NYSERDA makes every effort to provide accurate information about copyright owners and related matters in reports we publish. Contractors are responsible for determining and satisfying copyright or other use restrictions regarding the content of reports that they write, in compliance with NYSERDA’s policies and federal law. If you are the copyright owner and believe a NYSERDA report has not properly attributed your work to you or has used it without permission, please email [print@nyserda.ny.gov](mailto:print@nyserda.ny.gov)

Information contained in this document, such as web page addresses, are current at the time of publication.

## Disclaimer

---

The report was prepared as part of the category A feasibility study portion of PON 4614 (Community Heat Pump Program). The study explores the feasibility and potential options for creating a fossil fuel free district energy system in Troy, NY. Portions of the system described will be submitted for further design and implementation; however, the final design and construction of any particular portion of the system will likely deviate from what is described within. Any potential customers described are included for analysis purpose and no commitments have been made at this time, financial or otherwise.

## Abstract

---

This study explores the potential of a district heat pump system in Troy's downtown and waterfront areas. The project aims to establish a network ambient loop system for efficient heating and cooling of buildings. The system would reduce energy consumption by sharing energy, decreasing peak loads and improving equipment efficiencies. Phases 1A and 1B will cover buildings in the historic northern and southern downtown areas, including affordable housing projects. Phase 2 expands to other downtown buildings, while Phase 3 focuses on the waterfront redevelopment. The report provides a preliminary cost assessment and emphasizes Troy's commitment to sustainable development and economic revitalization.

## Keywords

---

district energy, geothermal, ground source heat pumps, electrification

## Acknowledgments

---

We would wish to acknowledge the following people and organizations that provided letters of support for the project grant application:

John. T McDonald, Member of the NYS Assembly  
Mayor WM. Patrick Madden, City of Troy  
Christopher Ames, President, Russel Sage College  
Sumeet Gupta, Hoboken Brownstone Co.  
John Johanson, Chair, City of Troy Sustainability Task Force  
Deborah Witkowski, Executive Director, Troy Housing Authority  
Kevin Bette, President, First Columbia LLC  
Jon Elbaum, Troy Savings Bank Music Hall  
Elizabeth Reiss , CEO, The Arts Center of the Capital Region  
Jody and Russ Brooks, River King Development LLC  
Sam Judge, Judge Development Corp.

# Table of Contents

---

<b>Notice</b> .....	<b>ii</b>
<b>Disclaimer</b> .....	<b>ii</b>
<b>Abstract</b> .....	<b>iii</b>
<b>Keywords</b> .....	<b>iii</b>
<b>Acknowledgments</b> .....	<b>iii</b>
<b>List of Figures</b> .....	<b>v</b>
<b>List of Tables</b> .....	<b>vi</b>
<b>Executive Summary</b> .....	<b>ES-1</b>
<b>1 Task 1. Establish Baseline Conditions</b> .....	<b>1</b>
1.1 Thermal Model—Heating and Cooling loads .....	1
1.2 Develop Interval Profiles .....	7
1.3 Monthly Load Profiles.....	13
1.4 Hourly and Design Day Load Profiles .....	15
1.5 Temporal Coincidence of Loads .....	22
1.6 Preliminary Utility Usage .....	22
1.7 Baseline Energy Use and Utility Costs .....	25
1.8 Life-Cycle Cost for Baseline.....	26
1.8.1 Initial Construction Costs .....	26
1.8.2 Electricity and Natural Gas Costs of System Operation .....	27
1.8.3 Operation, Maintenance, and Repair Costs.....	27
1.8.4 Replacement Costs.....	27
1.8.5 Net Present Value Analysis (NPV) Results.....	28
1.9 Environmental Footprint.....	28
<b>2 Task 3. Determine Optimal Energy Source and Develop Conceptual Design</b> .....	<b>29</b>
2.1 Vertical Bore Closed Loop System .....	29
2.2 Potential Ground Loop Heat Exchanger (GLHX) Site.....	30
2.3 Centralized System Overview .....	33
2.4 System Sizing.....	34
2.4.1 Heating Load.....	34
2.4.2 Cooling Load .....	36
2.5 Thermal Storage .....	37
2.6 Long-Term Thermal Imbalance.....	38
2.7 Ground Heat Exchanger (GHX) Site Locations .....	38

2.8	River Heat Exchanger (HEX) .....	39
2.9	Wastewater Heat Recovery .....	39
2.10	Air Source Heat Pump Chillers .....	39
2.11	Hybrid System .....	40
<b>3</b>	<b>Task 4. Perform Economic and Financial Analysis .....</b>	<b>41</b>
3.1	Life-Cycle Cost for Baseline .....	41
3.1.1	Initial Construction Costs .....	41
3.1.2	Electricity and Natural Gas Costs of System Operation .....	42
3.1.3	Operation, Maintenance, and Repair Costs .....	42
3.1.4	Replacement Costs .....	43
3.2	Life-Cycle Cost for District Energy System .....	43
3.3	Net Present Value (NPV) Analysis .....	43
3.3.1	Energy Escalation Rates .....	43
3.3.2	Discount Rate .....	44
3.3.3	NPV Summary .....	44
3.4	Results—Business Model .....	44
3.5	Results—Impact .....	47
<b>4</b>	<b>Task 6. Conduct Permitting and Regulatory Review .....</b>	<b>51</b>
<b>5</b>	<b>Task 7. Leverage Educational Opportunity of the Project .....</b>	<b>54</b>
<b>6</b>	<b>Lessons Learned .....</b>	<b>55</b>
	<b>Appendix A. City of Troy District Energy, Category A: Supporting Documents .....</b>	<b>A-1</b>

## List of Figures

---

Figure 1.	Phase 1A Site Map—Building Area .....	1
Figure 2.	Phase 1B Site Map—Building Area .....	2
Figure 3.	Phase 2 Site Map—Building Area .....	4
Figure 4.	Phase 3 Proposed Site Plan .....	5
Figure 5.	Sample Modeled Hourly Load Profiles .....	12
Figure 6.	Phase 1A Monthly Load Profile .....	13
Figure 7.	Phase 1B Monthly Load Profile .....	14
Figure 8.	Phase 2 Monthly Load Profile .....	14
Figure 9.	Phase 3 Monthly Load Profile .....	15
Figure 10.	Phase 1A Hourly Load Profile .....	16
Figure 11.	Phase 1A Design Day Heating Load .....	16
Figure 12.	Phase 1A Design Day Cooling Load .....	17

Figure 13. Phase 1B Hourly Load Profile .....	17
Figure 14. Phase 1B Design Day Heating Load .....	18
Figure 15. Phase 1B Design Day Cooling Load .....	18
Figure 16. Phase 2 Hourly Load Profile.....	19
Figure 17. Phase 2 Design Day Heating Load.....	19
Figure 18. Phase 2 Design Day Cooling Load.....	20
Figure 19. Phase 3 Hourly Load Profile.....	20
Figure 20. Phase 3 Design Day Heating Load.....	21
Figure 21. Phase 3 Design Day Cooling Load.....	21
Figure 22. Site Locations for Phase 1A Buildings.....	30
Figure 23. Potential Site Locations for Phase 1B Buildings .....	31
Figure 24. Potential Site Locations for Phase 2 Buildings .....	32
Figure 25. Air Source HP Cooling Efficiency .....	49
Figure 26. Air Source Heat Pump Heating Efficiency .....	49

## List of Tables

---

Table 1. List of Potential Buildings–Phase 1A .....	2
Table 2. List of Potential Buildings–Phase 1B .....	3
Table 3. List of Potential Buildings–Phase 2 .....	5
Table 4. Phase 3 Potential Building List .....	6
Table 5. Peak and Annual Heating Load for Phase 1A Buildings .....	8
Table 6. Peak and Annual Heating Load for Phase 1B Buildings .....	8
Table 7. Peak and Annual Heating Load for Phase 2 Buildings.....	9
Table 8. Peak and Annual Heating Load for Phase 3 Buildings.....	9
Table 9. Peak and Annual Cooling Load for Phase 1A Buildings .....	10
Table 10. Peak and Annual Cooling Load for Phase 1B Buildings .....	10
Table 11. Peak and Annual Cooling Load for Phase 2 Buildings.....	11
Table 12. Peak and Annual Cooling Load for Phase 3 Buildings.....	11
Table 13. Phase 1A: Existing and Proposed Systems Energy Usage .....	23
Table 14. Phase 1B: Existing and Proposed Systems Energy Usage .....	23
Table 15. Phase 2: Existing and Proposed Systems Energy Usage.....	24
Table 16. Phase 3: Existing and Proposed Systems Energy Usage.....	25
Table 17. Baseline Utility Usage and Cost .....	25
Table 18. Avoided Carbon Emissions .....	28
Table 19. Phases 1A and 1B.....	33
Table 20. Phase 2.....	34
Table 21. Phase 3.....	34
Table 22. GHX Heating Capacity–Phase 1A .....	35
Table 23. GHX Heating Capacity–Phase 1B .....	35
Table 24. GHX Heating Capacity–Phase 2 .....	35
Table 25. GHX Heating Capacity–Phase 3 .....	36



Table 26. GHX Cooling Capacity–Phase 1A .....	36
Table 27. GHX Cooling Capacity–Phase 1B .....	36
Table 28. GHX Cooling Capacity–Phase 2.....	37
Table 29. GHX Cooling Capacity–Phase 3.....	37
Table 30. Annual HVAC Load Balance .....	38
Table 31. Baseline Construction Cost .....	41
Table 32. Proposed Construction Cost.....	42
Table 33. Utility Costs .....	42
Table 34. NIST Fuel Escalation Rates .....	44
Table 35. Project Net Present Value Summary .....	44
Table 36. Energy Use–Individual Heat Pump Scenario .....	50
Table 37. Energy Use–District Loop Scenario .....	50

# Executive Summary

---

As Troy continues its economic resurgence, the city wishes to be a leader in implementing the Climate Leadership and Community Protection Act (CLCPA) just as they have historically led in economic development over the centuries. Troy's downtown area initially developed as a prosperous, vibrant city as a result of its success in manufacturing and the dominance of water-based transportation and energy. With the manufacturing decline, the downtown started to deteriorate and lose its vitality. Recent investments, including the restoration of heritage buildings and public realm improvements, are attracting new interest and activity including a cluster of computer technology and gaming businesses—many founded by Rensselaer Polytechnic Institute (RPI) alumni. An update to the city master development plan was completed by the city in 2018, with an emphasis on smart, sustainable redevelopment of the downtown area in general and the waterfront area in particular.

As part of that redevelopment plan, the City of Troy is pursuing a District Energy System project, which is the implementation of a district geothermal system. The purpose of this project is to provide a high-efficiency heating and cooling district energy utility option to buildings in the downtown and waterfront areas. The project team consists of Siemens, the project coordinator; CHA Consulting, the project engineer; and the City of Troy. Various additional community stakeholders have also been engaged as part of this project.

This district energy project has been identified as a major supplemental component of the City of Troy's Downtown Revitalization Initiative and an ongoing riverfront area redevelopment, including the proposed construction of the One Monument Square redevelopment project and the Riverfront Park redevelopment. The project will provide a clean energy source for the One Monument Square building as well as a number of the surrounding facilities, extending the benefit of this clean energy resource beyond the current scope of new building construction to reach the existing community.

The study revealed that a district energy system would reduce the community's future energy consumption due to decreasing community coincident peak loads that will become smaller than the sum of individual building peak loads, greater equipment efficiencies of larger equipment, and the reduction of mechanical heating and cooling requirements due to the use of a geothermal system.

The plan for the Troy District Energy project is to implement the proposed district geothermal system in three phases over the next 10 years. Phase 1 has been split into two parts: Phase 1A and Phase 1B. This proposal is for Phase 1A and covers nine potential buildings in the northern waterfront area: One Monument Square, the Arts Center, the Troy Atrium Complex, and existing mixed-used multifamily or office buildings. The potential buildings were chosen for the district geothermal system because of their geographical proximity to the new construction development project at the old Troy City Hall location on River Street in downtown Troy.

Phase 1B consists of 12 buildings on the southern part of downtown, centered around Russell Sage College. This phase also incorporates several affordable housing redevelopment projects that are planned for the area. Phase 2 consists of a further build-out of Phase 1 to include all the other buildings in the downtown area that would be large enough to see a significant benefit from a district geothermal system. Phase 3 consists of the future redevelopment of the Troy waterfront area referenced as the Riverside district in the Realize Troy Comprehensive Plan published in 2018.

The enclosed study characterizes the required heating and cooling loads for a potential project and provides a preliminary cost basis for each phase that can be pursued further. Several heat sources were considered, with vertical borehole ground heat exchangers as the primary sources of heating, supplemented with river, air, and/or wastewater resources.

# 1 Task 1. Establish Baseline Conditions

---


This section presents the approach and assumptions that were used to determine existing utility usages. Two key elements comprise baseline data—weather-related usage and non-weather-related usage. Building loads such as heating and cooling loads can be directly correlated to the local weather, however, building loads that originate from lighting systems or domestic hot water use may have little correlation to the local weather.

If the weather is less severe in a given year, resulting in an overall reduction in consumption, the energy savings from an implemented measure will be adjusted to determine the level of savings that would have been achieved under a typical year’s weather conditions. A building’s load characteristic may also drift because of changes in occupancy profile.

## 1.1 Thermal Model—Heating and Cooling loads

The table below shows the list of buildings that are included for the energy baseline development under phase 1A, 1B, 2 and 3 of the project. Phase 3 buildings are yet to be constructed.


Figure 1. Phase 1A Site Map—Building Area



**Table 1. List of Potential Buildings–Phase 1A**

Building No.	Building Address	Building Type	Building SQFT
1	One Monument Square	Highrise Apartment	180,000
2	261–269 River Street	Midrise Apartment	63,000
3	2 3rd Street	Office and Retail	40,867
4	Third St	Office	16,720
5	Fourth St	Office	36,632
6	213 River St	Midrise Apartment	14,000
7	219 River St	Midrise Apartment	16,080
8	221–223 River Street	Midrise Apartment	3,450
9	251 River Street	Midrise Apartment	29,760
10	291 River Street	Midrise Apartment	14,000
Total:			400,509


**Figure 2. Phase 1B Site Map–Building Area**



**Table 2. List of Potential Buildings–Phase 1B**

<b>Building No.</b>	<b>Building Address</b>	<b>Building Type</b>	<b>Building SQFT</b>
11	Taylor 1	Midrise Apartment	100,000
12	Taylor 2	Midrise Apartment	100,000
13	Taylor 3	Midrise Apartment	100,000
14	Taylor 4	Midrise Apartment	100,000
15	Cowee Hall	Classroom	23,313
16	Slingerland Alumnae House	Dormitory	5,208
17	Roy Courtyard	Classroom	7,757
18	Hart Hall	Classroom	21,552
19	Ricketts Hall	Classroom	34,191
20	Manning Hall	Dormitory	27,798
21	Esteves School of Education	Classroom	12,600
22	Plum Memorial	Classroom	9,794
Total:			182,213

Figure 3. Phase 2 Site Map–Building Area



**Table 3. List of Potential Buildings–Phase 2**

Building No.	Building Address	Building Type	Building SQFT
23	100 2nd Street	Midrise Apartment	9,792
24	141 Congress Street	Midrise Apartment	66,508
25	1646 5th Avenue	Midrise Apartment	12,050
26	119 Congress Street	Midrise Apartment	13,158
27	51 State Street	Office	19,734
28	1700 6th Avenue	Office	15,250
29	57-59 State Street	Office	12,301
30	61 State Street	Office	10,124
31	State Street	Midrise Apartment	119,136
32	1776 6th Avenue	Office	47,958
33	1800 6th Avenue	Midrise Apartment	136,005
34	1801 6th Avenue	Office	36,886
35	2000 6th Avenue	Midrise Apartment	122,708
36	720 Federal Street	Midrise Apartment	152,874
37	503 Grand Street	Midrise Apartment	46,196
38	2001 5th Avenue	Office	33,085
39	92-96 Fourth Street	Office	11,844
40	30 3rd Street	Office	10,754
41	43 3rd Street	Midrise Apartment	5,147
42	32 2nd Street	Office	19,585
<b>Total:</b>			<b>901,095</b>

**Figure 4. Phase 3 Proposed Site Plan**





**Table 4. Phase 3 Potential Building List**

<b>Phase 3</b>		
<b>Building No.</b>	<b>Building Type</b>	<b>Building SQFT</b>
43	Midrise Apartment	235,672
44	Midrise Apartment	353,323
45	Midrise Apartment	262,779
46	Midrise Apartment	248,046
47	Midrise Apartment	260,960
48	Midrise Apartment	428,797
49	Midrise Apartment	49,145
50	Midrise Apartment	32,745
51	Midrise Apartment	24,880
52	Midrise Apartment	30,720
53	Midrise Apartment	6,160
54	Midrise Apartment	46,100
55	Midrise Apartment	31,015
56	Midrise Apartment	364,990
57	Midrise Apartment	141,540
58	Office	27,091
59	Office	22,694
Total:		2,566,657

Note: For modelling purpose, buildings greater than 10 floors are considered as Highrise, and the ones greater than 3 floors up to 10 are considered mid-rise.

Since no detailed utility bills were available for all the buildings to generate the baseline, an alternate method of estimating heating and cooling loads for the system was necessary. It was determined that the best approach for this study was to use models of reference buildings of various building types obtained from the DOE to estimate energy use per square foot. Building energy uses and model details are available for many different types of buildings and various American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) climate zones. Based on the potential end-user buildings that were considered for the project, as well as a plan for potential future development, most of the Troy buildings were placed into three main categories (or some combination of them): apartment/multifamily home, retail space, and office space.

It was also necessary to consider two different types (vintages) of building construction since the potential buildings in the system are either existing construction to be updated, or brand-new construction (specifically the buildings located in the future waterfront development to the south of the proposed centralized plant). In order to account for this, two sets of models were created: one for ASHRAE 90.1 new construction reference buildings for the new buildings and one for ASHRAE 90.1 existing reference buildings constructed before 1980 for the existing buildings. Descriptions of each of the three building types can be seen below, as well as some information showing the differences between the two construction types:

- Midrise Apartment—The midrise apartment is a four-floor multifamily residential building with each floor consisting of eight apartments and one corridor. On the ground floor, however, the apartment space in the southeast corner of the building is replaced with an office space. Each space has a floor-to-ceiling height of 10 ft.
- Medium Office—The medium office is a three-floor office building consisting of one core-zone on each floor surrounded by four perimeter zones in each direction with a depth of 15 ft. from the external wall. Each space has a floor-to-ceiling height of 9 ft. with a 4 ft. above-ceiling plenum.
- Strip mall Retail—The strip mall retail is a single floor building consisting of ten conditioned retail spaces, two large and eight small, with windows on the south (entrance) side only. Each space has a floor-to-ceiling height of 17 ft.
- High-rise Apartment—The high-rise apartment is a 10-floor multifamily residential building with each floor consisting of eight apartments and one corridor. On the ground floor, however, the apartment space in the southeast corner of the building is replaced with an office space. Each space has a floor-to-ceiling height of 10 ft.
- Sit-down Restaurant—The sit-down restaurant is a single floor non-residential building with a kitchen and dining space, as well as an unconditioned attic space over the entire floor area. Windows wrap around the outer walls of the dining space, while the kitchen has none. Both the dining and kitchen spaces have a ceiling-to-ceiling height of 10 ft, the attic has a pitched roof.

## 1.2 Develop Interval Profiles

After constructing the models in EnergyPlus, each model was simulated using weather data from the representative city for the 5A climate zone specified by ASHRAE 90.1. This was necessary to accurately match the energy end-uses of each model to the end-uses of the DOE reference buildings. Once each model was sufficiently close to the reference building, the weather data for that building was changed to Albany to accurately reflect Troy’s local weather conditions. These Albany-based models were used as the base case data for comparison to the proposed system. Using these models, an 8,760-hour continuum heating, cooling and domestic hot water load was generated and used to build a load profile for each building.

Many of the buildings in the system fall into multiple building types, typically consisting of one ground floor retail space (sometimes an office) with multiple floors of apartments above. In order to account for this combination of building types, each building was given two building types, as well as a percentage of floor space represented by that type. For example, a building with one floor retail and three floors of apartments was given a space type of “Midrise Apartment” with a percentage of 75 percent, and a second

space type of “Retail” with a percentage of 25 percent. Additionally, since each building is a different physical size than the reference model buildings, each space type was given a “Space Ratio” which was calculated as a ratio of the building’s floor area compared to the floor area of the respective reference model.

This approach allowed for the ability to generate baseline load profiles at a granular level as shown in Table 2 and Table 3 below. Hourly loads for individual buildings were summed together to obtain an hourly baseline load for all of the buildings combined. The combined load was then used to determine monthly peaks and totals.

**Table 5. Peak and Annual Heating Load for Phase 1A Buildings**

<b>Buildings</b>	<b>One Monument Square</b>	<b>231–239 River Street</b>	<b>261–269 River Street</b>	<b>23rd Street</b>	<b>3rd Street</b>	<b>4th Street</b>	<b>213 River Street</b>	<b>219 River Street</b>	<b>221–223 River Street</b>	<b>251 River Street</b>	<b>Total</b>
Peak Heating (MMBtu/hr.)	1.15	1.66	1.30	0.22	0.48	0.41	0.41	0.24	0.22	0.95	<b>6.45</b>
Annual Heating (MMBtu/year)	2235	2693	1008	163	357	328	593	523	487	1253	<b>9,316</b>

**Table 6. Peak and Annual Heating Load for Phase 1B Buildings**

	<b>Taylor-1</b>	<b>Taylor-2</b>	<b>Taylor-3</b>	<b>Taylor-4</b>	<b>Cowee Hall</b>	<b>Slingerland Alumnae House</b>	<b>Roy Courtyard</b>	<b>Hart Hall</b>	<b>Ricketts Hall</b>	<b>Manning Hall</b>	<b>Esteves School of Education</b>	<b>Plum Memorial</b>	<b>Total</b>
Peak Heating (MMBtu/hr.)	1.81	1.81	1.81	1.81	0.72	0.09	0.24	0.67	1.06	0.50	0.39	0.30	<b>10.69</b>
Annual Heating (MMBtu/year)	4,380	4,380	4,380	4,380	443	228	147	409	649	1,218	239	186	<b>21,039</b>

**Table 7. Peak and Annual Heating Load for Phase 2 Buildings**

	<b>100 2nd Street</b>	<b>141 Congress Street</b>	<b>1646 5th Avenue</b>	<b>119 Congress Street</b>	<b>51 State Street</b>	<b>1700 6th Avenue</b>	<b>57-59 State Street</b>	<b>61 State Street</b>	<b>State Street</b>	<b>1776 6th Avenue</b>	<b>1800 6th Avenue</b>	<b>1801 6th Avenue</b>
Peak Heating (MMBtu/hr.)	0.13	0.53	0.1	0.1	0.26	0.2	0.16	0.13	0.95	0.63	2.46	0.49
Annual Heating (MMBtu/year)	96	1,264	229	250	193	149	120	99	2,265	468	5,967	360

**Table 7 continued**

	<b>2000 6th Avenue</b>	<b>720 Federal Street</b>	<b>503 Grand Street</b>	<b>2001 5th Avenue</b>	<b>92-96 4th Street</b>	<b>30 3rd Street</b>	<b>43 3rd Street</b>	<b>32 2nd Street</b>	<b>Total</b>
Peak Heating (MMBtu/hr.)	2.22	2.77	0.84	0.44	0.16	0.14	0.09	0.26	<b>12.08</b>
Annual Heating (MMBtu/year)	5,375	6,696	2,023	323	116	105	225	191	<b>26,504</b>

**Table 8. Peak and Annual Heating Load for Phase 3 Buildings**

	<b>Building-1</b>	<b>Building-2</b>	<b>Building-3</b>	<b>Building-4</b>	<b>Building-5</b>	<b>Building-6</b>	<b>Building-7</b>	<b>Building-8</b>
Peak Heating (MMBtu/hr.)	2.51	3.29	2.80	2.64	2.43	3.99	0.54	0.36
Annual Heating (MMBtu/year)	5172	7235	5766	5443	5344	8781	1094	729

**Table 8 continued**

	<b>Building-9</b>	<b>Building-10</b>	<b>Building-11</b>	<b>Building-12</b>	<b>Building-13</b>	<b>Building-14</b>	<b>Building-15</b>	<b>Building-16</b>	<b>Building-17</b>	<b>Total</b>
Peak Heating (MMBtu/hr.)	0.27	0.34	0.07	0.51	0.34	3.45	1.71	0.52	0.43	<b>52.37</b>
Annual Heating (MMBtu/year)	554	684	137	1027	691	7534	3291	738	601	<b>109,649</b>

**Table 9. Peak and Annual Cooling Load for Phase 1A Buildings**

<b>Buildings</b>	<b>231-239 River Street</b>	<b>261-269 River Street</b>	<b>23rd Street</b>	<b>3rd Street</b>	<b>4th Street</b>	<b>213 River Street</b>	<b>219 River Street</b>	<b>221-223 River Street</b>	<b>251 River Street</b>	<b>Total</b>
Peak Cooling (Tons.)	110.9	111.8	112.3	34.4	75.5	32	23.9	4.9	63.7	<b>557.87</b>
Annual Cooling (MMBtu/year)	1,763	505	790	374	820	125	175	33	288	<b>4,872</b>

**Table 10. Peak and Annual Cooling Load for Phase 1B Buildings**

	<b>Taylor-1</b>	<b>Taylor-2</b>	<b>Taylor-3</b>	<b>Taylor-4</b>	<b>Cowee Hall</b>	<b>Slingerland Alumnae House</b>	<b>Roy Courtyard</b>	<b>Hart Hall</b>	<b>Ricketts Hall</b>	<b>Manning Hall</b>	<b>Esteves School of Education</b>	<b>Plum Memorial</b>	<b>Total</b>
Peak Cooling (Tons.)	120.7	120.7	120.7	120.7	58.0	6.2	19.3	53.6	85	33.5	31.3	24.3	<b>769</b>
Annual Cooling (MMBtu/year)	525	525	525	525	311	27	103	288	456	146	168	131	<b>3,729</b>

**Table 11. Peak and Annual Cooling Load for Phase 2 Buildings**

	<b>100 2nd Street</b>	<b>141 Congress Street</b>	<b>1646 5th Avenue</b>	<b>119 Congress Street</b>	<b>51 State Street</b>	<b>1700 6th Avenue</b>	<b>57-59 State Street</b>	<b>61 State Street</b>	<b>State Street</b>	<b>1776 6th Avenue</b>	<b>1800 6th Avenue</b>	<b>1801 6th Avenue</b>
Peak Cooling (Tons.)	20.1	43.1	7.82	8.54	40.6	31.4	25.3	20.8	77.3	98.87	164	76.0
Annual Cooling (MMBtu/year)	219	827	149	163	441	341	275	226	1482	1072	713	825

**Table 11 continued**

	<b>2000 6th Avenue</b>	<b>720 Federal Street</b>	<b>503 Grand Street</b>	<b>2001 5th Avenue</b>	<b>92-96 Fourth Street</b>	<b>30 3rd Street</b>	<b>43 3rd Street</b>	<b>32 2nd Street</b>	<b>Total</b>
Peak Cooling (Tons.)	148.1	184.5	55.76	68.21	24.42	22.17	6.21	40.38	<b>1,156</b>
Annual Cooling (kWh)	644.0	802.3	242.4	740.1	264.9	240.5	27.01	438.1	<b>10,139</b>

**Table 12. Peak and Annual Cooling Load for Phase 3 Buildings**


	<b>Building-1</b>	<b>Building-2</b>	<b>Building-3</b>	<b>Building-4</b>	<b>Building-5</b>	<b>Building-6</b>	<b>Building-7</b>	<b>Building-8</b>
Peak Cooling (Tons.)	191.3	255.8	213.3	201.3	188.9	310.5	40.90	27.25
Annual Cooling (kWh)	2,671	4,200	2,978	2,811	3,102	5,097	551	367

**Table 12 continued**

	<b>Building-9</b>	<b>Building-10</b>	<b>Building-11</b>	<b>Building-12</b>	<b>Building-13</b>	<b>Building-14</b>	<b>Building-15</b>	<b>Building-16</b>	<b>Building-17</b>	<b>Total</b>
Peak Cooling (Tons.)	20.71	25.57	5.13	38.37	25.81	267.3	126.4	58.76	53.83	<b>2,026</b>
Annual Cooling (kWh)	279	344	69	517	348	4,316	1,534	841	757	<b>30,780</b>

The graph below shows hourly load profiles for two sample buildings. Similar load profiles were generated for all buildings and phases.

**Figure 5. Sample Modeled Hourly Load Profiles**




The next step was to create models for each building type to represent the energy use when using the proposed heat pump system. This was done by replacing the original HVAC systems that were in each model with a new water source heat pump (WSHP) system. Models were simulated with new system types to generate new yearly energy end-use data that could be compared to the data associated with the original HVAC systems. The data for both the baseline conditions and the new proposed conditions can then be used to determine annual utility consumption. Factoring in the utility rates for electricity, natural gas, district cooling and district heating, the operational cost and energy cost savings associated with using a WSHP district energy system compared to the original systems can be calculated.

### 1.3 Monthly Load Profiles


The graphs below show monthly net load profiles for each phase. Noted that the graphs show positive values for heating dominant months and negative values for cooling dominant months. The coincident cooling and heating loads offset each other. These graphs indicate that Troy, NY is a heating dominant area. The geothermal loop needs to be designed with this in mind, as an annual imbalance in loads will affect the long term temperature of the surrounding ground, and the performance of the ground heat exchanger.

**Figure 6. Phase 1A Monthly Load Profile**







**Figure 7. Phase 1B Monthly Load Profile**



**Figure 8. Phase 2 Monthly Load Profile**




**Figure 9. Phase 3 Monthly Load Profile**




### **1.4 Hourly and Design Day Load Profiles**

The graph below shows hourly load profiles for each phase. The peak loads noted here will be used to size the district system's peak capacity. It is to be noted that the heating dominated hours are shown as positive values in the graphs and the cooling dominant hours are shown as negative values in the graphs.


**Figure 10. Phase 1A Hourly Load Profile**




**Figure 11. Phase 1A Design Day Heating Load**




**Figure 12. Phase 1A Design Day Cooling Load**




**Figure 13. Phase 1B Hourly Load Profile**




**Figure 14. Phase 1B Design Day Heating Load**




**Figure 15. Phase 1B Design Day Cooling Load**




**Figure 16. Phase 2 Hourly Load Profile**




**Figure 17. Phase 2 Design Day Heating Load**




**Figure 18. Phase 2 Design Day Cooling Load**




**Figure 19. Phase 3 Hourly Load Profile**



**Figure 20. Phase 3 Design Day Heating Load**



**Figure 21. Phase 3 Design Day Cooling Load**





## 1.5 Temporal Coincidence of Loads

Buildings were grouped into different phases based on type of building and location to optimize the energy load balance and the capital costs. Multifamily residential buildings generally have extended periods of heating in a year compared to cooling, whereas retail and office spaces see cooling requirements for extended periods of the year. This is because retail and office spaces see a lot of internal loads (equipment, people), which add heat to the space. A balanced mix of these building types have been considered to minimize energy imbalance. As seen in the tables above each phase has a mix of apartment buildings as well as retail and office spaces to help balance thermal loads. However, close consideration was given to proximity from the river and proposed borefield locations so that piping costs do not undermine the economics of the project.

Sizing of geothermal systems is most efficient when the cooling and heating energy required from the ground is equal. As important as it is to balance annual loads to ensure the geothermal loop doesn't extract too much heat from the ground, it is also important to increase efficiency of the loop by matching loads such that simultaneous cooling and heating is taken care of by the loop by shifting energy around, rather than by extracted more energy from the ground. Our 8760-model looked at hours where some buildings require cooling and others require heating where the loads could offset each other without required an outside energy source. This is also seen in our monthly load profiles above. Included in the analysis is this diversity factor which will increase as more buildings are added to the loop.

## 1.6 Preliminary Utility Usage

Tables 5 show the annual heating and cooling requirements for all included buildings. In the existing scenario, the existing system type is not known in every building, therefore assumptions were made based on the type of buildings, size, age and known characteristics of typical buildings of that profile. The heating plants are assumed be a form of natural gas combustion with a combined average overall fuel to heating efficiency of 76 percent and the baseline thermal usage is calculated using this value. The buildings at Russell Sage college are heated by cast iron sectional boilers. The heating system for the other buildings need to be surveyed. All buildings are assumed to be cooled by air cooled DX type systems, with the typically least expensive option of PTACs chosen. The overall cooling EER is assumed to be 10.2.

In the proposed scenario all buildings are assumed to be heated and cooled by a water source heat pump district energy system. The proposed system is expected to have a COP of 4.3 for heating and an average EER of 20.1 for cooling.

**Table 13. Phase 1A: Existing and Proposed Systems Energy Usage**

<b>Phase 1A</b>	<b>Thermal Load</b>	<b>Existing Annual Heating</b>	<b>Existing Annual Cooling Load</b>	<b>Existing Annual Cooling</b>	<b>Proposed Annual Heating</b>	<b>Proposed Annual Cooling</b>
<b>Building</b>	<b>MMBtu/yr.</b>	<b>Therms</b>	<b>MMBtu/yr.</b>	<b>kWh</b>	<b>kWh</b>	<b>kWh</b>
1 Monument-Sq 231-239 River St.	2236	29,421	1,763	50,481	152,402	25,708
261-269 River Street	2693	35,435	505	14,455	183,557	7,361
2 3rd Street	1008	13,267	790	22,630	68,726	11,525
Third St	163	2,147	374	10,710	11,124	5,454
Fourth St	358	4,705	820	23,465	24,371	11,950
213 River Street	594	7,812	125	3,567	40,469	1,816
219 River Street	524	6,891	175	5,018	35,694	2,556
221-223 River Street	487	6,408	33	941	33,195	479
251 River Street	1253	16,491	288	8,242	85,426	4,197
<b>Totals:</b>	<b>9,316</b>	<b>122,578</b>	<b>4,872</b>	<b>139,510</b>	<b>634,963</b>	<b>71,046</b>

**Table 14. Phase 1B: Existing and Proposed Systems Energy Usage**

<b>Phase 1B</b>	<b>Thermal Load</b>	<b>Existing Annual Heating</b>	<b>Existing Annual Cooling Load</b>	<b>Existing Annual Cooling</b>	<b>Proposed Annual Heating</b>	<b>Proposed Annual Cooling</b>
<b>Building</b>	<b>MMBtu/yr.</b>	<b>Therms</b>	<b>MMBtu/yr.</b>	<b>kWh</b>	<b>kWh</b>	<b>kWh</b>
Taylor-1	4,380	57,633	525	15,027	298,544	7,653
Taylor-2	4,380	57,633	525	15,027	298,544	7,653
Taylor-3	4,380	57,633	525	15,027	298,544	7,653
Taylor-4	4,380	57,633	525	15,027	298,544	7,653
Cowee Hall	443	5,823	311	8,905	30,161	4,535
Slingerland Alumnae House	228	3,002	27	783	15,548	399
Roy Courtyard	147	1,937	103	2,963	10,036	1,509
Hart Hall	409	5,383	288	8,232	27,883	4,192
Ricketts Hall	649	8,539	456	13,060	44,235	6,651
Manning Hall	1,218	16,021	146	4,177	82,989	2,127
Esteves School of Education	239	3,147	168	4,813	16,301	2,451
Plum Memorial	186	2,446	131	3,741	12,671	1,905
<b>Totals:</b>	<b>21,039</b>	<b>276,830</b>	<b>3,729</b>	<b>106,782</b>	<b>1,433,998</b>	<b>54,379</b>

**Table 15. Phase 2: Existing and Proposed Systems Energy Usage**

<b>Phase 2</b>	<b>Thermal Load</b>	<b>Existing Annual Heating</b>	<b>Existing Annual Cooling Load</b>	<b>Existing Annual Cooling</b>	<b>Proposed Annual Heating</b>	<b>Proposed Annual Cooling</b>
<b>Building</b>	<b>MMBtu/yr.</b>	<b>Therms</b>	<b>MMBtu/yr.</b>	<b>kWh</b>	<b>kWh</b>	<b>kWh</b>
100 2nd Street	96	1,258	219	6,272	6,515	3,194
141 Congress Street	1,264	16,637	828	23,694	86,182	12,066
1646 5th Avenue	229	3,014	150	4,293	15,615	2,186
119 Congress Street	250	3,292	164	4,688	17,050	2,387
51 State Street	193	2,535	441	12,641	13,129	6,438
1700 6th Avenue	149	1,959	341	9,769	10,146	4,975
57-59 State Street	120	1,580	275	7,880	8,184	4,013
61 State Street	99	1,300	226	6,485	6,736	3,303
State Street	2,265	29,802	1482	42,443	154,379	21,614
1776 6th Avenue	468	6,159	1073	30,721	31,906	15,645
1800 6th Avenue	5,957	78,384	714	20,438	406,034	10,408
1801 6th Avenue	360	4,737	825	23,628	24,540	12,033
2000 6th Avenue	5,375	70,720	644	18,440	366,337	9,391
720 Federal Street	6,696	88,106	802	22,973	456,396	11,699
503 Grand Street	2,023	26,624	242	6,942	137,915	3,535
2001 5th Avenue	323	4,249	740	21,193	22,011	10,793
92-96 Fourth Street	116	1,521	265	7,587	7,880	3,864
30 3rd Street	105	1,381	241	6,889	7,155	3,508
43 3rd Street	225	2,966	27	773	15,366	394
32 2nd Street	191	2,515	438	12,546	13,030	6,389
<b>Totals:</b>	<b>26,504</b>	<b>348,741</b>	<b>10,139</b>	<b>290,294</b>	<b>1,806,506</b>	<b>147,833</b>

**Table 16. Phase 3: Existing and Proposed Systems Energy Usage**

<b>Phase 3</b>	<b>Thermal Load</b>	<b>Existing Annual Heating</b>	<b>Existing Annual Cooling Load</b>	<b>Existing Annual Cooling</b>	<b>Proposed Annual Heating</b>	<b>Proposed Annual Cooling</b>
<b>Building</b>	<b>MMBtu/yr.</b>	<b>Therms</b>	<b>MMBtu/yr.</b>	<b>kWh</b>	<b>kWh</b>	<b>kWh</b>
Building-1	5,172	68,053	2,671	76,463	352,519	38,939
Building-2	7,236	95,206	4,200	120,254	493,172	61,240
Building-3	5,767	75,880	2,978	85,258	393,066	43,418
Building-4	5,444	71,626	2,811	80,478	371,029	40,984
Building-5	5,344	70,318	3,102	88,818	364,251	45,231
Building-6	8,781	115,543	5,097	145,942	598,520	74,321
Building-7	1,095	14,402	551	15,771	74,603	8,032
Building-8	729	9,596	367	10,508	49,708	5,351
Building-9	554	7,291	279	7,984	37,768	4,066
Building-10	684	9,003	344	9,858	46,634	5,020
Building-11	137	1,805	69	1,977	9,351	1,007
Building-12	1,027	13,510	517	14,794	69,981	7,534
Building-13	691	9,089	348	9,953	47,082	5,069
Building-14	7,534	99,132	4,316	123,580	513,513	62,934
Building-15	3,291	43,300	1,534	43,922	224,297	22,367
Building-16	738	9,712	841	24,073	50,309	12,259
Building-17	601	7,910	757	21,675	40,974	11,038
<b>Totals:</b>	<b>54,825</b>	<b>721,375</b>	<b>30,780</b>	<b>881,310</b>	<b>3,736,777</b>	<b>448,811</b>

## 1.7 Baseline Energy Use and Utility Costs

Based on available utility data from National Grid, the electricity rate in Troy, NY is estimated to vary from \$0.8/kWh to \$0.12/kWh, and natural gas price is estimated to vary from \$7/MMBtu to \$9/MMBtu. Average rates of \$0.10/kWh and \$8/MMBtu are therefore used for this report. The table below shows the utility cost of operating the existing heating and cooling system.

**Table 17. Baseline Utility Usage and Cost**

	<b>Existing Annual Therms Usage</b>	<b>Existing Annual kWh Usage</b>	<b>Existing Annual Utility Cost</b>
Phase 1A	122,578	139,510	\$112,013
Phase 1B	276,830	106,782	\$232,142
Phase 2	348,741	290,294	\$308,022
Phase 3	721,375	881,310	\$665,231
<b>Total</b>	<b>1,574,308</b>	<b>1,207,316</b>	<b>\$1,317,408</b>

## 1.8 Life-Cycle Cost for Baseline

Life-cycle cost analyses (LCCA) provide the cost of ownership of the WSHP over the equipment life of the system. The costs that are incorporated into the life-cycle analysis are as follows:

- initial construction
- electricity and natural gas costs of system operation
- operation, maintenance, and repair
- replacement costs

It is to be noted that per the NYS DEC, State agencies are to use a social cost of carbon at \$123/ton CO<sub>2</sub>. However, this was not included in the LCCA. A life cycle of 25 years was utilized in all LCCA models.

### 1.8.1 Initial Construction Costs

The table below shows the preliminary cost estimate of installing the baseline building system. The baseline building system includes boilers in each building to generate heating hot water for the building's heat, as well as packaged terminal air conditioner (PTAC) units in each room to provide cooling. The PTACs are assumed to have a hydronic coil to utilize heat from the heating hot water. In each case, it is assumed that the existing terminal equipment in these buildings is at their end of life, and that replacements are required in Year 1 of the LCCA. Since boilers last longer and we did not know the age of the existing equipment in each building, it was assumed that 10 percent of boiler infrastructure will be replaced from year 10 through year 19 in our LCCA.

For the proposed system, a ground source heat pump system is considered, with water to air water-source heat pumps in each building providing all of the heating and cooling. A central plant adjacent to the geothermal borefield site would house pumps, heat exchangers, controls, and any other ancillary equipment needed to send the condenser water out to the buildings. In the buildings, it is assumed that water-source heat pumps are installed. An allowance is included for distribution piping going to the water-source heat pumps in each building.

## **1.8.2 Electricity and Natural Gas Costs of System Operation**

See previous section, “Preliminary Utility Usage,” for discussion and results of the annual electricity and natural gas costs for all buildings. A National Institute of Standards and Technology (NIST) paper<sup>1</sup> was used to calculate the electricity and natural gas escalation rates. The model assumes that general economic inflation is set at 3 percent in the foreseeable future; the actual escalation rates for both electric and gas differ, with electric seeing a more rapid increase in unit cost. Please see the section on “Net Present Value Analysis” (NPV Analysis) in the Task 4 portion of this report for the escalation rates used for gas and electric.

Also, a system efficiency degradation of 0.25 percent per year was used in the analysis, for both existing and proposed systems.

## **1.8.3 Operation, Maintenance, and Repair Costs**

The boilers in these buildings will be significantly more expensive to operate than the geothermal system with water-source heat pumps in the spaces. Initial estimates are that total baseline operations, maintenance, and repair costs will total about \$4,500 per year per building. In comparison, only \$4,500 per year is estimated for the proposed case for each central plant. An escalation rate for the O&M costs of 3 percent per year is used in the analysis.

## **1.8.4 Replacement Costs**

According to ASHRAE, commercial water-source heat pumps (WSHPs) have a 19-year life cycle, whereas the baseline PTAC units only have a 15-year life cycle.

To account for these shorter life cycles in the LCCA, it is assumed that some WSHP’s start failing 5 years before expected life and the last ones fail 5 years after the expected life. This results in 10 percent of the units failing from Year 14 through Year 23. The failure rate is assumed to drop to 5 percent for years 24 and 25 as most of the WSHP’s would be new at that point.

---

<sup>1</sup> Energy Price Indices and Discount Factors for Life-Cycle Cost Analysis–2021  
<https://nvlpubs.nist.gov/nistpubs/ir/2021/NIST.IR.85-3273-36.pdf>

For the PTAC units, the same is assumed; the first 10 percent of units would fail in year 10 and the last units would fail in year 19. In years 20 through 22, most of the units would be relatively new and the failure rate is assumed to drop to 5 percent for those years. In year 23, the oldest units begin to fail, and the rate goes back up to 10 percent.

### 1.8.5 Net Present Value Analysis (NPV) Results

Please refer to Task 4— “Perform economic analysis” for detailed results on the Net Present Value (NPV).

## 1.9 Environmental Footprint

The project will have a significant positive impact on the environment, hence there will be a reduction of emissions as shown below. The greenhouse gas emissions and CO<sub>2</sub> equivalence are calculated using DOE’s greenhouse gas equivalencies calculator. A value of 200g CO<sub>2</sub> equivalent per kilowatt-hour of electricity (eq/kWh) was used for the grid electricity mix in New York State.<sup>2</sup> The social cost of carbon was taken as \$123/ton based on a paper released by the DEC in the State.<sup>3</sup>

**Table 18. Avoided Carbon Emissions**

Phase	Annual Tons of CO <sub>2</sub> Emission Avoided	Annual Social Cost of Avoided Emissions
1A	440	\$54,120
1B	1,224	\$150,552
2	1,985	\$244,155
3	3,102	\$381,546

---

<sup>2</sup> United States Environmental Protection Agency–Greenhouse Gas Equivalencies Calculator; <https://www.epa.gov/energy/greenhouse-gas-equivalencies-calculator>

<sup>3</sup> New York State Department of Environmental Conservation–Establishing a Value of Carbon; Guidelines for Use By State Agencies; [https://www.dec.ny.gov/docs/administration\\_pdf/vocguidrev.pdf](https://www.dec.ny.gov/docs/administration_pdf/vocguidrev.pdf)

## 2 Task 3. Determine Optimal Energy Source and Develop Conceptual Design

---

### 2.1 Vertical Bore Closed Loop System

Vertical boreholes provide a passive source of heat and heat rejection from the ground. A 495-foot deep bore is proposed, as closed loop geothermal boreholes in New York State are subject to additional regulations by the Department of Environmental Conservation (DEC) when drilled beyond 500 ft. Deeper wells are technically possible and have been attempted elsewhere: however, the current regulatory statutes create a barrier to installation by treating them as oil and gas wells with additional permitting and escrow requirements. If the borefield is municipally owned, there may be relief available to the escrow requirements.

#### Borehole Layout

- Spacing of 20 ft. on center in a grid pattern for boreholes typically provides an optimal tradeoff between land area and performance. However, in this land constrained condition a staggered spacing—15 ft. on center with each row offset from the adjacent rows—is more effective at getting additional boreholes in the same fixed area, and still allows for an average 21 ft. spacing between boreholes.

- Geology

A thermal conductivity test has not been completed at this time; however, data was available from several structure bores in the vicinity. We expect loose gravel/fill until about 50 ft., then a formation of tight, wet, shale. The associated average thermal conductivity of the rock formations is taken to be 1.3 Btu/hr. ft. F and the thermal diffusivity for wet shale is 0.55 ft<sup>2</sup>/day. Additionally, ground water was observed at 17–20 ft. below grade, which would coincide with the depth of the nearby sea wall.

A building across the street from the 1 Monument square site also has a geothermal borefield, and in interviews with the design team from that project, they did not report any issues with drilling in the immediate vicinity.

- Grout

A graphite enhanced bentonite will be utilized to provide a minimum thermal conductivity of 1.2 Btu/hr. ft. F.



## 2.2 Potential Ground Loop Heat Exchanger (GLHX) Site

The map below shows the location of the sites that are identified for the installation of the vertical bores. A total of seven land sites for vertical bores and one river water heat exchanger site were identified for buildings that are enlisted under Phases 1A and 1B. A total of 156,000 ft.<sup>2</sup> is available for borehole construction. The one borefield location is highlighted in yellow in Figure 22 and seven borefield locations are highlighted in yellow in Figures 23. The blue area outlined in Figure 23 is the boundary of Russell Sage College.

Figure 22. Site Locations for Phase 1A Buildings






Figure 23. Potential Site Locations for Phase 1B Buildings





Figure 24. Potential Site Locations for Phase 2 Buildings



## 2.3 Centralized System Overview

There are two central plants for Phases 1A and 1B of the project, and the central plants are shown in Figures 4 and 5, highlighted in blue. The boreholes will utilize a ground loop heat exchanger (GHX) and the river water loop will utilize a river water heat exchanger (River HX) to connect to the central plant. The central plant will house the pumping system that will pump either water or a water/glycol mix to the end-user buildings via the central loop.

**Table 19. Phases 1A and 1B**

Phase	Proposed System	Total Heating Load on GHX (MMBtu)	Total Cooling Load on GHX (MMBtu)	Served By System	Area Available for Bores (sf)	Number of Boreholes	Borehole Grid Structure
1A	Central Plant - 1	7,044	4,872	Potential GHX Site 7, River HX 1	50,198	150	25 x 6
				Phase 1 A Totals	<b>50,198</b>	<b>150</b>	
1B	Central Plant - 2	15,908	3,729	Potential GHX Site 1	20,079	45	5 x 9
				Potential GHX Site 2	20,952	49	7 x 7
				Phase 1B Totals	<b>41,031</b>	<b>94</b>	
1B Sage	Central Plant - 2	15,908	3,729	Potential GHX Site 3	15,278	75	5 x 15
				Potential GHX Site 4	8,730	27	9 x 3
				Potential GHX Site 5	23,571	48	8 x 6
				Potential GHX Site 6	17,460	40	5 x 8
				Phase 1B Sage Totals	<b>65,039</b>	<b>190</b>	

**Table 20. Phase 2**

Phase	Proposed System	Total Heating Load on GHX (MMBtu)	Total Cooling Load on GHX (MMBtu)	Served By System	Area Available for Bores (sf)	Number of Boreholes	Borehole Grid Structure
Phase 2	Central Plant 4, 5, and 6	20,040	10,139	Potential GHX Site - 8	26,190	55	11 x 5
				Potential GHX Site - 9	17,024	45	9 x 5
				Potential GHX Site - 10	17,024	40	5 x 8
				Potential GHX Site - 11	30,119	66	11 x 6
				Potential GHX Site - 13	8,730	24	6 x 4
				River HX - 2	-	-	-
					<b>99,087</b>	<b>230</b>	

**Table 21. Phase 3**

Building	Proposed System	Total Heating Load on GHX (MMBtu)	Total Cooling Load on GHX (MMBtu)	Served By System	Square-Foot Available for Bores	Number of Boreholes	Borehole Grid Structure
Phase 3	Central Plant - 3	41,453	30,780	Potential GHX Site 12	192,060	440	21 x 21

## 2.4 System Sizing

The heating degree days (HDD) and the cooling degree days (CDD) for this location were compared using a base temperature of 65°F. The HDD are significantly higher than the CDD; as a result, the buildings have a heating dominant load.

### 2.4.1 Heating Load

The tables below show the hourly and the annual heating load for different phases. The hourly GHX capacity for the sites is calculated based on a capacity of 2.3 tons/bore. The annual thermal energy available from the sites was obtained from a bin analysis. The annual heat loads for all buildings under each phase were added to obtain a combined hourly and annual value.

It is notable that on an annual basis, the GHX nearly meets or exceeds the heat load for Phases 1a and 1b; however, to meet the peak load of the buildings, we would need to add a river HX to supplement the GHX. For Phases 2 and 3 the GHX capacity falls short by 10 percent and 42 percent respectively. For these two phases as well, we would need to add either a river HX or wastewater heat recovery from the sewer system to supplement the GHX to meet the peak load.

During the design phase, adding more boreholes, increasing the size of the river heat exchanger or sewer wastewater heat recovery can be considered for all the phases based on the results of the conductivity test which is being performed on each site.

**Table 22. GHX Heating Capacity–Phase 1A**

Phase 1A	Hourly Peak Load	Annual Load
	MMBtu/hr.	MMBtu/yr.
Total Building Load	4.88	5,931
GHX Capacity	4.14	8,190
% Load Delivered by GHX	85%	138.1%
% Load Delivered by River HEX/Heat Recovery	15%	(38%)

**Table 23. GHX Heating Capacity–Phase 1B**

Phase 1B	Hourly Peak Load	Annual Load
	MMBtu/hr.	MMBtu/yr.
Total Building Load	10.69	15,908
GHX Capacity	7.84	15,506
% Load Delivered by GHX	73%	97.5%
% Load Delivered by River HEX/Heat Recovery	27%	2.5%

**Table 24. GHX Heating Capacity–Phase 2**

Phase 2	Hourly Peak Load	Annual Load
	MMBtu/hr.	MMBtu/yr.
Total Building Load	12.08	27,051
GHX Capacity	6.35	24,391
% Load Delivered by GHX	53%	90%
% Load Delivered by River HEX/Heat Recovery	47%	10%

**Table 25. GHX Heating Capacity–Phase 3**

<b>Phase 3</b>	<b>Hourly Peak Load</b>	<b>Annual Load</b>
	<b>MMBtu/hr.</b>	<b>MMBtu/yr.</b>
Total Building Load	19.42	41,453
GHX Capacity	12.14	24,023
% Load Delivered by GHX	63%	58.0%
% Load Delivered by River HEX/Heat Recovery	37%	42%

## 2.4.2 Cooling Load

The tables below show the peak hourly and the annual cooling load for different phases. Cooling loads for all buildings under each phase were added to obtain a combined hourly and annual value.

It is to be noted that on an annual basis, the GHX exceeds the annual cooling load requirement for all phases. However, to meet the peak cooling capacity, we would need to couple the GHX with a river HX or a sewer wastewater heat recovery system.

**Table 26. GHX Cooling Capacity–Phase 1A**

<b>Phase 1A</b>	<b>Hourly Peak Load</b>	<b>Annual Load</b>
	<b>Tons</b>	<b>MMBtu/yr.</b>
Total Building Load	558	4,872
GHX Capacity	345	8,190
% Load Delivered by GHX	62%	168.1%
% Load Delivered by River HEX/Heat Recovery	38%	

**Table 27. GHX Cooling Capacity–Phase 1B**

<b>Phase 1B</b>	<b>Hourly Peak Load</b>	<b>Annual Load</b>
	<b>Tons</b>	<b>MMBtu/yr.</b>
Total Building Load	769	3,729
GHX Capacity	653	15,506
% Load Delivered by GHX	85%	415.8%
% Load Delivered by River HEX/Heat Recovery	15%	

**Table 28. GHX Cooling Capacity–Phase 2**

<b>Phase 2</b>	<b>Hourly Peak Load</b>	<b>Annual Load</b>
	<b>Tons</b>	<b>MMBtu/yr.</b>
Total Building Load	1,156	10,139
GHX Capacity	529	27,051
% Load Delivered by GHX	46%	266.8%
% Load Delivered by River HEX/Heat Recovery	54%	

**Table 29. GHX Cooling Capacity–Phase 3**

<b>Phase 3</b>	<b>Hourly Peak Load</b>	<b>Annual Load</b>
	<b>Tons</b>	<b>MMBtu/yr.</b>
Total Building Load	2026	30,780
GHX Capacity	1012	41,453
% Load Delivered by GHX	50%	134.7%
% Load Delivered by River HEX/Heat Recovery	50%	

The remaining part of the load may be delivered by a combination of the following. A decision to be made during the design phase:

1. Include the river water heat exchanger (River HX).
2. Add another site to include more boreholes.
3. Potentially dig deeper boreholes.
4. Add wastewater heat recovery from a nearby wastewater source.
5. Add air source heat pumps.
6. Remove building load by installing hybrid systems in the end-user buildings.

## **2.5 Thermal Storage**

Thermal storage was not analyzed in this task since the annual cooling loads for all buildings in all phases are being designed such that the ground loops, river heat exchanger, or the wastewater heat recovery could satisfy the cooling loads without any thermal storage.



## 2.6 Long-Term Thermal Imbalance

As observed in the previous graphs, the Troy, NY region is heating dominated and this means that more heat will need to be extracted from the ground during heating periods than will be put into the ground during cooling periods in a given year. The design challenge will be to balance the thermal loads such that there is minimal change to the ground temperature over a long period of time. This can be done in a few ways.

- Utilize the proposed river water heat exchanger and the proposed wastewater heat recovery opportunity in Troy to offset the majority of the thermal imbalance. We can use either the river water heat exchanger or the wastewater heat recovery as a primary loop and use the ground heat exchanger as a secondary loop. This will ensure lesser delta temperatures going in and out of the ground loop leading to balanced loads. The sizing and site-specific details of the river water heat exchanger and the wastewater heat recovery is mentioned in Task 3.
- During the design phase, borehole spacing and ground water movement will play a crucial role in the ability to absorb and dissipate heat. Close borehole spacing will restrict the ability of the borehole to dissipate heat, whereas good ground water movement will help carry the heat away.

**Table 30. Annual HVAC Load Balance**

Phase	Total Heating Load (MMBtu/year)	Total Cooling Load (MMBtu/year)
1A	5,931	3,369
1B	15,908	3,729
2	27,051	4,287
3	41,453	30,780

## 2.7 Ground Heat Exchanger (GHX) Site Locations

The potential GHX sites were chosen based on the location relative to the off-takers for each phase. Downtown Troy has multiple parking lots which could be used to drill the bore holes. Additional to the idea of having boreholes in parking lots, river heat exchangers can be utilized to add capacity to the loops. Currently, 14 potential GHX sites have been identified as shown in Figures 4, 5 and 6.

With the exception of the Riverfront Park area, all of the identified locations have third-party ownership, and a legal framework of how to lease the space underneath existing parking lots has yet to be determined.

## **2.8 River Heat Exchanger (HEX)**

The site is adjacent to the Hudson River, which is accessed by other nearby sites for cooling water in an open system scheme. To simplify the regulatory process, a closed loop approach is instead proposed. Expansion of the system size would be possible from a modestly sized stainless steel heat exchanger. These heat exchangers can be used in series to supplement the temperature rise of the heat transfer fluid and can be sequenced as a secondary source of heat. The GHX will be used to meet the baseload and the river heat exchanger will be operational when additional capacity is needed.

The proposed River HEX system can help in increasing the efficiency of the system if the loop water is passed through the river HEX first and then through the ground loop. As part of the proposed design, heat pumps are being installed at central plants as a snow melt system for the sidewalks for the City of Troy. In extremely cold days when the return water temperature from the buildings is very low (around 28° F), we can pass that water through the river HEX where river water temperatures are expected to be higher (around 32° F), and we can extract heat from the water even at low temperatures by using those heat pumps in the central plant. Once that heat is recovered, we can further extract more heat from the ground loop as well enabling us to reduce the size of the equipment required to satisfy the peak heating load in the buildings.

## **2.9 Wastewater Heat Recovery**

The city of Troy, like many northeast U.S. cities, has an aging combined storm sewer system. The E-W lines are owned by the city, and the N-S force mains are owned and operated by Rensselaer County. An 18 inch combined storm/sewer line goes through the 1 Monument Square site that can be accessed to provide supplemental heating capacity. A manhole is to be replaced as part of that project, which would allow the installation of a manhole with a wet well to allow for a submersible pump to pump the contents over to the central plant to be processed. Further filtration is needed by specialized equipment before it can be interfaced with the loop.

## **2.10 Air Source Heat Pump Chillers**

Air source heat pump chillers are available from a limited number of manufacturers and provide heating to the loop. Since the loop would be at a low temperature in the winter, the leaving water temperature (LWT) of the heat pump would be near its minimum setting of 80°F and be able to operate fairly efficiently down to 5–10°F. Maximum equipment size is around 200–250 tons. VRF derivative

heat pump chillers are also available that can function down to -15°F if peak winter heating is the limiting case. The units do require space and are noisy, which limits where they may be applied. However, this will be further investigated in the design phase of the project if the proposed supplemental systems such as river HEX and wastewater heat recovery from the sewers doesn't materialize due to permitting reasons.

## **2.11 Hybrid System**

A hybrid system can be considered at the building level to satisfy the heating and cooling loads of the building.

In a hybrid cooling system, a cooling tower or a chiller can be installed (or an existing unit can be used where possible) in parallel to the building HEX. During the hotter days the tower/chiller will run at part or full load to supplement the building HEX.

In heating mode, a terminal unit that has electric resistance backup heat can be selected to meet the heat load during colder days. The electric resistance heat can be sequenced to serve as a secondary source of heat, and the heat pump will remain as the primary heat source.

# 3 Task 4. Perform Economic and Financial Analysis

## 3.1 Life-Cycle Cost for Baseline

Life-cycle cost analyses (LCCA) provides the cost of ownership of the water source heat pump (WSHP) over the equipment life of the system. The costs that are incorporated into the life-cycle analysis are shown below:

- initial construction costs
- electricity and natural gas costs of system operation
- operation, maintenance, and repair costs
- replacement costs

In this case, a life cycle of 25 years was utilized.

### 3.1.1 Initial Construction Costs

The table below shows the preliminary cost estimate of installing the baseline building system. The baseline building system includes boilers in each building to generate heating hot water for the building’s heat, as well as PTAC units in each room to provide cooling. The PTACs are assumed to have a hydronic coil to utilize heat from the heating hot water. In each case, it is assumed that the existing equipment in these buildings is almost at end of life since site visits were not conducted on any of the buildings and that replacements are completed from Year 1 to Year 3 at the same rate in each year of the LCCA. Detailed line-by-line cost breakouts for each phase is provided in the appendix.

**Table 31. Baseline Construction Cost**

	<b>Baseline Construction Cost (\$)</b>			
	Phase 1A	Phase 1B	Phase 2	Phase 3
Cost	\$3,853,571	\$5,150,597	\$8,489,018	\$10,417,023

For the proposed system, a geothermal heat pump system is considered, with water source heat pumps in each building providing all the heating and cooling. There would be a central plant adjacent to the geothermal borefield site that would have all the pumps, heat exchangers, controls, and any other ancillary equipment needed to send the condenser water out to the buildings. To supplement the heat load of the geothermal system, river heat exchanger and waste heat recovery from sewer lines are added to appropriate phases. In the buildings, it is assumed that water source heat pumps are installed. An

allowance is included for some piping going to the water source heat pumps in each building. It is to be noted that although these costs include building level WSHP retrofit costs, they are for reference purposes only and will not be carried by the central plant owner and are supposed to be financed separately. The details of all the costs are available in appendix A.

**Table 32. Proposed Construction Cost**

	<b>Proposed System Construction Cost (\$)</b>			
	Phase 1A	Phase 1B	Phase 2	Phase 3
Cost	\$13,615,989	\$20,538,540	\$43,493,354	\$34,649,333

### 3.1.2 Electricity and Natural Gas Costs of System Operation

The Table 37 shows the utility cost of operating the existing and proposed system, broken down by phases. All the assumptions for calculating these values are presented under “Preliminary Utility Usage” under Task 1. Also, a system efficiency degradation of 0.25 percent per year was used in the analysis, for both existing and proposed systems.

**Table 33. Utility Costs**

	<b>First Year Utility Cost (\$)</b>			
	Phase 1A	Phase 1B	Phase 2	Phase 3
Existing - Therms	\$98,063	\$221,464	\$366,923	\$562,266
Existing - kWh	\$13,951	\$10,678	\$11,506	\$82,628
Proposed - kWh	\$63,496	\$143,399	\$261,983	\$436,764

### 3.1.3 Operation, Maintenance, and Repair Costs

The PTAC units along with boilers in these buildings will be significantly more expensive to operate than the geothermal system with water source heat pumps in the spaces. Initial estimates are that total baseline operations, maintenance, and repair costs will total about \$4,500 per year for each building. This generally includes annual boiler cleaning and tuning, valve replacements, burner service, sensor replacement, pump service, and motor replacements.

In comparison, \$4,500 per year is estimated for the proposed case for each central plant. The maintenance cost of the existing terminal PTAC units and the WSHP is expected to offset each other. An O&M escalation rate of 3 percent per year, in line with the assumed inflation rate of the economy, is used in the analysis.

### **3.1.4 Replacement Costs**

Based on ASHRAE life expectancy, it is assumed that the boilers will last the full 25 years of the baseline life cycle; however, since we do not know the exact age of the existing boiler systems in the buildings, it is assumed that 10 percent of the boiler infrastructure will start to get replaced every year from year 10 through year 19. It is also assumed that all the geothermal infrastructures will last the full 25 years of the proposed life cycle. However, according to ASHRAE, commercial water source heat pumps (WSHPs) have a 19-year life cycle, whereas the baseline PTAC units only have a 15-year life cycle.

To account for these shorter life cycles in the LCCA, it is assumed that some WSHP's start failing 5 years before expected life and the last ones fail 5 years after the expected life. This results in 10 percent of the units failing in Year 14, 10 percent in Year 15, and so on, through Year 23. The failure rate is assumed to drop to 5 percent for years 24 and 25 as most of the WSHP's would be new at that point.

For the PTAC units, the same is assumed; the first 10 percent of units would fail in year 10 and the last units would fail in year 19. In years 20 through 22, most of the units would be relatively new and the failure rate is assumed to drop to 5 percent for those years. In year 23, the oldest units begin to fail, and the rate goes back up to 10 percent.

The LCA attached as an appendix to this report shows the LCCA on a year-by-year basis.

## **3.2 Life-Cycle Cost for District Energy System**

The LCA attached as appendix A to this report shows the LCCA on a year-by-year basis.

## **3.3 Net Present Value (NPV) Analysis**

### **3.3.1 Energy Escalation Rates**

National Institute of Standards and Technology (NIST) publishes energy price indices and discount factors for life-cycle cost analysis. The energy escalation factors for electricity and natural gas as shown below was obtained from the NIST handbook and used in the analysis. These factors correspond to an overall inflation of 3 percent in the broader economy. The complete table for the factors is available in appendix B for reference.

**Table 34. NIST Fuel Escalation Rates**

	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035
Electricity	1	1.05	1.09	1.14	1.19	1.24	1.3	1.35	1.4	1.43	1.48	1.52	1.59	1.65	1.71
Natural Gas	1	1.03	1.04	1.03	1.06	1.1	1.13	1.17	1.22	1.26	1.3	1.34	1.38	1.43	1.48

### 3.3.2 Discount Rate

The discount rate for future cash flows depends on the capital structure of an entity. Typically, a weighted average cost of capital is used to derive the present value of future cash flows. For municipal entities such as the City of Troy, the interest rate is typically lower because the income from these investments is free from federal income tax. In our analysis, we have used a discount rate of 5 percent and have included a sensitivity analysis of the NPV based on the discount rate.

### 3.3.3 NPV Summary

In the NPV analysis, using a 5 percent discount rate, the net present values of the investment in the more efficient water source heat pump units are shown in the table below. The analysis is broken down by phases. This indicates a positive return on investment for the project.

**Table 35. Project Net Present Value Summary**

	Phase 1A	Phase 1B	Phase 2	Phase 3
NPV without category C NYSERDA Aid	(\$6,746,839)	(\$10,796,029)	(\$27,364,455)	(\$19,560,824)
NPV with category C NYSERDA Aid	(\$3,116,205)	(\$7,165,395)	(\$23,769,767)	(\$15,966,136)

## 3.4 Results—Business Model

1. Describe the customer contract offerings (e.g., ownership structure, membership rules, billing rates, terms/contractual relationships between project participants, organization and operational control) and rate of uptake of customers.

The City of Troy will act as the lead applicant, in conjunction with co-applicant Troy Local Development Corporation (TLDC) to own and operate the system. Siemens will be the lead contractor for design and implementation for the turnkey project under NYS Article 9 Energy Performance Contract (EPC).

Under Siemens, the project is designed and engineered by CHA Consulting, Inc. (CHA) with additional geothermal design support from Karpinski Engineering. Siemens' implementation team will consist of CD Perry (Construction Services), Allied Well Drilling (Geothermal Wells), John W. Danforth (Mechanical Contractor), and Aztech Geothermal (Consulting).

The Siemens team also looked at other business models with the Article 9 EPC providing procurement, the most efficient and cost-effective model for this phase. The team looked at Energy-as-a-Service models for the project but determined this becomes more feasible once there is less speculation from off-takers, and when the future phases for district energy are adopted.

Billing Rates: Participants will be billed through the City of Troy Water Department as a separate service. The initial billing model will be a per square foot per month charge with a residential and commercial rate. This will minimize complexity for both the City and off-takers. Initial rates are being assessed at \$0.05 per square foot per month for residential and \$0.10 per month for commercial. Final rates and contract terms will be clarified once the final project cost and grant award allocation is determined. The potential customers heating and cooling needs are greater than the system can produce. The list of off-takers to those will be near term projects and/or have signed letters of support. A variable rate was discussed and could be implemented, especially as the capacity is expanded in future phases.

Metered rates are being evaluated and documented for subsequent additional phases. During discussions with potential off-takers for this project, it was determined that a fixed rate pricing structure would be initially beneficial.

## **2. Explain how the preferred ownership model unlocks value, such as desirable depreciation schedules of equipment, tax implications, etc.**

While there is no tax advantage for a Municipally owned system, the energy performance contracting (EPC) financial model will provide an opportunity for the City to create a needed additional revenue stream while helping achieve sustainability goals. As a municipally owned endeavor, this project can leverage funds from the recently awarded \$10 million (M) Downtown Revitalization Initiative (DRI), thereby offsetting some of the tax benefits allowed to a privately owned business.



### **3. Explain how the project offers a value proposition to the various stakeholders.**

City of Troy—The City needs District Geothermal to meet the NYS Climate Act Passed in 2019 to reduce emissions by at least 85 percent by 2050. The City can also provide snow melt for key public areas to improve safety and salt wear on concrete/asphalt and contamination of the water table.

Troy Local Development Corporation (TLDC)—The TLDC will use this to attract new business and development. This will also be an opportunity for the City and the TLDC partnership to generate additional revenue to support future development.

Commercial/Residential Off-takers—Off-takers can take advantage of:

- Avoided infrastructure costs—No cooling towers, boiler, flue, chimney, and other initial capital investments.
- Lower maintenance cost—No cooling tower maintenance, chemical treatment, burner maintenance, etc.
- Improved equipment life cycle of WSHP versus Boiler and PTAC systems.
- Lower energy costs and fixed monthly heating/cooling costs for easy budget planning.

Workforce Development—The City of Troy, Siemens, RPI, Sage College, Hoboken Brownstone, and Future of Small Cities have been planning a Living Lab Space at One Monument Square who will be an off-taker. This Future of Cities and Urban Sustainability (FOCUS) Living Lab will be a dynamic, interactive exhibit space that showcases urban design and technology solutions for sustainable communities. District Geothermal will be showcased as “The Future of Equitable Energy Design in Small City Communities” and align with the green workforce development initiatives.

### **4. Discuss the financial viability/net project benefits (and the impact of incentives), budget, potential sources of funds and proposed uses of funds, and implication of schedule.**

The full project proforma can be found in the appendix.

The Financial Model includes both commercial and residential off-takers that have Letters of Support for District Geothermal and have building projects in the next one to five years to take advantage of geothermal heating and cooling. As outlined previously, billing will be calculated by square footage. The initial group of off-takers have square footages outlined below.

The total square footage targeted for this project is 548,490 sq/ft.

- Commercial/Industrial—217,860 sq/ft
- Residential/Mixed Use—330,630 sq/ft

This will yield annual revenues of \$459,810/year.

- For every 10,000 square foot of additional commercial off-takers that participate the annual revenue increases by \$12,000.00.
- For every 10,000 square foot of additional residential off-takers that participate the annual revenue increases by \$6,000.00.

The financial model includes annual mechanical services and measurement and verification to ensure that flow and btu/s requirements are being achieved.

The incentive is critical to the first tranche of the Troy District Energy plan as outline in the feasibility study. Maximizing the incentive will provide the most robust system and an acceptable ROI to the city and community.

- 5. If the project was a public works project (e.g., for a municipal customer) please discuss compliance with public project requirements, and influence on the selected business model.**

The City of Troy has a previously awarded contract with Siemens for EPC contracting services. Under NYS Energy Law Article 9, Troy can leverage that contract to meet public project requirements with all of the partners outlined in the proposal.

### **3.5 Results—Impact**

- 6. Compare and contrast total project costs versus out-of-pocket costs (as a result of incentives, tax credits, etc.) for the community configuration and the individual smaller systems configuration, and highlight any awkward economic signals.**

One of the main drivers considered in terms of the district style geothermal system in this project was the location. Downtown Troy is dense with multiple buildings in close proximity without much open space with which private owners can use for geothermal. However, there is ample public space owned by the City of Troy which can be leveraged for a district style geothermal system.

The Phase 1A building—One Monument Square’s ownership wanted to construct a geothermal system for the building as part of the new construction but could not find the required space to install the boreholes required to satisfy the majority of the modeled heating and cooling loads. This in fact kickstarted the conversation with the City of Troy and Siemens to consider the district style approach, where the city would own and operate the system and charge the off-takers a fee for use. This would not only bring down the first cost of construction for the One Monument Square ownership, it would improve the economics of the project immensely as well as lead to the construction of a green building.

The analysis for economic signals wasn’t conducted in depth as the 58 buildings considered in this project would not be able to construct geothermal systems individually mainly due to space constraints in downtown Troy.


#### **7. Community heat pump system compared to individual building electrification:**

One of the main questions to analyze is how a community heat pump system is more efficient than installing standalone heat pumps in individual buildings.


Individual buildings were analyzed based on the modeling loads created. For each of the buildings, the heating and cooling loads were met by standard air source heat pumps (ASHPs) with electric back up. This was compared with a loop-wide geothermal analysis including pumping energy required for the loop from the central plant to the buildings.

The following curves were used for the coefficient of performance (COPs) of the individual building heat pumps.

**Figure 25. Air Source HP Cooling Efficiency**



**Figure 26. Air Source Heat Pump Heating Efficiency**



From an 8760 analysis on each building, the following results were obtained for energy consumption for both scenarios in Phase 1A. The load profiles and the calculations are attached in the appendix.

**Table 36. Energy Use–Individual Heat Pump Scenario**

	<b>Heating kW</b>	<b>Heating kWh</b>	<b>Cooling kW</b>	<b>Cooling kWh</b>	<b>Peak kW</b>	<b>Total kWh</b>
<b>231–249 River Street</b>	89	117,081	78	60,695	89	177,776
<b>261–269 River Street</b>	129	169,895	82	18,914	129	188,809
<b>2 3rd Street</b>	103	67,935	87	39,593	103	107,528
<b>Third St</b>	18	11,427	26	18,519	26	29,946
<b>Fourth St</b>	39	25,036	57	40,574	57	65,609
<b>213 River Street</b>	32	37,669	20	4,988	32	42,657
<b>219 River Street</b>	19	31,772	17	6,351	19	38,123
<b>221–223 River Street</b>	4	7,397	3	1,106	4	8,503
<b>251 River Street</b>	74	79,956	48	12,098	74	92,054
<b>Individual Building Total:</b>	<b>506</b>	<b>548,167</b>	<b>420</b>	<b>202,837</b>	<b>533</b>	<b>751,004</b>

**Table 37. Energy Use–District Loop Scenario**

	<b>Heating kW</b>	<b>Heating kWh</b>	<b>Cooling kW</b>	<b>Cooling kWh</b>	<b>Pumping kW</b>	<b>Pumping kWh</b>	<b>Peak kW</b>	<b>Total kWh</b>
<b>Geothermal Loop Totals</b>	246	306,863	394	230,460	27	109,222	421	646,545
<b>% Difference</b>	51%	44%	6%	-14%			21%	14%

From the analysis we can see that the community geothermal system consumes 14 percent lesser energy than the individual ASHP systems including the loop pumping energies.

It is worth noting that the peak sizes of the systems have significant reduction in a community-based system compared to individual systems. With the electrification of the grid imminent in the near future, there is a need to reduce peak demand usage. We can see that the winter peaks in a community system is 51 percent lesser than the individual heat pump system and this contributes significantly to the health of the grid. It is also worth noting that the overall peak load is 21 percent lesser in the community system compared to the individual heat pump scenario.

## 4 Task 6. Conduct Permitting and Regulatory Review

---

The overall project will require compliance with the State Environmental Quality Review Act (SEQR) through the Department of Environmental Conservation (DEC). In New York State, most projects proposed by a State agency or unit of local government, and all discretionary approvals (permits) from a NYS agency or unit of local government, require an environmental impact assessment as prescribed by 6 NYCRR Part 617 SEQR.

Completion of the SEQR process will be required prior to any approvals, permitting, or funding on the part of State, regional, and local agencies. SEQR can be completed between conceptual layout and 30 percent completion of design plans, which will involve approvals from the City Council and the planning board. For this project, the timeline for SEQR approval can be between four and six months.

Based on the project's proximity to historic sites and districts, it is anticipated that the project will be progressed as a Type I Action and will require the preparation of a Full Environmental Assessment Form (FEAF) with the City of Troy serving as the Lead Agency. The FEAF is used when a state or local agency has determined that a SEQR review is necessary, and they have identified the project as being a Type I Action. Type I Actions are listed in SEQR (617.4) and described there as "...those actions and projects that are more likely to require the preparation of an Environmental Impact Statement (EIS) than Unlisted actions." It goes on to state "...the fact that an action or project has been listed as a Type I action carries with it the presumption that it is likely to have a significant adverse impact on the environment and may require an EIS."

The FEAF is designed specifically for Type I Actions. It has three parts. The first part (Part 1) is filled out by the applicant, or project sponsor. Part 2 and 3 are the responsibility of the lead agency.

Part 1 of the FEAF provides details that will help the reviewing agency understand the location, size, type, and characteristics of the proposed project. Part 1 can be completed by the applicant using information prepared as part of the approval submission along with maps, plats, or other studies that may have been conducted and by exploring the information and maps available through the links in this guide. The lead agency should also review the information provided by the applicant in Part 1 for basic accuracy and completeness.

Part 2 is used to help the reviewing agency identify potential impacts that may result from the project. In order to do this, the reviewing agency will evaluate information from Part 1, but may also ask the applicant for clarification of information provided in Part 1, or additional information.

Part 3 is used by the reviewing agency to determine if the potential adverse impacts identified in Part 2 are significant or not, and whether a draft environmental impact statement (DEIS) will be prepared. If the reviewing agency determines that a DEIS shall be required, Part 3 is also used to identify the scope (topics to be considered in more detail) for that evaluation. Part 3 is also used to help the reviewing agency identify whether the applicant has addressed the potential adverse impacts as part of the project design.

For this project, issuance of a Negative Declaration is anticipated. A Negative Declaration means one of the three scenarios applies: (1) there are no adverse environmental impacts identified, (2) the impacts identified will not be significant, or (3) any potential impacts are mitigated by project plans. In other words, there is nothing to be gained by further analysis, and the preparation of an EIS will not be needed.

Federal and State permitting will likely be limited to the installation of the heat exchanger within the Hudson River. The Hudson River is a federal and State Navigable waterway regulated by the U.S. Army Corps of Engineers (USACE) and the NYS Department of Environmental Conservation (NYSDEC). In addition, the NYS Office of General Services (NYSOGS) is responsible for the management of State lands underwater. Based on these jurisdictions and the nature of the project, the following permits and approvals are anticipated:

- Section 10 of the 1899 Rivers and Harbors Act and Section 404 of the Clean Water Act—Nationwide Permit(s)—USACE
- Section 401 Water Quality Certification (Blanket coverage may apply)—NYSDEC
- Article 15 Protection of Waters Permit—NYSDEC
- Authorization to occupy State lands underwater—NYSOGS

In addition to the above permits, it will be necessary to address the potential impact to the federal and State endangered species of fish in the Hudson River. According to the NOAA Fisheries Section 7 website,<sup>4</sup> there are two species listed under the Endangered Species Act (ESA) that occur or have the potential to occur in the proposed project area. These include the shortnose sturgeon (*Acipenser*

---

<sup>4</sup> National Oceanic and Atmospheric Administration/U.S. Department of Commerce; New England-Mid-Atlantic; <https://www.greateratlantic.fisheries.noaa.gov/protected/section7/guidance/maps/index.html>

brevirostrum) and Atlantic sturgeon (*Acipenser oxyrinchus*). CHA worked on a construction project at the Troy Seawall where a potential impact study was conducted to gauge any possible adverse effect to these species due to construction near the seawall. The conclusion of the report stated that construction at the seawall will be insignificant and/or discountable and is likely not going to affect any of the species listed under the National Marine Fisheries Services' (NMFS) jurisdiction. A similar study will need to be performed for this project as well as a project in which river heat exchangers are proposed to be placed in the Hudson River.

Permitting can start with drawings at 60 percent design. The primary permitting effort will be the in-river work. Assuming this can be progressed as a Nationwide Permit or possibly a Letter of Permission from the Corps, approval for this step could take around eight months as coordination with NMFS would be required.



## 5 Task 7. Leverage Educational Opportunity of the Project

---

Several suitable educational institutions operate in the project area, including Russell Sage College, which is part of Phase 1B of the project. However, the current timeline of the project is not suitable for creating a dedicated internship or other partnership. CHA will work with the City of Troy in the design and implementation phase of the project to explore the opportunities available and provide a detailed recommendation on how to incorporate education in future phases.

Initial ideas include:

- Educational site visit to the borefield and central plants of the project for students interested in the subject.
- Educational sign boards near the Troy Seawall explaining the project and benefits of the project.
- Creating an elective subject in Russell Sage College to study and understand clean heating and cooling in more depth.
- Educational displays in each building involved in the project as an off-taker showing the environmental impacts of incorporating geothermal energy.

## 6 Lessons Learned

---

### **1. Discuss observations of opportunities to improve the project value proposition to stakeholders.**

This project had a mix of new construction buildings, existing buildings with aging equipment and existing buildings with equipment that were relatively new. This mix created a different value proposition with each stakeholder. The phases for the project were created based on location and not on these factors. Going forward, both these factors must be weighted and considered to make it easier to bring off-takers on board. This will lead to more streamlined implementation.

### **2. Discuss improvements to methods to recruit and select additional teammates to conduct subsequent work (e.g., an RFP to expand the team for conducting the next stage, if applicable)**

In this project, the City of Troy, Siemens, and CHA Consulting have well-defined project roles all the way through construction. Having a well-defined project team starting with a feasibility study and drilling a test bore hole has helped streamline the process and provide continuity. As the project progresses to construction the current design team will continue with enhancements where needed. Siemens will operate under the existing energy performance contract with the City of Troy, with CHA serving as a technical sub-consultant. The final construction documents will be publicly bid to provide competitive pricing. Once the system is operational, the goal would be to provide a framework where building owners could engage their chosen consultants and contractors to provide retrofit solutions that connect into the system.

**Appendix A. City of Troy District Energy, Category A:  
Supporting Documents**

---





Category A: Site-specific scoping study

Report Stage  
(Final Report for Category A  
Instructions part 2)

**BUSINESS MODEL**

<b>Applicant:</b>	<b>City of Troy</b>
-------------------	---------------------

**Ownership**

**C18 Building Ownership**

Buildings all owned by a single entity	
Buildings having unrelated owners	X
Buildings owned by a cooperative or association	
Other - Specify	

**C19 Proposed System Ownership & Operation**

System owned/operated by a private entity	
System owned/operated by a public entity (municipality)	
System owned by a public entity and operated by a private entity	
System owned/operated by a utility	
System owned by a private or public entity and operated by another private entity	
System owned/operated by a public-private partnership.	X
Other - Specify	

**C20 Key Assumptions used for 25 year NPV Life Cycle Cost Analysis**

<b>Economic Factors</b>	<i>input values here - the values are examples</i>	
Economic Discount Rate or Hurdle Rate	5.0%	
General Inflation Rate	3.0%	/year
Electricity Escalation Rate	3.5%	/year
Useful life of Ground Heat Exchanger Loop	50	years
Useful life of GSHP	15	years

Geothermal Sizing Analysis

Building	Phase	Sq Ft	Peak Heating Load (MMBtu/hr)	Peak Cooling Load (Tons)	Base System	Proposed System (check map for locations)	Number of bore holes	Boreholes grid structure (20 ft o.c.)	GPM	SQFT available for bores	Tons/Bore		Total Heating Load (MMBtu)	Total Cooling Load (MMBtu)	Peak Heating Load (MMBtu/hr)	Total Cooling Load (MMBtu)	Peak Cooling Load (Tons)
											GLHX Capacity (MMBtu/hr)	MMBtu/year Available from GHX					
1 Monument - Sq 231 - 239 River St	1A	18000	1.66	111.8	Boiler/PAC/HW	Central Plant 1	150	25 x 4	1500	50.198	4.14	8190	7.845	5.931	4.88	4.872	557.87
217 2nd River Street	1A	4300	1.13	86.9	Boiler/PAC/HW												
2 3rd Street	1A	6067	0.22	12.7	Boiler/PAC/HW												
Third St	1A	16720	0.48	27.8	Boiler/PAC/HW												
Fourth St	1A	3643	0.41	27.5	Boiler/PAC/HW												
713 River Street	1A	14000	0.31	20.6	Boiler/PAC/HW												
719 River Street	1A	16080	0.07	4.3	Boiler/PAC/HW												
221-223 River Street	1A	3650	0.04	6.7	Boiler/PAC/HW												
251 River Street	1A	29760	1.15	110.9	Boiler/PAC/HW												
Taylor - 1	1B	10000	1.81	120.7	Boiler/PAC/HW												
Taylor - 2	1B	10000	1.81	120.7	Boiler/PAC/HW												
Taylor - 3	1B	10000	1.81	120.7	Boiler/PAC/HW												
Taylor - 4	1B	10000	1.81	120.7	Boiler/PAC/HW												
West Hall	1B Sage	21750	0.67	53.6	Boiler/PAC/HW												
Ricketts Hall	1B Sage	34,191	1.06	85	Boiler/PAC/HW												
Boy Courtyard	1B Sage	7,757	0.24	19.3	Boiler/PAC/HW												
Cowen Hall	1B Sage	23,713	0.72	58	Boiler/PAC/HW												
Kingland Alumnae House	1B Sage	5,208	0.09	6.2	Boiler/PAC/HW												
Manning Hall	1B Sage	27,796	0.35	33.5	Boiler/PAC/HW												
Liberal School of Education	1B Sage	12,660	0.39	31.3	Boiler/PAC/HW												
Plum Memorial	1B Sage	9,794	0.3	24.3	Boiler/PAC/HW												
150 2nd Street	2	879	0.11	7.84	Boiler/PAC/HW	Central Plant 2	45	5 x 9	675	20.079	7.84	15.506	21.039	15.908	10.69	3.729	768.86
141 Congress Street	2	6658	1.21	80.27	Boiler/PAC/HW												
1648 5th Avenue	2	12950	0.22	14.54	Boiler/PAC/HW												
119 Congress Street	2	1158	0.24	18.88	Boiler/PAC/HW												
51 State Street	2	19774	0.22	14.09	Boiler/PAC/HW												
1700 6th Avenue	2	15250	0.17	11.38	Boiler/PAC/HW												
17 54 State Street	2	12401	0.14	9.24	Boiler/PAC/HW												
61 State Street	2	10124	0.12	7.69	Boiler/PAC/HW												
State Street	2	119758	2.16	143	Boiler/PAC/HW												
1716 6th Avenue	2	47928	0.35	36.32	Boiler/PAC/HW												
1800 6th Avenue	2	136005	2.46	164.1	Boiler/PAC/HW												
1800 6th Avenue	2	36888	0.42	28.01	Boiler/PAC/HW												
2000 6th Avenue	2	122708	2.22	148.1	Boiler/PAC/HW												
220 Federal Street	2	152974	2.77	184.5	Boiler/PAC/HW												
501 Grand Street	2	46796	0.84	55.36	Boiler/PAC/HW												
2007 5th Avenue	2	13085	0.38	25.12	Boiler/PAC/HW												
92 4th South Street	2	11844	0.14	8.99	Boiler/PAC/HW												
12 3rd Street	2	10794	0.12	8.17	Boiler/PAC/HW												
43 3rd Street	2	5147	0.09	6.21	Boiler/PAC/HW												
12 2nd Street	2	19680	0.22	14.81	Boiler/PAC/HW												
Building - 1	3	255,472	2.51	191.3	Boiler/PAC/HW	Central Plant 3	440	21 x 21	6,600	192,060	12.1	24,023	54,825	41,453	19.42	30,780	2,026
Building - 2	3	253,223	3.29	255.8	Boiler/PAC/HW												
Building - 3	3	262,779	2.8	213.3	Boiler/PAC/HW												
Building - 4	3	248,046	2.64	201.3	Boiler/PAC/HW												
Building - 5	3	265,865	2.43	188.9	Boiler/PAC/HW												
Building - 6	3	428,797	3.99	310.5	Boiler/PAC/HW												
Building - 7	3	49,146	0.54	40.9	Boiler/PAC/HW												
Building - 8	3	12,746	0.36	27.25	Boiler/PAC/HW												
Building - 9	3	24,880	0.27	20.71	Boiler/PAC/HW												
Building - 10	3	28,729	0.24	25.31	Boiler/PAC/HW												
Building - 11	3	6,140	0.07	5.13	Boiler/PAC/HW												
Building - 12	3	46,180	0.51	38.37	Boiler/PAC/HW												
Building - 13	3	11,053	0.14	25.81	Boiler/PAC/HW												
Building - 14	3	364,990	3.45	267.3	Boiler/PAC/HW												
Building - 15	3	141,543	1.11	126.4	Boiler/PAC/HW												
Building - 16	3	27,001	0.52	38.76	Boiler/PAC/HW												
Building - 17	3	22,684	0.43	33.83	Boiler/PAC/HW												

## Phase 1A Savings Analysis

Baseline	Boiler Efficiency	76%
Baseline	PTAC EER	10.2
Proposed	Heating COP - WSHP	4.3
Proposed	Cooling EER - WSHP	20.1

Building	Thermal Load		BASELINE			PROPOSED WSHP			
	MMBtu/yr	Cooling Load MMBtu/yr	Existing Systems	Existing HTG Baseline Therms	Existing CLG KWH	Proposed System	Thermal Load MMBtu/yr	Proposed HTG KWH	Proposed CLG KWH
1 Monument - Sq 231 - 239 River St.	2236	1,763	Boiler/PTAC HW	29,421	50,481	DES-WSHP	2236	152,402	25,708
261 - 269 River Street	2693	505	Boiler/PTAC HW	35,435	14,455	DES-WSHP	1008	183,557	7,361
2 3rd Street	1008	790	Boiler/PTAC HW	13,267	22,630	DES-WSHP	163	68,726	11,525
Third St	163	374	Boiler/PTAC HW	2,147	10,710	DES-WSHP	357	11,124	5,454
Fourth St	358	820	Boiler/PTAC HW	4,705	23,465	DES-WSHP	328	24,371	11,950
213 River Street	594	125	Boiler/PTAC HW	7,812	3,567	DES-WSHP	255	40,469	1,816
219 River Street	524	175	Boiler/PTAC HW	6,891	5,018	DES-WSHP	54	35,694	2,556
221-223 River Street	487	33	Boiler/PTAC HW	6,408	941	DES-WSHP	748	33,195	479
251 River Street	1253	288	Boiler/PTAC HW	16,491	8,242	DES-WSHP	2235	85,426	4,197
	9,316	4,872		122,578	139,510		7,384	634,963	71,046

Utility Cost (\$)		
Existing - Therms	122,578	\$98,062
Existing - KWH	139,510	\$13,951
Existing Total \$\$		\$112,013

Proposed - KWH (HTG)	634,963	\$63,496
Proposed - KWH (CLG)	71,046	\$7,105
Proposed Total KWH	706,009	\$70,601

Therms to KWH	3,591,535
Delta KWH	(566,499)
KWH Savings	3,025,036
\$\$ Savings	\$41,412



# Phase 1B Savings Analysis

Baseline	Boiler Efficiency	76%
Baseline	PTAC EER	10.2
Proposed	Heating COP - WSHP	4.3
Proposed	Cooling EER - WSHP	20.1

Building	Thermal Load MMBtu/yr	Cooling Load MMBtu/yr	BASELINE			PROPOSED WSHP			
			Existing Systems	Existing HTG	Existing CLG	Proposed System	Thermal Load	Proposed HTG	Proposed CLG
				Baseline Therms	KWH		MMBtu/yr	KWH	KWH
Taylor - 1	4,380	525	Boiler/PTAC HW	57,633	15,027	DES-WSHP	4380.113808	298,544	7,653
Taylor - 2	4,380	525	Boiler/PTAC HW	57,633	15,027	DES-WSHP	4380.113808	298,544	7,653
Taylor - 3	4,380	525	Boiler/PTAC HW	57,633	15,027	DES-WSHP	4380.113808	298,544	7,653
Taylor - 4	4,380	525	Boiler/PTAC HW	57,633	15,027	DES-WSHP	4380.113808	298,544	7,653
Cowee Hall	443	311	Boiler/PTAC HW	5,823	8,905	DES-WSHP	442.5120571	30,161	4,535
Slingerland Alumnae House	228	27	Boiler/PTAC HW	3,002	783	DES-WSHP	228.1163271	15,548	399
Roy Courtyard	147	103	Boiler/PTAC HW	1,937	2,963	DES-WSHP	147.2382802	10,036	1,509
Hart Hall	409	288	Boiler/PTAC HW	5,383	8,232	DES-WSHP	409.0859115	27,883	4,192
Ricketts Hall	649	456	Boiler/PTAC HW	8,539	13,060	DES-WSHP	648.9911099	44,235	6,651
Manning Hall	1,218	146	Boiler/PTAC HW	16,021	4,177	DES-WSHP	1217.584036	82,989	2,127
Esteves School of Education	239	168	Boiler/PTAC HW	3,147	4,813	DES-WSHP	239.164926	16,301	2,451
Plum Memorial	186	131	Boiler/PTAC HW	2,446	3,741	DES-WSHP	185.9032766	12,671	1,905
	21,039	3,729		276,830	106,782			1,433,998	54,379

### Utility Cost (\$)

Existing - Therms	276,830	\$221,464
Existing - KWH	106,782	\$10,678
Existing Total \$\$		\$232,142

Proposed - KWH (HTG)	1,433,998	\$143,400
Proposed - KWH (CLG)	54,379	\$5,438
Proposed Total KWH	1,488,378	\$148,838

Therms to KWH	8,111.108
Delta KWH	(1,381.595)
KWH Savings	6,729.512
\$\$ Savings	\$83,304

## Phase 2 Savings Analysis

Baseline	Boiler Efficiency	76%
Baseline	PTAC EER	10.2
Proposed	Heating COP - WSHP	4.3
Proposed	Cooling EER - WSHP	20.1

Building	Thermal Load MMBtu/yr	Cooling Load MMBtu/yr	BASELINE			PROPOSED WSHP			
			Existing Systems	Existing HTG Baseline Therms	Existing CLG KWH	Proposed System	Thermal Load MMBtu/yr	Proposed HTG KWH	Proposed CLG KWH
100 2nd Street	96	219	Boiler/PTAC HW	1,258	6,272	DES-WSHP	95.57994549	6,515	3,194
141 Congress Street	1,264	828	Boiler/PTAC HW	16,637	23,694	DES-WSHP	1264.431965	86,182	12,066
1646 5th Avenue	229	150	Boiler/PTAC HW	3,014	4,293	DES-WSHP	229.0913151	15,615	2,186
119 Congress Street	250	164	Boiler/PTAC HW	3,292	4,688	DES-WSHP	250.156309	17,050	2,387
51 State Street	193	441	Boiler/PTAC HW	2,535	12,641	DES-WSHP	192.6240446	13,129	6,438
1700 6th Avenue	149	341	Boiler/PTAC HW	1,959	9,769	DES-WSHP	148.8556136	10,146	4,975
57-59 State Street	120	275	Boiler/PTAC HW	1,580	7,880	DES-WSHP	120.0703543	8,184	4,013
61 State Street	99	226	Boiler/PTAC HW	1,300	6,485	DES-WSHP	98.8206054	6,736	3,303
State Street	2,265	1482	Boiler/PTAC HW	29,802	42,443	DES-WSHP	2264.981155	154,379	21,614
1776 6th Avenue	468	1073	Boiler/PTAC HW	6,159	30,721	DES-WSHP	468.1191815	31,906	15,645
1800 6th Avenue	5,957	714	Boiler/PTAC HW	78,384	20,438	DES-WSHP	5957.173784	406,034	10,408
1801 6th Avenue	360	825	Boiler/PTAC HW	4,737	23,628	DES-WSHP	360.0451255	24,540	12,033
2000 6th Avenue	5,375	644	Boiler/PTAC HW	70,720	18,440	DES-WSHP	5374.750051	366,337	9,391
720 Federal Street	6,696	802	Boiler/PTAC HW	88,106	22,973	DES-WSHP	6696.055182	456,396	11,699
503 Grand Street	2,023	242	Boiler/PTAC HW	26,624	6,942	DES-WSHP	2023.437375	137,915	3,535
2001 5th Avenue	323	740	Boiler/PTAC HW	4,249	21,193	DES-WSHP	322.9434739	22,011	10,793
92-96 Fourth Street	116	265	Boiler/PTAC HW	1,521	7,587	DES-WSHP	115.6095664	7,880	3,864
30 3rd Street	105	241	Boiler/PTAC HW	1,381	6,889	DES-WSHP	104.9700504	7,155	3,508
43 3rd Street	225	27	Boiler/PTAC HW	2,966	773	DES-WSHP	225.4444577	15,366	394
32 2nd Street	191	438	Boiler/PTAC HW	2,515	12,546	DES-WSHP	191.169652	13,030	6,389
	26,504	10139		348,741	290,294			1,806,506	147,833

Utility Cost (\$)		
Existing - Therms	348,741	\$278,993
Existing - KWH	290,294	\$29,029
Existing Total \$\$		\$308,022

Proposed - KWH (HTG)	1,806,506	\$180,651
Proposed - KWH (CLG)	147,833	\$14,783
Proposed Total KWH	1,954,339	\$195,434

Therms to KWH	10,218,116
Delta KWH	(1,664,045)
KWH Savings	8,554,071
\$\$ Savings	\$112,588

Phase 3 Savings Analysis

Baseline	Boiler Efficiency	76%
Baseline	PTAC EER	10.2
Proposed	Heating COP - WSHP	4.3
Proposed	Cooling EER - WSHP	20.1

	Thermal Load	Cooling Load	BASELINE			PROPOSED WSHP			
			Existing Systems	Existing HTG	Existing CLG	Proposed System	Thermal Load	Proposed HTG	Proposed CLG
Building	MMBtu/yr	MMBtu/yr	Existing Systems	Existing HTG	Existing CLG	Proposed System	Thermal Load	Proposed HTG	Proposed CLG
Building - 1	5,172	2,671	Boiler/PTAC HW	68,053	76,463	DES-WSHP	5172.024606	352,519	38,939
Building - 2	7,236	4,200	Boiler/PTAC HW	95,206	120,254	DES-WSHP	7235.628741	493,172	61,240
Building - 3	5,767	2,978	Boiler/PTAC HW	75,880	85,258	DES-WSHP	5766.911102	393,066	43,418
Building - 4	5,444	2,811	Boiler/PTAC HW	71,626	80,478	DES-WSHP	5443.582671	371,029	40,984
Building - 5	5,344	3,102	Boiler/PTAC HW	70,318	88,818	DES-WSHP	5344.145941	364,251	45,231
Building - 6	8,781	5,097	Boiler/PTAC HW	115,543	145,942	DES-WSHP	8781.245198	598,520	74,321
Building - 7	1,095	551	Boiler/PTAC HW	14,402	15,771	DES-WSHP	1094.551258	74,603	8,032
Building - 8	729	367	Boiler/PTAC HW	9,596	10,508	DES-WSHP	729.2925208	49,708	5,351
Building - 9	554	279	Boiler/PTAC HW	7,291	7,984	DES-WSHP	554.1242302	37,768	4,066
Building - 10	684	344	Boiler/PTAC HW	9,003	9,858	DES-WSHP	684.1919756	46,634	5,020
Building - 11	137	69	Boiler/PTAC HW	1,805	1,977	DES-WSHP	137.1947451	9,351	1,007
Building - 12	1,027	517	Boiler/PTAC HW	13,510	14,794	DES-WSHP	1026.733401	69,981	7,534
Building - 13	691	348	Boiler/PTAC HW	9,089	9,953	DES-WSHP	690.7621785	47,082	5,069
Building - 14	7,534	4,316	Boiler/PTAC HW	99,132	123,580	DES-WSHP	7534.050874	513,513	62,934
Building - 15	3,291	1,534	Boiler/PTAC HW	43,300	43,922	DES-WSHP	3290.793429	224,297	22,367
Building - 16	738	841	Boiler/PTAC HW	9,712	24,073	DES-WSHP	738.1166362	50,309	12,259
Building - 17	601	757	Boiler/PTAC HW	7,910	21,675	DES-WSHP	601.1544712	40,974	11,038
	54,825	30,780		721,375	881,310			3,736,777	448,811

Utility Cost (\$)	
Existing - Therms	\$577,100
Existing - KWH	\$88,131
Existing Total \$\$	\$665,231

Proposed - KWH (HTG)	\$373,678
Proposed - KWH (CLG)	\$44,881
Proposed Total KWH	\$418,559

Therms to KWH	21,136,289
Delta KWH	(3,304,278)
KWH Savings	17,832,011
\$\$ Savings	\$246,672

## Energy Escalation Rates

	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Electricity	1	1.05	1.09	1.14	1.19	1.24	1.3	1.35	1.4	1.43	1.48	1.52	1.59	1.65	1.71	1.75	1.8	1.85	1.9	1.97	2.04	2.12	2.18	2.25	2.33
Natural Gas	1	1.03	1.04	1.03	1.06	1.1	1.13	1.17	1.22	1.26	1.3	1.34	1.38	1.43	1.48	1.52	1.56	1.61	1.66	1.71	1.76	1.81	1.87	1.92	1.98

**Table S-1. Projected fuel price indices with assumed general price inflation rates of 2%, 3%, 4%, and 5%, by end-use sector and fuel type.**

Census Region 1

Connecticut, Maine, Massachusetts, New Hampshire, New Jersey, New York, Pennsylvania, Rhode Island, Vermont

Projected April 1 Fuel Price Indices (April 2021 = 1.00)

Residential

Year	Electricity				Distillate Oil				LPG				Natural Gas			
	Inflation Rate				Inflation Rate				Inflation Rate				Inflation Rate			
	2%	3%	4%	5%	2%	3%	4%	5%	2%	3%	4%	5%	2%	3%	4%	5%
2022	1.04	1.05	1.06	1.07	1.07	1.08	1.09	1.10	1.04	1.05	1.06	1.07	1.02	1.03	1.04	1.05
2023	1.07	1.09	1.11	1.13	1.20	1.22	1.24	1.27	1.08	1.10	1.12	1.14	1.02	1.04	1.06	1.08
2024	1.10	1.14	1.17	1.20	1.30	1.34	1.38	1.42	1.13	1.16	1.19	1.23	1.00	1.03	1.06	1.09
2025	1.14	1.19	1.24	1.29	1.38	1.44	1.50	1.55	1.18	1.23	1.27	1.32	1.02	1.06	1.10	1.14
2026	1.18	1.24	1.30	1.37	1.47	1.54	1.62	1.69	1.24	1.30	1.36	1.43	1.04	1.10	1.15	1.21
2027	1.22	1.30	1.38	1.46	1.52	1.61	1.71	1.81	1.29	1.37	1.45	1.53	1.07	1.13	1.20	1.27
2028	1.26	1.35	1.44	1.54	1.58	1.69	1.81	1.93	1.35	1.44	1.54	1.65	1.09	1.17	1.25	1.34
2029	1.29	1.40	1.51	1.63	1.63	1.76	1.90	2.05	1.40	1.52	1.64	1.77	1.13	1.22	1.32	1.42
2030	1.31	1.43	1.56	1.70	1.69	1.84	2.01	2.19	1.46	1.59	1.74	1.89	1.15	1.26	1.37	1.50
2031	1.34	1.48	1.63	1.79	1.74	1.92	2.11	2.32	1.51	1.67	1.84	2.02	1.18	1.30	1.43	1.57
2032	1.36	1.52	1.69	1.88	1.79	1.99	2.22	2.46	1.57	1.75	1.94	2.16	1.20	1.34	1.49	1.65
2033	1.41	1.59	1.79	2.00	1.84	2.07	2.32	2.60	1.63	1.83	2.05	2.30	1.23	1.38	1.55	1.74
2034	1.46	1.65	1.87	2.12	1.88	2.14	2.42	2.75	1.68	1.91	2.16	2.45	1.26	1.43	1.63	1.84
2035	1.49	1.71	1.96	2.24	1.93	2.21	2.53	2.90	1.73	1.99	2.27	2.60	1.29	1.48	1.69	1.93
2036	1.51	1.75	2.03	2.34	1.98	2.29	2.64	3.05	1.79	2.07	2.39	2.76	1.31	1.52	1.76	2.03
2037	1.54	1.80	2.10	2.45	2.03	2.37	2.77	3.23	1.84	2.15	2.51	2.93	1.34	1.56	1.82	2.13
2038	1.57	1.85	2.18	2.57	2.09	2.47	2.91	3.42	1.90	2.24	2.64	3.11	1.36	1.61	1.90	2.23
2039	1.60	1.90	2.27	2.69	2.14	2.55	3.03	3.60	1.96	2.33	2.77	3.30	1.39	1.66	1.97	2.34
2040	1.63	1.97	2.36	2.84	2.20	2.65	3.19	3.82	2.02	2.43	2.92	3.50	1.42	1.71	2.05	2.46
2041	1.68	2.04	2.47	2.99	2.27	2.76	3.35	4.05	2.08	2.53	3.07	3.72	1.45	1.76	2.14	2.59
2042	1.73	2.12	2.60	3.18	2.33	2.86	3.50	4.28	2.15	2.63	3.23	3.94	1.48	1.81	2.22	2.71
2043	1.76	2.18	2.70	3.33	2.40	2.97	3.67	4.53	2.21	2.74	3.39	4.18	1.51	1.87	2.31	2.85
2044	1.80	2.25	2.82	3.51	2.45	3.07	3.83	4.77	2.27	2.85	3.56	4.43	1.54	1.92	2.40	2.99
2045	1.84	2.33	2.93	3.69	2.50	3.16	3.98	5.01	2.33	2.94	3.71	4.67	1.57	1.98	2.50	3.14



City of Troy

Multipliers	
Material:	0.98
Labor:	1.09
Equipment:	1.00

Phase 1A  
WSHP District Energy

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Geothermal Well Install</b>										
Hardscape Restoration	300	LF		\$ 150		\$ -	\$ -	\$ 45,000	\$ 45,000	
Parking Lot Excavation	25000	SF		\$ 40		\$ -	\$ -	\$ 1,000,000	\$ 1,000,000	
Parking Lot Restoration	25000	SF		\$ 1.5		\$ -	\$ -	\$ 37,500	\$ 37,500	
Geothermal Boreholes (150 Boreholes x 500 ft)	75000	LF		\$ 50		\$ -	\$ -	\$ 3,750,000	\$ 3,750,000	
Heat Exchanger	2	EA	\$ 75,000	\$ 50,000		\$ 147,450	\$ 109,000	\$ -	\$ 256,450	
						\$ -	\$ -	\$ -	\$ -	
<b>Mechanical Systems</b>										
Central Plant Building	1000	SF		\$ 750		\$ -	\$ -	\$ 750,000	\$ 750,000	
Pump Station	250	SF		\$ 750		\$ -	\$ -	\$ 187,500	\$ 187,500	
HDPE Piping	14050	LF	\$ 25	\$ 5.5		\$ 345,279	\$ 84,230	\$ -	\$ 429,509	
Loop Pumps	6	EA	\$ 8,500	\$ 1,125		\$ 50,133	\$ 7,358	\$ -	\$ 57,491	
Pump VFD	6	EA	\$ 7,500	\$ 1,350		\$ 44,235	\$ 8,829	\$ -	\$ 53,064	
Borefield Pumps	6	EA	\$ 12,600	\$ 1,130		\$ 74,315	\$ 7,390	\$ -	\$ 81,705	
Borefield Pump VFD	6	EA	\$ 15,500	\$ 3,500		\$ 91,419	\$ 22,890	\$ -	\$ 114,309	
6" Black Iron Pipe	2500	LF	\$ 45	\$ 42		\$ 110,588	\$ 114,450	\$ -	\$ 225,038	
Steel Fittings	15	LS			\$ 15,000	\$ -	\$ -	\$ 225,000	\$ 225,000	
4" HDPE	5000	LF	\$ 4			\$ 18,824	\$ -	\$ -	\$ 18,824	
3" HDPE	5000	LF	\$ 3	\$ 8		\$ 12,386	\$ 40,875	\$ -	\$ 53,261	
2 1/2" HDPE	5000	LF	\$ 2	\$ 8		\$ 11,305	\$ 40,875	\$ -	\$ 52,180	
2" HDPE	3000	LF	\$ 2	\$ 8		\$ 5,574	\$ 24,525	\$ -	\$ 30,099	
1 1/2" HDPE	1500	LF	\$ 1	\$ 8		\$ 1,681	\$ 12,263	\$ -	\$ 13,943	
HDPE Fittings	15	LS			\$ 10,657	\$ -	\$ -	\$ 159,852	\$ 159,852	
Air Separator - 6"	6	EA	\$ 3,950	\$ 533		\$ 23,297	\$ 3,486	\$ -	\$ 26,783	
Expansion Tanks -300 gal	6	EA	\$ 3,000	\$ 200		\$ 17,694	\$ 1,308	\$ -	\$ 19,002	
Snow Melt System	1	EA	\$ 225,000	#####	\$ 50,000	\$ 221,175	\$ 190,750	\$ 50,000	\$ 461,925	
						\$ -	\$ -	\$ -	\$ -	
<b>River Heat Exchanger</b>										
Rigging	1	EA		\$ 75,000		\$ -	\$ -	\$ 75,000	\$ 75,000	
HEX Equipment (100 Ton)	70	TONS		\$ 750		\$ -	\$ 57,225	\$ -	\$ 57,225	
HEX Labor	120	HRS		\$ 250		\$ -	\$ 32,700	\$ -	\$ 32,700	
Piping	150	LF	\$ 45	\$ 40		\$ 6,635	\$ 6,540	\$ -	\$ 13,175	
Pumps (2 x 15 HP) + Motor + VFD	2	EA	\$ 6,500	\$ 2,500		\$ 12,779	\$ 5,450	\$ -	\$ 18,229	300 GPM/100'
Electricals	1	EA	\$ 8,500	\$ 4,500		\$ 8,356	\$ 4,905	\$ -	\$ 13,261	
						\$ -	\$ -	\$ -	\$ -	
<b>WSHP Heat Pump Terminal Equipment Cost</b>										
231-249 River Street - Monument Sq. (already has HP)	120,000	SF		\$ 2.0		\$ -	\$ -	\$ 240,000	\$ 240,000	
261-269 River Street -	63,000	SF		\$ 20.0		\$ -	\$ -	\$ 1,260,000	\$ 1,260,000	
2 3rd Street	40867	SF		\$ 20.0		\$ -	\$ -	\$ 817,340	\$ 817,340	
Third St (already has HP)	16720	SF		\$ 2.0		\$ -	\$ -	\$ 33,440	\$ 33,440	
Fourth St (already has HP)	36632	SF		\$ 2.0		\$ -	\$ -	\$ 73,264	\$ 73,264	
213 River Street -	14000	SF		\$ 20.0		\$ -	\$ -	\$ 280,000	\$ 280,000	
219 River Street -	16080	SF		\$ 20.0		\$ -	\$ -	\$ 321,600	\$ 321,600	
221-223 River Street -	3450	SF		\$ 20.0		\$ -	\$ -	\$ 69,000	\$ 69,000	
251 River Street -	29760	SF		\$ 20.0		\$ -	\$ -	\$ 595,200	\$ 595,200	
<b>Misc and Electrical</b>										
SWPPP/Erosion Control	1	LS		\$ 35,000		\$ -	\$ -	\$ 35,000	\$ 35,000	
Site Prep/Access	1	LS		\$ 30,000		\$ -	\$ -	\$ 30,000	\$ 30,000	
Construction Management	1	LS		\$ 300,000		\$ -	\$ -	\$ 300,000	\$ 300,000	
						\$ -	\$ -	\$ -	\$ -	

Geothermal Side Totals (Includes contractor O&P)

\$ 8,413,434	Subtotal
\$ 1,682,687	20% Contingency
\$ -	0% Contractor O&P
\$ 1,009,612	10% Engineering
<b>\$ 11,105,732</b>	<b>Total</b>

Terminal and River HX side totals

\$ 2,639,434	Subtotal
\$ 527,887	20% Contingency
\$ 633,464	20% Contractor O&P
\$ 380,078	10% Engineering
<b>\$ 4,180,863</b>	<b>Total</b>

City of Troy

Multipliers		
Material:		0.98
Labor:		1.09
Equipment:		1.00

**Phase 1A  
Boiler Chiller Tower System**

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Boilers</b>										
213 River Street -2 x 500 MBH	2	EA	\$ 20,000	\$ 9,500		\$ 39,320	\$ 20,710	\$ -	\$ 60,030	
219 River Street -2 x 500 MBH	2	EA	\$ 20,000	\$ 9,500		\$ 39,320	\$ 20,710	\$ -	\$ 60,030	
221-223 River Street - 75 MBH -Fumace	1	EA	\$ 8,000	\$ 2,500		\$ 7,864	\$ 2,725	\$ -	\$ 10,589	
1 MO SQ -231-249 River Street -2 x 1000 MBH	2	EA	\$ 30,400	\$ 13,500		\$ 59,766	\$ 29,430	\$ -	\$ 89,196	
251 River Street -2 x 1000 MBH	2	EA	\$ 30,400	\$ 13,500		\$ 59,766	\$ 29,430	\$ -	\$ 89,196	
261-269 River Street -2 x 1500 MBH	2	EA	\$ 38,000	\$ 13,500		\$ 74,708	\$ 29,430	\$ -	\$ 104,138	
2 3rd Street - 2 x 1000 MBH	2	EA	\$ 30,400	\$ 13,500		\$ 59,766	\$ 29,430	\$ -	\$ 89,196	
Fourth Street -2 x 1500 MBH	2	EA	\$ 38,000	\$ 13,500		\$ 74,708	\$ 29,430	\$ -	\$ 104,138	
Third St - 200 MBH - Furnace	1	EA	\$ 10,000	\$ 4,500		\$ 9,830	\$ 4,905	\$ -	\$ 14,735	
		EA						\$ -	\$ -	
<b>Main Pumps</b>										
213 River Street -2x5 HP Pump	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
219 River Street -2x5 HP Pump	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
221-223 River Street - Fan	2	EA	\$ 7,500	\$ 650		\$ 14,745	\$ 1,417	\$ -	\$ 16,162	
1 MO SQ - 231-249 River Street -2x7.5 HP Pump	2	EA	\$ 13,800	\$ 750		\$ 27,131	\$ 1,635	\$ -	\$ 28,766	
251 River Street -2x7.5 HP Pump	2	EA	\$ 13,800	\$ 750		\$ 27,131	\$ 1,635	\$ -	\$ 28,766	
261-269 River Street -2x10 HP Pump	2	EA	\$ 14,950	\$ 950		\$ 29,392	\$ 2,071	\$ -	\$ 31,463	
2 3rd Street - 2 x 5 HP Pump	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
Fourth Street -2x10 HP Pump	2	EA	\$ 14,950	\$ 950		\$ 29,392	\$ 2,071	\$ -	\$ 31,463	
Third Street - Fan/Motor/VFD	1	EA	\$ 7,500	\$ 550		\$ 7,373	\$ 600	\$ -	\$ 7,972	
<b>Cooling PTAC with Hot Water Heat -0620</b>										
Cooling PTACs w/ HW coil included in terminal costs									\$ 779,025	
<b>Circ Pumps</b>										
213 River Street -Circulation Pumps - 1 HP	2	EA	\$ 2,050	\$ 300		\$ 4,030	\$ 654	\$ -	\$ 4,684	
219 River Street -Circulation Pumps - 1 HP	2	EA	\$ 2,050	\$ 300		\$ 4,030	\$ 654	\$ -	\$ 4,684	
221-223 River Street -Circulation Pumps - 2 HP	2	EA	\$ 3,500	\$ 325		\$ 6,881	\$ 709	\$ -	\$ 7,590	
1 MO SQ -231-249 River Street -Circulation Pumps- 2HP	2	EA	\$ 3,500	\$ 325		\$ 6,881	\$ 709	\$ -	\$ 7,590	
251 River Street -Circulation Pumps - 2HP	2	EA	\$ 3,500	\$ 325		\$ 6,881	\$ 709	\$ -	\$ 7,590	
261-269 River Street -Circulation Pumps - 3HP	2	EA	\$ 3,700	\$ 500		\$ 7,274	\$ 1,090	\$ -	\$ 8,364	
2 3rd Street - 1 HP Pump	2	EA	\$ 2,050	\$ 300		\$ 4,030	\$ 654	\$ -	\$ 4,684	
Fourth Street -1 HP Pump	2	EA	\$ 2,050	\$ 300		\$ 4,030	\$ 654	\$ -	\$ 4,684	
Third Street - 1 HP pump	2	EA	\$ 2,050	\$ 300		\$ 4,030	\$ 654	\$ -	\$ 4,684	
<b>Electricals and Misc.</b>										
Misc Electricals - xformer/ Panel/ Switchgear	9	EA	\$ 17,500	\$ 7,500		\$ 154,823	\$ 73,575	\$ -	\$ 228,398	
Chemical Treatment	7	EA			\$ 6,500	\$ -	\$ -	\$ 45,500	\$ 45,500	
Concrete Pad - Primary Boilers	7	EA	\$ 4,500	\$ 1,500		\$ 30,965	\$ 11,445	\$ -	\$ 42,410	
Boiler Rigging - Boilers	7	EA			\$ 7,500	\$ -	\$ -	\$ 52,500	\$ 52,500	
Boiler - Flue Venting (double wall stainless steel AL-294c)	7	EA	\$ 20,000	\$ 5,500		\$ 137,620	\$ 41,965	\$ -	\$ 179,585	
Boiler / Furnace Controls and Wiring	7	EA	\$ 7,500	\$ 4,500		\$ 51,608	\$ 34,335	\$ -	\$ 85,943	
Power Wiring to new equipment	9	EA	\$ 5,000	\$ 4,500		\$ 44,235	\$ 44,145	\$ -	\$ 88,380	
Startup & Testing	300	HRS	\$ -	\$ 100		\$ -	\$ 32,700	\$ -	\$ 32,700	

\$ 2,432,810	Subtotal
\$ 486,562	20% Contingency
\$ 583,874	20% Contractor O&P
\$ 350,325	10% Engineering
<b>\$ 3,853,571</b>	<b>Total</b>





City of Troy

Multipliers	
Material:	0.98
Labor:	1.09
Equipment:	1.00

Phase 1B  
WSHP District Energy

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Geothermal Well Install</b>										
Hardscape Restoration	300	LF							\$ 45,000	
Parking Lot Excavation	25000	SF		\$ 40				\$ 1,000,000	\$ 1,000,000	
Parking Lot Restoration	25000	SF		\$ 1.5				\$ 37,500	\$ 37,500	
Geothermal Boreholes (280 Boreholes x 500 ft)	140000	LF		\$ 50				\$ 7,000,000	\$ 7,000,000	
Heat Exchanger	6	EA	\$ 75,000	\$ 50,000		\$ 442,350	\$ 327,000		\$ 769,350	
						\$ -	\$ -		\$ -	
<b>Mechanical Systems</b>										
Central Plant Buildings	1500	SF			\$ 750			\$ 1,125,000	\$ 1,125,000	
Pump Station	500	SF			\$ 750			\$ 375,000	\$ 375,000	
HDPE Piping	25000	LF	\$ 25	\$ 5.5		\$ 614,375	\$ 149,875		\$ 764,250	
Loop Pumps	6	EA	\$ 8,500	\$ 1,125		\$ 50,133	\$ 7,358		\$ 57,491	
Pump VFD	6	EA	\$ 7,500	\$ 1,350		\$ 44,235	\$ 8,829		\$ 53,064	
Borefield Pumps	6	EA	\$ 12,600	\$ 1,130		\$ 74,315	\$ 7,390		\$ 81,705	
Borefield Pump VFD	6	EA	\$ 15,500	\$ 3,500		\$ 91,419	\$ 22,890		\$ 114,309	
6" Black Iron Pipe	2250	LF	\$ 45	\$ 42		\$ 99,529	\$ 103,005		\$ 202,534	
Steel Fittings	12	LS			\$ 15,000			\$ 180,000	\$ 180,000	
4" HDPE	1250	LF	\$ 4			\$ 4,706	\$ -		\$ 4,706	
3" HDPE	1250	LF	\$ 3	\$ 8		\$ 3,096	\$ 10,219		\$ 13,315	
2 1/2" HDPE	1250	LF	\$ 2	\$ 8		\$ 2,826	\$ 10,219		\$ 13,045	
2" HDPE	1250	LF	\$ 2	\$ 8		\$ 2,322	\$ 10,219		\$ 12,541	
1 1/2" HDPE	1250	LF	\$ 1	\$ 8		\$ 1,401	\$ 10,219		\$ 11,620	
HDPE Fittings	7	LS			\$ 10,657			\$ 74,598	\$ 74,598	
Air Separator - 6"	6	EA	\$ 3,950	\$ 533		\$ 23,297	\$ 3,486		\$ 26,783	
Expansion Tanks -300 gal	6	EA	\$ 3,000	\$ 200		\$ 17,694	\$ 1,308		\$ 19,002	
						\$ -	\$ -		\$ -	
						\$ -	\$ -		\$ -	
<b>River Heat Exchanger</b>										
Rigging	1	EA			\$ 75,000			\$ 75,000	\$ 75,000	
HEX Equipment (100 Ton)	70	TONS		\$ 750			\$ 57,225		\$ 57,225	
HEX Labor	120	HRS		\$ 250			\$ 32,700		\$ 32,700	
Piping	500	LF	\$ 45	\$ 40		\$ 22,118	\$ 21,800		\$ 43,918	
Pumps + Motor + VFD	2	EA	\$ 25,000	\$ 17,500		\$ 49,150	\$ 38,150		\$ 87,300	
Electricals	1	EA	\$ 8,500	\$ 4,500		\$ 8,356	\$ 4,905		\$ 13,261	
						\$ -	\$ -		\$ -	
<b>WSHP Heat Pump Terminal Equipment Cost</b>										
Taylor 1 - New construction will already have HPs	100,000	SF		\$ 2.0		\$ -	\$ -	\$ 200,000	\$ 200,000	
Taylor 2 - New construction will already have HPs	100,000	SF		\$ 2.0						
Taylor 3 - New construction will already have HPs	100,000	SF		\$ 2.0						
Taylor 4 - New construction will already have HPs	100,000	SF		\$ 2.0		\$ -	\$ -	\$ 200,000	\$ 200,000	
Hart Hall	21,552	SF		\$ 20		\$ -	\$ -	\$ 431,040	\$ 431,040	
Ricketts Hall	34,191	SF		\$ 20		\$ -	\$ -	\$ 683,820	\$ 683,820	
Roy Courtyard	7,757	SF		\$ 20		\$ -	\$ -	\$ 155,140	\$ 155,140	
Cowee Hall + Swimming Pool	23,313	SF		\$ 20		\$ -	\$ -	\$ 466,260	\$ 466,260	
Slingerland Alumnae House	5,208	SF		\$ 20		\$ -	\$ -	\$ 104,160	\$ 104,160	
Manning Hall	27,798	SF		\$ 20		\$ -	\$ -	\$ 555,960	\$ 555,960	
Esteves School of Education	12,600	SF		\$ 20		\$ -	\$ -	\$ 252,000	\$ 252,000	
Plum Memorial	9,794	SF		\$ 20		\$ -	\$ -	\$ 195,880	\$ 195,880	
						\$ -	\$ -		\$ -	
<b>Misc and Electrical</b>										
SWPPP/Erosion Control	1	LS		\$ 35,000		\$ -	\$ -	\$ 35,000	\$ 35,000	
Site Prep/Access	1	LS		\$ 30,000		\$ -	\$ -	\$ 30,000	\$ 30,000	
Construction Management	1	LS		\$ 300,000		\$ -	\$ -	\$ 300,000	\$ 300,000	
						\$ -	\$ -		\$ -	

\$ 15,899,475	Subtotal
\$ 3,179,895	20% Contingency
\$ 3,815,874	20% Contractor O&P
\$ 2,289,524	10% Engineering
<b>\$ 25,184,768</b>	<b>Total</b>

City of Troy

Multipliers	
Material:	0.98
Labor:	1.09
Equipment:	1.00

**Phase 1B**  
**Boiler, Chiller, Tower System**

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Boilers</b>										
Taylor 1 -2 x 1500 MBH	2	EA	\$ 38,000	\$ 13,500		\$ 74,708	\$ 29,430	\$ -	\$ 104,138	
Taylor 2 -2 x 1500 MBH	2	EA	\$ 38,000	\$ 13,500		\$ 74,708	\$ 29,430	\$ -	\$ 104,138	
Taylor 3 -2 x 1500 MBH	2	EA	\$ 38,000	\$ 13,500		\$ 74,708	\$ 29,430	\$ -	\$ 104,138	
Taylor 4 -2 x 1500 MBH	2	EA	\$ 38,000	\$ 13,500		\$ 74,708	\$ 29,430	\$ -	\$ 104,138	
Cowee Hall + Swimming Pool -2 x 500 MBH	2	EA	\$ 20,000	\$ 9,500		\$ 39,320	\$ 20,710	\$ -	\$ 60,030	
Slingerland Alumnae House - 100 MBH Furnace	1	EA	\$ 4,500	\$ 1,500		\$ 4,424	\$ 1,635	\$ -	\$ 6,059	
Roy Courtyard - 150 MBH Furnace	1	EA	\$ 7,500	\$ 2,250		\$ 7,373	\$ 2,453	\$ -	\$ 9,825	
Hart Hall - 2 x 500 MBH	2	EA	\$ 20,000	\$ 9,500		\$ 39,320	\$ 20,710	\$ -	\$ 60,030	
Ricketts Hall - 2 x 500 MBH	2	EA	\$ 20,000	\$ 9,500		\$ 39,320	\$ 20,710	\$ -	\$ 60,030	
Manning Hall - 2 x 500 MBH	2	EA	\$ 20,000	\$ 9,500		\$ 39,320	\$ 20,710	\$ -	\$ 60,030	
Esteves School of Education - 2 x 300 MBH	2	EA	\$ 12,000	\$ 5,150		\$ 23,592	\$ 11,227	\$ -	\$ 34,819	
Plum Memorial - 200 MBH Furnace	1	EA	\$ 10,000	\$ 4,500		\$ 9,830	\$ 4,905	\$ -	\$ 14,735	
						\$ -	\$ -	\$ -	\$ -	
<b>Main Pumps</b>										
Taylor 1 -2x10 HP Pump	2	EA	\$ 14,950	\$ 950		\$ 29,392	\$ 2,071	\$ -	\$ 31,463	
Taylor 2 -2x10 HP Pump	2	EA	\$ 14,950	\$ 950		\$ 29,392	\$ 2,071	\$ -	\$ 31,463	
Taylor 3 -2x10 HP Pump	2	EA	\$ 14,950	\$ 950		\$ 29,392	\$ 2,071	\$ -	\$ 31,463	
Taylor 4 -2x10 HP Pump	2	EA	\$ 14,950	\$ 950		\$ 29,392	\$ 2,071	\$ -	\$ 31,463	
Cowee Hall + Swimming Pool - 2x5 HP	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
Hart Hall - 2x5 HP	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
Ricketts Hall - 2x5 HP	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
Manning Hall - 2x5 HP	2	EA	\$ 12,500	\$ 650		\$ 24,575	\$ 1,417	\$ -	\$ 25,992	
Esteves School of Education - 2x3 HP	2	EA	\$ 7,500	\$ 500		\$ 14,745	\$ 1,090	\$ -	\$ 15,835	
Slingerland Alumnae House- Fan/Motor/VFD	1	EA	\$ 4,500	\$ 450		\$ 4,424	\$ 491	\$ -	\$ 4,914	
Roy Courtyard - Fan/Motor/VFD	1	EA	\$ 5,500	\$ 550		\$ 5,407	\$ 600	\$ -	\$ 6,006	
Plum Memoria - Fan/Motor/VFD	1	EA	\$ 6,500	\$ 550		\$ 6,390	\$ 600	\$ -	\$ 6,989	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
<b>Cooling PTAC with Hot Water Heat-0620</b>										
Cooling PTACs w/ HW coil	11,217	MBH			\$ 118				\$ 1,318,050	
<b>Circ Pumps</b>										
Taylor 1 -Circulation Pumps 3-HP	2	EA	\$ 3,000	\$ 500		\$ 5,898	\$ 1,090	\$ -	\$ 6,988	
Taylor 2 -Circulation Pumps 3-HP	2	EA	\$ 3,000	\$ 500		\$ 5,898	\$ 1,090	\$ -	\$ 6,988	
Taylor 3 -Circulation Pumps 3-HP	2	EA	\$ 3,000	\$ 500		\$ 5,898	\$ 1,090	\$ -	\$ 6,988	
Taylor 4 -Circulation Pumps 3-HP	2	EA	\$ 3,000	\$ 500		\$ 5,898	\$ 1,090	\$ -	\$ 6,988	
Cowee Hall + Swimming Pool - 1 HP	2	EA	\$ 2,050	\$ 250		\$ 4,030	\$ 545	\$ -	\$ 4,575	
Hart Hall - 1 HP	2	EA	\$ 2,050	\$ 250		\$ 4,030	\$ 545	\$ -	\$ 4,575	
Ricketts Hall - 1 HP	2	EA	\$ 2,050	\$ 250		\$ 4,030	\$ 545	\$ -	\$ 4,575	
Manning Hall - 1 HP	2	EA	\$ 2,050	\$ 250		\$ 4,030	\$ 545	\$ -	\$ 4,575	
Esteves School of Education - 3/4 HP	2	EA	\$ 1,500	\$ 200		\$ 2,949	\$ 436	\$ -	\$ 3,385	
<b>For four new buildings/ Use existing for all others.</b>										
Misc Electricals - xformer/ Panel/ Switchgear	12	EA	\$ 20,000	\$ 9,500		\$ 235,920	\$ 124,260	\$ -	\$ 360,180	
Chemical Treatment	9	EA			\$ 6,500	\$ -	\$ -	\$ 58,500	\$ 58,500	
Concrete Pad - Primary Boilers	9	EA	\$ 4,500	\$ 1,500		\$ 39,812	\$ 14,715	\$ -	\$ 54,527	
Boiler Rigging - All Boilers	9	EA			\$ 7,500	\$ -	\$ -	\$ 67,500	\$ 67,500	
Boiler - Flue Venting (double wall stainless steel AL-294c)	9	EA	\$ 20,000	\$ 5,500		\$ 176,940	\$ 53,955	\$ -	\$ 230,895	
Boiler / Furnace Controls and Wiring	12	EA	\$ 7,500	\$ 4,500		\$ 88,470	\$ 58,860	\$ -	\$ 147,330	
Power Wiring to new equipment	12	EA	\$ 5,000	\$ 4,500		\$ 58,980	\$ 58,860	\$ -	\$ 117,840	
Startup & Testing	400	HRS	\$ -	\$ 100		\$ -	\$ 43,600	\$ -	\$ 43,600	

\$ 3,433,732	Subtotal
\$ 686,746	20% Contingency
\$ 686,746	20% Contractor O&P
\$ 343,373	10% Engineering
<b>\$ 5,150,597</b>	<b>Total</b>

LCA Calculation for Troy BES Geothermal Phase 2

Total buildings square footage	20,000
Base-load Electric Utility Rate (per kWh)	0.16
Capacity Rate (per kW)	0.16

Energy Efficiency Improvement	0.25%
Cost Savings (\$/kW)	0.04

20 Year Project Energy Consumption (kWh)	2,384,000
--	-----------

20 Year Energy Consumption Comparison (System efficiency delta varies by 0.25% every year)	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10	Year 11	Year 12	Year 13	Year 14	Year 15	Year 16	Year 17	Year 18	Year 19	Year 20	Total kWh	
Base-load electric utility consumption	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	381,440	7,628,800
Energy Efficiency Improvement	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-95,360	-1,907,200
Net Energy Consumption	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	286,080	5,721,600

Operations and Maintenance	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10	Year 11	Year 12	Year 13	Year 14	Year 15	Year 16	Year 17	Year 18	Year 19	Year 20	Total (\$)	
Annual O&M	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	2,000

Total Equipment Replacement Cost at the End of Equipment Life	0
---	---

Boiler Replacement Cost at the End of Equipment Life	0
--	---

Energy Cost Savings	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10	Year 11	Year 12	Year 13	Year 14	Year 15	Year 16	Year 17	Year 18	Year 19	Year 20	Total (\$)	
Annual Savings	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	307,200

Cost of Part Equipment Installation	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10	Year 11	Year 12	Year 13	Year 14	Year 15	Year 16	Year 17	Year 18	Year 19	Year 20	Total (\$)	
Installation Costs	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

NPV ANALYSIS

NPV ANALYSIS	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10	Year 11	Year 12	Year 13	Year 14	Year 15	Year 16	Year 17	Year 18	Year 19	Year 20	Total (\$)	
Initial Investment	-100,000																					-100,000
Annual Savings	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	15,360	307,200	
Net Present Value	-100,000	13,600	12,500	11,400	10,300	9,200	8,100	7,000	5,900	4,800	3,700	2,600	1,500	400	-700	-1,600	-2,500	-3,400	-4,300	-5,200	-6,100	-10,000

City of Troy

Multipliers	
Material:	0.98
Labor:	1.09
Equipment:	1.00

Phase 2  
WSHP District Energy

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Geothermal Well Install</b>										
Hardscape Restoration	300	LF			\$ 150	\$ -	\$ -	\$ 45,000	\$ 45,000	
Parking Lot Excavation	25000	SF			\$ 40	\$ -	\$ -	\$ 1,000,000	\$ 1,000,000	
Parking Lot Restoration	25000	SF			\$ 1.5	\$ -	\$ -	\$ 37,500	\$ 37,500	
Geothermal Boreholes (230 Boreholes x 500 ft)	115000	LF			\$ 50	\$ -	\$ -	\$ 5,750,000	\$ 5,750,000	
Heat Exchanger	6	EA	\$ 75,000	\$ 50,000		\$ 442,350	\$ 327,000	\$ -	\$ 769,350	
						\$ -	\$ -	\$ -	\$ -	
<b>Mechanical Systems</b>										
Central Plant Buildings	2100	SF			\$ 750	\$ -	\$ -	\$ 1,575,000	\$ 1,575,000	
Pump Station	750	SF			\$ 750	\$ -	\$ -	\$ 562,500	\$ 562,500	
HDPE Piping	35000	LF	\$ 25	\$ 5.5		\$ 860,125	\$ 209,825	\$ -	\$ 1,069,950	
Loop Pumps	12	EA	\$ 8,500	\$ 1,125		\$ 100,266	\$ 14,715	\$ -	\$ 114,981	
Pump VFD	12	EA	\$ 7,500	\$ 1,350		\$ 88,470	\$ 17,658	\$ -	\$ 106,128	
Borefield Pumps	12	EA	\$ 12,600	\$ 1,130		\$ 148,630	\$ 14,780	\$ -	\$ 163,410	
Borefield Pump VFD	12	EA	\$ 15,500	\$ 3,500		\$ 182,838	\$ 45,780	\$ -	\$ 228,618	
6" Black Iron Pipe	3500	LF	\$ 45	\$ 42		\$ 154,823	\$ 160,230	\$ -	\$ 315,053	
Steel Fittings	15	LS			\$ 15,000	\$ -	\$ -	\$ 225,000	\$ 225,000	
4" HDPE	2500	LF	\$ 4			\$ 9,412	\$ -	\$ -	\$ 9,412	
3" HDPE	2500	LF	\$ 3	\$ 8		\$ 6,193	\$ 20,438	\$ -	\$ 26,630	
2 1/2" HDPE	2500	LF	\$ 2	\$ 8		\$ 5,652	\$ 20,438	\$ -	\$ 26,090	
2" HDPE	2500	LF	\$ 2	\$ 8		\$ 4,645	\$ 20,438	\$ -	\$ 25,082	
1 1/2" HDPE	2500	LF	\$ 1	\$ 8		\$ 2,802	\$ 20,438	\$ -	\$ 23,239	
HDPE Fittings	10	LS			\$ 10,657	\$ -	\$ -	\$ 106,568	\$ 106,568	
Air Separator - 6"	12	EA	\$ 3,950	\$ 533		\$ 46,594	\$ 6,972	\$ -	\$ 53,566	
Expansion Tanks -300 gal	12	EA	\$ 3,000	\$ 200		\$ 35,388	\$ 2,616	\$ -	\$ 38,004	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
<b>River Heat Exchanger</b>										
Rigging	1	EA			\$ 75,000	\$ -	\$ -	\$ 75,000	\$ 75,000	
HEX Equipment (100 Ton)	100	TONS		\$ 750		\$ -	\$ 81,750	\$ -	\$ 81,750	
HEX Labor	150	HRS		\$ 250		\$ -	\$ 40,875	\$ -	\$ 40,875	
Piping	500	LF	\$ 45	\$ 40		\$ 22,118	\$ 21,800	\$ -	\$ 43,918	
Pumps + Motor + VFD	2	EA	\$ 25,000	\$ 17,500		\$ 49,150	\$ 38,150	\$ -	\$ 87,300	
Electricals	1	EA	\$ 8,500	\$ 4,500		\$ 8,356	\$ 4,905	\$ -	\$ 13,261	
						\$ -	\$ -	\$ -	\$ -	
<b>WSHP Heat Pump Terminal Equipment Cost</b>										
WSHP Heat Pump Terminal Equipment and Installation Cos	901,095	SF			\$ 20.0	\$ -	\$ -	\$ 18,021,900	\$ 18,021,900	
						\$ -	\$ -	\$ -	\$ -	
<b>Misc and Electrical</b>										
SWPPP/Erosion Control	1	LS			\$ 35,000	\$ -	\$ -	\$ 35,000	\$ 35,000	
Site Prep/Access	1	LS			\$ 30,000	\$ -	\$ -	\$ 30,000	\$ 30,000	
Construction Management	1	LS			\$ 300,000	\$ -	\$ -	\$ 300,000	\$ 300,000	
						\$ -	\$ -	\$ -	\$ -	

\$ 31,000,084	Subtotal
\$ 6,200,017	20% Contingency
\$ 7,440,020	20% Contractor O&P
\$ 4,464,012	10% Engineering
<b>\$ 49,104,133</b>	<b>Total</b>

City of Troy

Phase 2

Boiler Chiller Tower System

Multipliers		
Material:		0.98
Labor:		1.09
Equipment:		1.00

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Boilers</b>										
100 2nd Street	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
141 Congress Street	1000 MBH	2	EA	\$ 38,000	\$ 12,500		\$ 74,708	\$ 27,250	\$ -	\$ 101,958
1646 5th Avenue	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
119 Congress Street	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
51 State Street	400 MBH	2	EA	\$ 25,000	\$ 7,500		\$ 49,150	\$ 16,350	\$ -	\$ 65,500
1700 6th Avenue	300 MBH	2	EA	\$ 22,500	\$ 7,500		\$ 44,235	\$ 16,350	\$ -	\$ 60,585
57-59 State Street	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
61 State Street	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
State Street	2000 MBH	2	EA	\$ 50,000	\$ 15,000		\$ 98,300	\$ 32,700	\$ -	\$ 131,000
1776 6th Avenue	1000 MBH	2	EA	\$ 38,000	\$ 12,500		\$ 74,708	\$ 27,250	\$ -	\$ 101,958
1800 6th Avenue	2000 MBH	2	EA	\$ 50,000	\$ 15,000		\$ 98,300	\$ 32,700	\$ -	\$ 131,000
1801 6th Avenue	750 MBH	2	EA	\$ 30,000	\$ 10,000		\$ 58,980	\$ 21,800	\$ -	\$ 80,780
2000 6th Avenue	2000 MBH	2	EA	\$ 50,000	\$ 15,000		\$ 98,300	\$ 32,700	\$ -	\$ 131,000
720 Federal Street	3000 MBH	2	EA	\$ 60,000	\$ 15,000		\$ 117,960	\$ 32,700	\$ -	\$ 150,660
503 Grand Street	750 MBH	2	EA	\$ 30,000	\$ 10,000		\$ 58,980	\$ 21,800	\$ -	\$ 80,780
2001 5th Avenue	750 MBH	2	EA	\$ 30,000	\$ 10,000		\$ 58,980	\$ 21,800	\$ -	\$ 80,780
92-96 Fourth Street	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
30 3rd Street	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
43 3rd Street	100 MBH	2	EA	\$ 10,000	\$ 5,000		\$ 19,660	\$ 10,900	\$ -	\$ 30,560
32 2nd Street	300 MBH	2	EA	\$ 22,500	\$ 7,500		\$ 44,235	\$ 16,350	\$ -	\$ 60,585
<b>Main Pumps</b>										
100 2nd Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
141 Congress Street	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
1646 5th Avenue	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
119 Congress Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
51 State Street	2x 7.5 HP	2	EA	\$ 7,500	\$ 1,250		\$ 14,745	\$ 2,725	\$ -	\$ 17,470
1700 6th Avenue	2x 7.5 HP	2	EA	\$ 7,500	\$ 1,250		\$ 14,745	\$ 2,725	\$ -	\$ 17,470
57-59 State Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
61 State Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
State Street	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
1776 6th Avenue	2 x 10 HP	2	EA	\$ 10,000	\$ 1,500		\$ 19,660	\$ 3,270	\$ -	\$ 22,930
1800 6th Avenue	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
1801 6th Avenue	2 x 10 HP	2	EA	\$ 10,000	\$ 1,250		\$ 19,660	\$ 2,725	\$ -	\$ 22,385
2000 6th Avenue	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
720 Federal Street	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
503 Grand Street	2 x 10 HP	2	EA	\$ 10,000	\$ 1,250		\$ 19,660	\$ 2,725	\$ -	\$ 22,385
2001 5th Avenue	2 x 10 HP	2	EA	\$ 10,000	\$ 1,250		\$ 19,660	\$ 2,725	\$ -	\$ 22,385
92-96 Fourth Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
30 3rd Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
43 3rd Street	2x 3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
32 2nd Street	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
<b>Cooling PTAC with Hot Water Heat -0620</b>										
Cooling PTACs w/ HW coil included in terminal costs	901,095		SOFT							\$ 1,534,550
<b>Circ Pumps</b>										
100 2nd Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
141 Congress Street	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
1646 5th Avenue	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
119 Congress Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
51 State Street	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
1700 6th Avenue	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
57-59 State Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
61 State Street	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
State Street	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
1776 6th Avenue	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
1800 6th Avenue	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
1801 6th Avenue	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
2000 6th Avenue	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
720 Federal Street	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
503 Grand Street	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
2001 5th Avenue	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
92-96 Fourth Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
30 3rd Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
43 3rd Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
32 2nd Street	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
<b>For four new buildings/ Use existing for all others.</b>										
Misc Electricals - xformer/ Panel/ Switchgear	20		EA	\$ 16,000	\$ 7,500		\$ 314,560	\$ 163,500	\$ -	\$ 478,060
Chemical Treatment	20		EA			\$ 3,500	\$ -	\$ -	\$ 70,000	\$ 70,000
Concrete Pad - Primary Boilers	20		EA	\$ 4,500	\$ 1,500		\$ 88,470	\$ 32,700	\$ -	\$ 121,170
Boiler Rigging - All Boilers	20		EA			\$ 7,500	\$ -	\$ -	\$ 150,000	\$ 150,000
Boiler - Flue Venting (double wall stainless steel AL-294c)	20		EA	\$ 20,000	\$ 4,500		\$ 393,200	\$ 98,100	\$ -	\$ 491,300
Gas Piping	20		EA	\$ 7,500	\$ 5,000		\$ 147,450	\$ 109,000	\$ -	\$ 256,450
Boiler Controls and Wiring	20		EA	\$ 5,000	\$ 3,500		\$ 98,300	\$ 76,300	\$ -	\$ 174,600
Power Wiring to new equipment	20		EA	\$ 5,000	\$ 4,500		\$ 98,300	\$ 98,100	\$ -	\$ 196,400
Startup & Testing	1000		HRS	\$ -	\$ 100		\$ -	\$ 109,000	\$ -	\$ 109,000

\$ 5,659,345	Subtotal
\$ 1,131,869	20% Contingency
\$ 1,131,869	20% Contractor O&P
\$ 565,935	10% Engineering
<b>\$ 8,489,018</b>	<b>Total</b>





City of Troy

Phase 3

**Boiler Chiller Tower System**

Multipliers		
Material:		0.98
Labor:		1.09
Equipment:		1.00

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
<b>Boilers</b>										
Building - 1	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
Building - 2	1000 MBH	2	EA	\$ 38,000	\$ 12,500		\$ 74,708	\$ 27,250	\$ -	\$ 101,958
Building - 3	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
Building - 4	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
Building - 5	400 MBH	2	EA	\$ 25,000	\$ 7,500		\$ 49,150	\$ 16,350	\$ -	\$ 65,500
Building - 6	300 MBH	2	EA	\$ 22,500	\$ 7,500		\$ 44,235	\$ 16,350	\$ -	\$ 60,585
Building - 7	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
Building - 8	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
Building - 9	2000 MBH	2	EA	\$ 50,000	\$ 15,000		\$ 98,300	\$ 32,700	\$ -	\$ 131,000
Building - 10	1000 MBH	2	EA	\$ 38,000	\$ 12,500		\$ 74,708	\$ 27,250	\$ -	\$ 101,958
Building - 11	2000 MBH	2	EA	\$ 50,000	\$ 15,000		\$ 98,300	\$ 32,700	\$ -	\$ 131,000
Building - 12	750 MBH	2	EA	\$ 30,000	\$ 10,000		\$ 58,980	\$ 21,800	\$ -	\$ 80,780
Building - 13	2000 MBH	2	EA	\$ 50,000	\$ 15,000		\$ 98,300	\$ 32,700	\$ -	\$ 131,000
Building - 14	3000 MBH	2	EA	\$ 60,000	\$ 15,000		\$ 117,960	\$ 32,700	\$ -	\$ 150,660
Building - 15	750 MBH	2	EA	\$ 30,000	\$ 10,000		\$ 58,980	\$ 21,800	\$ -	\$ 80,780
Building - 16	750 MBH	2	EA	\$ 30,000	\$ 10,000		\$ 58,980	\$ 21,800	\$ -	\$ 80,780
Building - 17	200 MBH	2	EA	\$ 20,000	\$ 7,500		\$ 39,320	\$ 16,350	\$ -	\$ 55,670
<b>Main Pumps</b>										
Building - 1	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
Building - 2	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
Building - 3	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
Building - 4	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
Building - 5	2x 7.5 HP	2	EA	\$ 7,500	\$ 1,250		\$ 14,745	\$ 2,725	\$ -	\$ 17,470
Building - 6	2x 7.5 HP	2	EA	\$ 7,500	\$ 1,250		\$ 14,745	\$ 2,725	\$ -	\$ 17,470
Building - 7	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
Building - 8	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
Building - 9	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
Building - 10	2 x 10 HP	2	EA	\$ 10,000	\$ 1,500		\$ 19,660	\$ 3,270	\$ -	\$ 22,930
Building - 11	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
Building - 12	2 x 10 HP	2	EA	\$ 10,000	\$ 1,250		\$ 19,660	\$ 2,725	\$ -	\$ 22,385
Building - 13	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
Building - 14	2x 15 HP	2	EA	\$ 12,500	\$ 1,500		\$ 24,575	\$ 3,270	\$ -	\$ 27,845
Building - 15	2 x 10 HP	2	EA	\$ 10,000	\$ 1,250		\$ 19,660	\$ 2,725	\$ -	\$ 22,385
Building - 16	2 x 10 HP	2	EA	\$ 10,000	\$ 1,250		\$ 19,660	\$ 2,725	\$ -	\$ 22,385
Building - 17	2x 5 HP	2	EA	\$ 5,000	\$ 950		\$ 9,830	\$ 2,071	\$ -	\$ 11,901
<b>Cooling PTAC with Hot Water Heat -0620</b>										
<i>Cooling PTACs w/ HW coil included in terminal costs</i>										
										\$ 3,076,868
<b>Circ Pumps</b>										
Building - 1	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
Building - 2	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
Building - 3	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
Building - 4	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
Building - 5	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
Building - 6	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
Building - 7	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
Building - 8	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
Building - 9	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
Building - 10	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
Building - 11	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
Building - 12	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
Building - 13	3 HP	2	EA	\$ 3,000	\$ 750		\$ 5,898	\$ 1,635	\$ -	\$ 7,533
Building - 14	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
Building - 15	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
Building - 16	2 HP	2	EA	\$ 2,500	\$ 500		\$ 4,915	\$ 1,090	\$ -	\$ 6,005
Building - 17	1 HP	2	EA	\$ 2,000	\$ 250		\$ 3,932	\$ 545	\$ -	\$ 4,477
<b>For four new buildings/ Use existing for all others.</b>										
Misc Electricals - xformer/ Panel/ Switchgear	20		EA	\$ 16,000	\$ 7,500		\$ 314,560	\$ 163,500	\$ -	\$ 478,060
Chemical Treatment	20		EA			\$ 3,500			\$ 70,000	\$ 70,000
Concrete Pad - Primary Boilers	20		EA	\$ 4,500	\$ 1,500		\$ 88,470	\$ 32,700	\$ -	\$ 121,170
Boiler Rigging - All Boilers	20		EA			\$ 7,500			\$ 150,000	\$ 150,000
Boiler - Flue Venting (double wall stainless steel AL-294c)	20		EA	\$ 20,000	\$ 4,500		\$ 393,200	\$ 98,100	\$ -	\$ 491,300
Gas Piping	20		EA	\$ 7,500	\$ 5,000		\$ 147,450	\$ 109,000	\$ -	\$ 256,450
Boiler Controls and Wiring	20		EA	\$ 5,000	\$ 3,500		\$ 98,300	\$ 76,300	\$ -	\$ 174,600
Power Wiring to new equipment	20		EA	\$ 5,000	\$ 4,500		\$ 98,300	\$ 98,100	\$ -	\$ 196,400
Startup & Testing	400	HRS		\$ -	\$ 100			\$ 43,600	\$ -	\$ 43,600

Central Equipment Costs	Central Equipment Costs	\$ 6,944,682
PTAC with HW Heat	Terminal Equipment Costs	\$ 3,076,868

\$ 6,944,682	Subtotal
\$ 1,388,936	20% Contingency
\$ 1,388,936	20% Contractor O&P
\$ 694,468	10% Engineering
<b>\$ 10,417,023</b>	<b>Total</b>



NYSERDA, a public benefit corporation, offers objective information and analysis, innovative programs, technical expertise, and support to help New Yorkers increase energy efficiency, save money, use renewable energy, and reduce reliance on fossil fuels. NYSERDA professionals work to protect the environment and create clean-energy jobs. NYSERDA has been developing partnerships to advance innovative energy solutions in New York State since 1975.

To learn more about NYSERDA's programs and funding opportunities, visit [nyserda.ny.gov](http://nyserda.ny.gov) or follow us on Twitter, Facebook, YouTube, or Instagram.

**New York State  
Energy Research and  
Development Authority**

17 Columbia Circle  
Albany, NY 12203-6399

**toll free:** 866-NYSERDA  
**local:** 518-862-1090  
**fax:** 518-862-1091

[info@nyserda.ny.gov](mailto:info@nyserda.ny.gov)  
[nyserda.ny.gov](http://nyserda.ny.gov)



**NYSERDA**

**State of New York**

Kathy Hochul, Governor

**New York State Energy Research and Development Authority**

Richard L. Kauffman, Chair | Doreen M. Harris, President and CEO