Standards and Quality Assurance

NY-Sun





The Standards and Quality Assurance Team manages a network of third-party inspectors to verify a sampling of projects for compliance with program and technical requirements.

This fact sheet is part of a series aimed at helping contractors become knowledgeable about common nonconformances in the NY-Sun Residential and Nonresidential Program.

The 120% Rule

Data collected from NYSERDA inspections indicates that one of the top critical nonconformances observed in the NY-Sun Residential and Nonresidential Program is: "main panel overcurrent protection is sufficient" for load side connections. In other words, the 120% rule is being sufficiently met.


The 120% rule ensures that a site's electrical service equipment can safely withstand simultaneous electrical load from the utility, solar, storage, and/or other power sources. The rule allows installers to calculate how much new power generation can safely be added as a load side connection. Use this formula to calculate the 120% rule:

(Busbar Rating (A) x 1.2) - Main Breaker Rating (A) = Max PV (A)

Example of the 120% rule

If a home has a busbar rating of 100 amps and a main breaker rating of 100 amps, then the maximum PV output over current protection according to the 120% rule would be 20 amps.

 $(100 A \times 1.2) - 100 A = 20 A$



If you have questions, please contact:

inspections@nyserda.ny.gov



As a reminder, the load side connection must meet all requirements of NEC 705.12(B) to pass inspection, including:

- Inverter output connection is made at a dedicated circuit breaker or fusible disconnect.
- The sum of 125% of the inverter(s) output current plus the main circuit breaker rating must be less than or equal to 120% of the bus or cable rating (NEC 705.12(B)(3)(b)).
- Backfed breaker located at opposite end of busbar from main breaker (NEC 705.12(B)(2)(1))

To help eliminate or reduce the frequency of this nonconformance the Quality Assurance Team suggests:

- 1. Ensure the installation crew has the current set of plans on site.
- 2. Verify crew lead thoroughly understands the plans.
- 3. Confirm the correct parts have been ordered and are on the truck.

Have questions?

If you have questions, please contact: inspections@nyserda.ny.gov.

