



CHP Program – CHP Module/Vendor Qualification
Request for Information (RFI) 2568

Summary of Revisions

March 2016

The CHP Program – CHP Module/Vendor Qualification RFI 2568 has undergone significant changes since the last update. You are encouraged to read the entire RFI in order to get a full understanding of the Program requirements going forward.

Major changes include the following:

1. The minimum system size limit has been eliminated and the maximum size limit has been increased to 3MW.
2. CHP Systems fueled by propane and compressed natural gas are now eligible in addition to pipeline natural gas.
3. Non-black-start capable induction-based modules 50kW and smaller are now eligible.
4. Both black-start capable and non-black-start capable back pressure steam turbines and organic Rankine cycle (ORC) generators are now eligible.
5. A vendor qualification application section has been added.
6. Program gap-filling CHP equipment 1MW and smaller that does not have the operating history to qualify under the general terms of this RFI can apply under a new "CHP Equipment Demonstration" option.
7. Several sections have been rewritten to improve readability and to provide clarity.