



NYSERDA

Multifamily Performance Program Comprehensive Option Guidelines

Version 8

July 2017

Comprehensive Option Guidelines

MULTIFAMILY PERFORMANCE PROGRAM, VERSION 8

Table of Contents

1	MULTIFAMILY PERFORMANCE PROGRAM OVERVIEW	1
2	GENERAL REQUIREMENTS	3
2.1	MPP Comprehensive Option Rules	3
2.2	Deadlines	4
3	ELIGIBILITY	5
3.1	Eligibility Requirements	5
3.1.1	System Benefits Charge	5
3.1.2	Project Size and Building Characteristics	5
3.1.3	Construction Type	5
3.1.4	Market Type (Affordable vs. Market Rate)	6
3.1.5	Extent of Renovation	7
3.1.6	Intended Use	7
3.1.7	Large Projects (500+ units)	8
3.2	Definition of a Project	8
3.3	Coordination with other NYS Energy Efficiency Programs	9
3.3.1	AMP, ResTech, GEPP, and MPP Existing Buildings Versions 1-7	9
3.3.2	Coordination with NYSERDA On-Site Generation Programs	9
3.3.3	Coordination with the MPP Targeted Option	9
3.3.4	Coordination with Utility Program incentives	9
3.4	Contact Information	10
4	INCENTIVES	11
4.1	Base Incentives	11
4.2	Performance Payment (Stage 4)	12
4.3	Incentive Cap	12
5	APPLICATION	13
5.1	Application Documents and Processing	13
5.1.1	Application Submittal	13
5.1.2	Terms and Conditions	13
5.2	Energy Use Baseline	14
5.3	Scoping Session	14
5.4	Application Approval	14
6	STAGE 1 – BUILDING ANALYSIS & SAVINGS VERIFICATION AND INFORMATION TOOL (SAV-IT)	15
6.1	Overview	15
6.2	Auditing Requirements	16

6.2.1	Documentation and data entry	16
6.3	Work Scope Development.....	16
6.3.1	Utility Cost Analysis	17
6.3.2	Cost Estimation	17
6.3.3	Health and Safety Measures.....	17
6.3.4	Operation and Maintenance (O&M) Savings.....	17
6.3.5	Minimum Performance Standards.....	17
6.4	Quality Control	22
6.5	Stage 1 Approval.....	22
6.5.1	Stage 1 Deliverables.....	22
6.5.2	Stage 1 Approval	23
7	STAGES 2 & 3 CONSTRUCTION PHASE	24
7.1	Provider Responsibilities	24
7.2	Changes to the Scope of Work.....	24
7.2.1	Scope Change Document Submission	24
7.3	Optional Stage 2: Construction Management Incentive and 50% Complete	25
7.3.1	50% Complete	25
7.3.2	Construction Manager	25
7.3.3	Stage 2 Deliverables.....	26
7.3.4	Stage 2 Approval	26
7.4	Stage 3: 100% Construction Complete.....	27
7.4.1	Stage 3 Deliverables.....	27
7.4.2	Stage 3 Approval	27
8	SITE INSPECTION.....	29
8.1	Provider Responsibilities	29
8.2	System Testing	29
8.3	Statement of Substantial Completion	29
8.4	Inspection Request Documentation Requirements.....	31
9	STAGE 4 - PERFORMANCE PAYMENT	51
9.1	Overview	51
9.2	Performance Payment Analysis	51
9.3	Non-Achieving Projects	51
9.4	Stage 4 Approval.....	51
9.4.1	Stage 4 Deliverables.....	51
9.4.2	Stage 4 Approval	52
10	APPENDIX A – CONSOLIDATED LIST OF DELIVERABLES	53

1 MULTIFAMILY PERFORMANCE PROGRAM OVERVIEW

NYSERDA's Multifamily Performance Program (MPP) Comprehensive Option helps developers, building owners, and their representatives to plan and implement energy efficiency projects within existing multifamily buildings.

MPP Comprehensive Option participants select and work with a technical service provider who is an approved member of the NYSERDA Multifamily Building Solutions Network (Provider). Participants choose the Provider with whom they want to work. Providers shepherd projects through the Program from beginning to end, performing or overseeing the performance of all the Program's technical service requirements.

The Comprehensive Option focuses on improving the energy usage of existing multifamily buildings by a minimum of 20%. Projects follow a process, which is also represented in Figure 1-1:

- Plan - The building owner works with a Provider to conduct an energy assessment using industry best practices and standards. The Provider identifies improvements that will reduce the building's source energy consumption by at least 20%. Building owners can choose which improvements they would like to install as long as the overall work scope meets or exceeds 20%. The results of this planning phase are submitted to NYSERDA using the Program's Savings Verification and Information Tool.
- Install - The Provider conducts limited construction oversight and inspection services during installation of the improvements identified in their approved work scope. The Provider is not responsible for installing the measures, but is responsible for ensuring that installation is properly completed by whomever the building owner chooses to do the work.
- Measure - One year after construction completion, the project's energy performance is analyzed. If actual performance meets or exceeds the Program's target, building owners are eligible to receive a final Performance Payment incentive.

Multifamily Performance Program Version 8

Comprehensive Option At-A-Glance




FIGURE 1-1: COMPREHENSIVE OPTION AT-A-GLANCE

2 GENERAL REQUIREMENTS

2.1 MPP Comprehensive Option Rules

The following rules apply to all projects accepted under the MPP Comprehensive Option. This list focuses on programmatic requirements and is not intended to cover all of the Program's eligibility requirements as listed in the remainder of this document, the Terms and Conditions, and/or the Provider Agreement.

All references to the "performance target" refer to the minimum percent reduction required by the MPP Comprehensive Option, which is 20%.

1. When assembling a scope of work in the Savings Verification and Information Tool (SAV-IT), the following performance target criteria must be met:
 - a. The SAV-IT must identify a scope of work that will achieve a minimum **20%** source energy use reduction for the project.
 - b. If the NYSERDA-approved SAV-IT indicates that there are insufficient opportunities in the project to achieve the minimum performance target, the participant is ineligible to receive any incentives.
2. Providers must use the utility baseline provided via the NYSERDA's Energy Use Snapshot service.
 - a. The pre-construction utility baseline will be provided by NYSERDA and must be used in the SAV-IT.
 - b. The pre-construction utility baseline may be requested by the Provider up to 12 months prior to Comprehensive Option Application approval.
 - c. NYSERDA will provide the post-construction utility baseline, which will be the basis for determining if a building is eligible to receive a Performance Payment in Stage 4.
3. Providers must perform improvement analyses, including cost and savings projections:
 - a. Energy efficiency measure savings calculations must adhere to the technical standards of the Provider's professional certification (AEE CEM, AEE CEA, or BPI MFBA).
 - b. Energy efficiency measures installed and functional within 12 months prior to NYSERDA approving an application may be included in the SAV-IT to contribute to the 20% performance target. The cost of these previously installed measures must be excluded from the incentive cap that limits NYSERDA's incentives under the Comprehensive Option.
 - c. Submetering may only be included as an eligible measure once all regulatory approvals are complete.

4. Milestones:

- a. Stage 1 deliverables must be submitted within 90 calendar days of NYSERDA's *Application Approval*. Projects that do not meet this deadline will be terminated from the Program and unpaid incentives forfeited.
- b. Stage 3 deliverables must be submitted within two years of the NYSERDA's Application Approval. Projects that do not meet this deadline will be terminated from the Program and unpaid incentives forfeited.
- c. Performance Payment submittals are due within 14 months of the Stage 3 submittal to NYSERDA. Projects that do not meet this deadline will be terminated from the Program and unpaid incentives forfeited.
- d. The deadlines in (a) and (b) can only be extended by a written or emailed request from the Provider to NYSERDA that is approved in writing by NYSERDA. There are no extensions allowed for the deadline in (c) for any reason.

5. Any changes to the approved work scope that alter the project's percent savings reduction or adds or removes measures must be submitted as a revision to the SAV-IT via a Scope Change Request. The project must continue to meet the minimum performance target of 20%.
6. The audit must be conducted or supervised by a certified energy professional (AEE CEM, AEE CEA, or BPI MFBA) and the audit must be conducted in accordance with the certification's standards. This individual may be directly employed by, or a subcontractor to, the Provider responsible for the project. At any time, NYSERDA or its agents may request proof of the auditor certification.
7. All recommended and installed improvements must comply with the Minimum Performance Standards for the MPP Comprehensive Option.

2.2 Deadlines

Provider performance is tracked to determine rate of compliance with Program deadlines. NYSERDA expects projects to meet the following guidelines for deliverables. The Provider is responsible for assuring that their projects move through Stages 1, 2, and 3 in a timely manner to assure that the two-year construction completion deadline is met. SAV-IT Revisions:

- Should be submitted to NYSERDA within 30 days of receiving NYSERDA comments.
- Are expected to be limited to one revision per project.

3 ELIGIBILITY

3.1 Eligibility Requirements

This section provides the requirements for establishing a project. At the onset of their relationship with a potential Program Participant, Providers should determine whether a property is eligible for the Comprehensive Option.

The eligible property types listed in this section is not comprehensive. Special circumstances may be reviewed on a case-by-case basis. Contact NYSERDA at MultifamilyPrograms@nyserda.ny.gov for a review.

3.1.1 System Benefits Charge

All buildings within a project must pay into the NYS System Benefits Charge fund on their electric utility bill.

3.1.2 Project Size and Building Characteristics

- The project must be a multifamily, residential building(s) with five or more units in each building.
- Projects larger than 500 units or multiple projects comprised of a campus larger than 500 units require pre-approval from NYSERDA. See Section 3.1.7 for details and instructions.

3.1.3 Construction Type

Buildings may contain nonresidential commercial space if that space does not consist of more than 50% of the gross heated square footage of the entire building.

3.1.4 Market Type (Affordable vs. Market Rate)

NYSERDA defines affordable housing as projects in which at least 25% of the units are, or are expected to be, occupied by households earning not more than 80% of the area or state median income, whichever is higher. All other properties are considered market rate and ineligible for the Comprehensive Option.

Affordable housing documentation must be submitted with the application package. There are three ways to qualify a project for Affordable Housing incentives:

1. Proxy – NYSERDA allows certain proxies to represent compliance with the above definition. Table 3-1 lists eligible proxies and supporting documentation.

Eligibility Proxy	Details	Documentation Required
A. US HUD, USDA-RD, and other Federally Regulated LMI Housing	Properties that receive subsidies from HUD or USDA-RD based on household income may be defined as LMI, based on household income criteria detailed in the contract or award, including regulatory control or structures such as: <ul style="list-style-type: none"> • Section 8 Contract • Sections 202, 236, 811 • Public Housing Authorities 	Copy of the HUD contract or contract award notice
B. NYS HCR-Regulated Affordable Housing	Properties with subsidized mortgages or contracts that place them under the regulatory control of HCR may be defined as LMI, based on household income criteria detailed in the HCR contract or award	Copy of HCR contract or contract award notice
C. Low Income Housing Tax Credits	Properties that receive tax credits may be defined as LMI based on household income criteria detailed in the tax credit award notice	Copy of tax credit award notice from HCR or HPD.
D. NYCHPD-Regulated LMI Housing (or similar local housing agencies)	Properties with loans, mortgages, or deeds of purchase (HDFC incorporation) from NYCHPD or similar local housing agencies may be defined as LMI, based on household income criteria detailed in the award documentation	Documentation of current mortgage, loan closing, HDFC incorporation, or deeds
E. SONYMA Mortgage Insurance	Properties subsidized for low- to moderate-income multi-family residents with SONYMA subsidized financing through the HFA	Copy of loan closing/mortgage insurance award documents
F. Participation in NYS HFA's 80/20 Program or similar HFA-regulated offerings	Properties that have been accepted into the HFA's 80/20 Program, or similar HFA-regulated offering, may be defined as LMI based on household income criteria detailed in the contract or award.	Copy of the award letter or HFA contract documents.
G. Participation in NYC HDC's 80/20 or Mixed Income Programs or similar HDC-regulated offerings	Properties that have been accepted into the NYC HDC's 80/20 or Mixed Income Program, or similar HDC-regulated offering, may be defined as LMI based on household income criteria detailed in the contract or award.	Copy of the award letter or HDC contract documents.

TABLE 3-1: AFFORDABILITY ELIGIBLE PROXIES

2. Rent Roll – This type of qualification may be used by projects that do not meet the proxy requirements or resident income requirements.

Applications must include the annual rent, size, and occupancy for each apartment in the property. Twenty-five percent of the units must have a calculated household income no more than 80% of the State or Area Median Income, based on the assumption that 30% of household income is applied to housing costs (i.e., rent). A calculation spreadsheet tool is available on the Provider Portal for determining Rent Roll income eligibility. The Rent Roll method may not be combined with the Resident Income method.

3. Resident Income – This type of qualification may be used by projects that do not meet the proxy or Rent Roll requirements. This method requires the submission of signed *Resident Income Certification* forms with supporting documentation for 25% of a project's units. See the *Resident Income Certification Instructions* and related forms (available on the Provider Portal). The Resident Income method may not be combined with the Rent Roll method.

3.1.5 Extent of Renovation

The MPP Comprehensive Option will accept renovations to existing structures defined as changes, additions, or deletions to any system or process that impacts an existing building's energy consumption and/or cost not defined as New Construction or Substantial Renovations (gut rehabs).

Substantial Renovations (gut rehabs) are not eligible for MPP. These types of projects may be eligible for the incentives through other NYSEDA or utility programs serving New Construction buildings. Substantial Renovations are defined as one of the following types of projects:

- Change of use and reconstruction of an existing building or space within;
- Construction work of a nature requiring that the building or space within be out of service for at least 30 consecutive days;
- Reconstruction of a vacant structure or space within.

Contact the New Construction Team at NYSEDA (ResMFNCP@nyserda.ny.gov) for more information about New Construction Programs for Multifamily Buildings.

3.1.6 Intended Use

The intended use of the building must be for residential purposes. Commercial facilities, such as motels/hotels, group homes, dormitories, shelters, monasteries, nunneries, assisted living facilities, and nursing homes are typically not eligible for MPP. Supportive housing, Single Room Occupancy (SRO) facilities, and senior living residences that do not include nursing or hospitalization amenities are typically eligible for MPP. Supportive housing is defined as residences that are owned and operated by nonprofit organizations. Tenants are individuals and families who require affordable permanent housing and support services, have lease agreements, pay rent (often a percentage of their income), and abide by the terms of their lease. This group includes people who have been homeless, have histories of substance abuse, are coping with mental illness, have chronic physical illness, are young adults aging out of foster care, are homeless veterans, or are grandparents raising grandchildren.

3.1.7 Large Projects (500+ units)

Projects over 500 units require pre-approval from NYSERDA before applying to MPP. Providers considering large projects should send an email to multifamilyprograms@nyserda.ny.gov containing the following information:

- Project name
- Project address or utility territory
- Number of buildings
- Number of units
- Affordability Proxy


NYSERDA will review the information and determine potentially available funding based on the size of the project. NYSERDA will then contact the Provider regarding how to move forward.

3.2 Definition of a Project

A Comprehensive Option project is defined as a building or group of buildings where energy assessments are performed by a Provider for a single Program Participant. The Provider will develop one SAV-IT per project.

One project can include multiple buildings with multiple energy assessments.

- Project can consist of multiple buildings.
- One Comprehensive Option Application is allowed per project.
- One SAV-IT is allowed per project.
- One SAV-IT can include multiple buildings.
- One SAV-IT can include multiple energy assessments.



3.3 Coordination with other NYS Energy Efficiency Programs

3.3.1 AMP, ResTech, GEPP, and MPP Existing Buildings Versions 1-7

Projects that participated in NYSERDA’s Assisted Multifamily Program (AMP), Residential Technical Assistance (ResTech), or MPP EB Versions 1 - 7 and received funding must fulfill their current contract before applying to Version 8. Projects participating in MPP EB Versions 1 – 7 that have not received funding may terminate their contract and reapply to Version 8. These re-application projects will not retain their previous funding, but will be applying anew for Version 8 funding.

3.3.2 Coordination with NYSERDA On-Site Generation Programs

Projects participating in the Comprehensive Option may participate in both MPP and one or several of the NYSERDA renewable programs including on-site generation, solar electric, and others. Energy savings and measure costs from these systems may contribute to the 20% performance target and the total project costs. The incentives received from other NYSERDA programs will be deducted from the total eligible MPP incentives.

3.3.3 Coordination with the MPP Targeted Option

Projects that participated in the MPP Targeted Option may participate in the Comprehensive Option. Energy savings and measure costs of Targeted Option measures may contribute to the 20% performance target and the total project costs. The incentives received from the Targeted Option will be deducted from the total eligible MPP incentives.

3.3.4 Coordination with Utility Program incentives

Projects that received utility program incentives for energy efficiency measures installed and functional within one year (12 months) prior to NYSERDA’s Application approval may include those measures in the project’s MPP scope of work. The energy savings and cost of the measures may contribute to the 20% performance target and the total project costs. The utility incentive will be deducted from the total eligible MPP incentive.

Coordination with Previously Installed Measures and Other Energy Efficiency Programs			
	Measure savings may be used to reach Performance Target	Measure costs may be included in Incentive Cap	Incentive Adjustments
Previously Installed Measures	Yes	No	N/A
Utility Programs	Yes	Yes	Utility Incentives are deducted from eligible MPP Incentive
Other NYSERDA Programs (renewables, MPP Targeted Option)	Yes	Yes	Other Program incentives are deducted from eligible MPP Incentive

TABLE 3-2: PROGRAM INTERACTIONS

3.4 Contact Information

Email all application, intake, and eligibility questions to **MultifamilyPrograms@nyserda.ny.gov**.

A project Case Manager is assigned upon application approval to coordinate all project-related tasks. All correspondence and questions about a project after an Application Approval email is received must be directed to the project's Case Manager. Contact information will be provided upon assignment. Email all project submittals to **MultifamilyPrograms@nyserda.ny.gov**.

4 INCENTIVES

4.1 Base Incentives

Projects are eligible to receive financial assistance through a schedule of incentives. This schedule is subject to modification. Incentives are distributed via the schedule of payments in Table 4-2 and Table 4-3.

Projected Energy Savings Target	Total Incentive (per unit)	Base Incentive (per unit)	Performance Payment (per unit)
20% - 24%	\$700	\$600	\$100
25% - 29%	\$800	\$700	\$100
30% - 34%	\$1,000	\$800	\$200
35% +	\$1,500	\$1,000	\$500

TABLE 4-1: INCENTIVE SCHEDULE

Projected Energy Savings Target	Stage 1* Analysis (per unit)	Stage 2 Construction Management (per unit)	Stage 3 Construction Complete (per unit)	Stage 4 Performance Payment (per unit)
20% - 24%	\$100	\$200	\$300	\$100
25% - 29%	\$100	\$250	\$350	\$100
30% - 34%	\$100	\$300	\$400	\$200
35% +	\$100	\$400	\$500	\$500

* If the NYSERDA-approved SAV-IT indicates that there are insufficient opportunities in the project to achieve the minimum performance target, the participant will be paid the lesser of Stage 1 payment OR 25% of the cost of the SAV-IT services provided by the Multifamily Performance Provider as documented in the executed contract between the Provider and the Participant OR \$5,000.

TABLE 4-2: INCENTIVE PAYMENT SCHEDULE FOR PROJECTS WITH 50 UNITS OR LESS AND NOT SUBJECT TO LOCAL LAW 84 IN NEW YORK CITY

Projected Energy Savings Target	Stage 1 Analysis (per unit)	Stage 2 Construction Management (per unit)	Stage 3 Construction Complete (per unit)	Stage 4 Performance Payment (per unit)
20% - 24%	N/A	\$300	\$300	\$100
25% - 29%	N/A	\$350	\$350	\$100
30% - 34%	N/A	\$400	\$400	\$200
35% +	N/A	\$500	\$500	\$500

TABLE 4-3: INCENTIVE PAYMENT SCHEDULE FOR PROJECTS WITH MORE THAN 50 UNITS OR SUBJECT TO LOCAL LAW 84 IN NEW YORK CITY

4.2 Performance Payment (Stage 4)

All projects are eligible to receive a Performance Payment in addition to the Base Incentive. The projected energy reduction from the SAV-IT must determine the project's Performance Payment tier in accordance with Table 4-1. If a project's one-year post-construction analysis demonstrates an actual energy reduction within the project's original tier, the project will receive a Performance Payment equal to that tier's amount. If the analysis demonstrates actual savings greater than the project's original tier, the Performance Payment will be at the original tier's amount. If the analysis demonstrates actual savings, less than the project's original tier, but at least 20%, the Performance Payment will be at the new tier's amount. If the analysis demonstrates actual savings less than 20%, the project will not receive a Performance Payment.

Refer to Section 9.4 for more information on deliverables.

4.3 Incentive Cap

NYSERDA incentives will not exceed 50% of the total costs of eligible measures. For the purposes of calculating the incentive cap, the total project cost includes the total cost of improvements in the proposed SAV-IT. The following are not included in the total project cost for the purposes of calculating the incentive cap: previously installed measures, Provider fees for delivering required Program services; and construction management fees.

5 APPLICATION

Before submitting a project application package to NYSERDA for a potential Participant, Providers should work with the potential Participant to determine eligibility and potential incentives as outlined in Sections 3 and 4. The Provider is expected to take the lead role in the project application process.

5.1 Application Documents and Processing

Upon identifying an eligible project, the Provider (in consultation with the Participant) should submit an application to MPP. The Application package consists of the following deliverables:

Project Information Form	Use this form to help gather basic information about the project. (Does not need to be submitted with the online application.)
Terms and Conditions	This is the contract where the Participant accepts the rules and requirements of the Comprehensive Option.
W-9	Establishes the Federal Tax Identification Number of the Participant.
Affordable Housing Documentation	Required for all projects.
Energy Use Snapshot Request (if applicable)	This package of materials allows NYSERDA to establish the project's energy use baseline. Projects are required to use NYSERDA's baseline as a basis for energy savings calculations. A new Energy Use Snapshot request is not required if a project submits a request prior to MPP application submission.

TABLE 5-1: APPLICATION PACKAGE REQUIREMENTS

5.1.1 Application Submittal

NYSERDA uses an online application submittal system called CRIS (Comprehensive Residential Information System). Providers receive a CRIS login and password upon entering MPP and attending a mandatory Provider Orientation.

5.1.2 Terms and Conditions

Providers are required to keep an original signed copy of the Terms and Conditions for seven years for each project. Signed originals need not be sent to NYSERDA, but Providers must keep them on file.

5.2 Energy Use Baseline

Projects participating in the Comprehensive Option must also apply to NYSERDA's Energy Use Snapshot service. Information from the report generated by NYSERDA's Energy Use Snapshot service must be used as a basis for energy savings calculations in the SAV-IT. A new Energy Use Snapshot request is not required if a project submitted a request prior to MPP and the baseline energy use that was established was within two years of Application Approval. Refer to the Energy Use Snapshot service section on the NYSERDA website for more information.

5.3 Scoping Session

Upon application acceptance, the project Case Manager will schedule a Scoping Session with the Participant and Provider. The Scoping Session may be either in-person meetings or conference calls. The intent of the Scoping Session is to establish Participant interest, identify likely energy efficiency measures, review the Program's requirements and responsibilities, and determine sources of potential funding.

Knowledgeable representatives of both the Provider and Participant are required to attend the Scoping Session.

5.4 Application Approval

Upon completion of a successful Scoping Session, NYSERDA issues an Application Approval to the Provider and Participant. The Application Approval is an email that contains the Incentive Award letter and Terms & Conditions as attachments. Projects that proceed with development of the Savings Verification and Information Tool prior to receipt of NYSERDA's Application Approval do so at their own risk.

6 STAGE 1 – BUILDING ANALYSIS & SAVINGS VERIFICATION AND INFORMATION TOOL (SAV-IT)

6.1 Overview

Upon Application Approval, the Provider will work with the Participant to complete the Stage 1 submittal, including the SAV-IT. The SAV-IT is a spreadsheet workbook that serves as the primary vehicle for providing detailed information about the project. All projects are required to use the SAV-IT. It may not be used as a means of cost or savings estimation. It must only be used as a place for Providers to record their outside custom energy savings calculations.

The SAV-IT is located on the Provider Portal. Providers should always use a new spreadsheet from the Provider Portal for each new project. The development process consists of:

- Completing a comprehensive building assessment.
- Calculating the proposed energy savings for each improvement.
- Completing the SAV-IT spreadsheet.
- Reviewing proposed scope of work with Participant.
- Finalizing all required submittal documentation and submit it to NYSERDA.

The complete SAV-IT will summarize the results of a comprehensive building assessment and represents the work scope that the Participant is willing to undertake.

A building assessment is a necessary first step, but is only one component of the SAV-IT. After the building assessment is complete, a work scope is developed that incorporates the Participant's financial and contracting abilities. These post-audit components of the SAV-IT are critically important and must be developed in close consultation with the Participant to ensure that the project moves through to construction.

Most importantly, the SAV-IT helps to educate both the Participant and NYSERDA. It also standardizes information, data, and documentation across the entire Program and from Provider to Provider.

The SAV-IT components are:

- Energy use baseline (provided by NYSERDA).
- Existing and post-retrofit building energy use.
- Existing conditions.
- Complete descriptions of all improvements to be installed.
- Cost effectiveness calculations.
- Quality control analysis of all inputs to the SAV-IT.

6.2 Auditing Requirements

This section describes the requirements for completing a comprehensive building assessment of a Comprehensive Option project. The requirements in this section must be followed for the SAV-IT to be approved.

The comprehensive building assessment(s) is (are) to be conducted or supervised by a certified energy professional (AEE CEM, AEE CEA, or BPI MFBA) and be conducted in accordance with the certification's standards. Any instrumented testing must use equipment that is built for the tolerances required and is accurate and verified in calibration.

The Provider may conduct the audit directly or use a subcontractor to perform the audit on the Provider firm's behalf. All requirements outlined in this section must be adhered to by Providers and their subcontractors. It is the Provider's responsibility to oversee their subcontractors and ensure their compliance with all Program rules.

6.2.1 Documentation and data entry

All building information collected via on-site observation, surveys, and performance testing, must be documented and serve as a reference for data entry into an energy analysis tool. It is recommended that the auditor who performs the on-site assessment be responsible for entering building data into the analysis tool, as much of the data entry requires interpretation of occupant/management responses to queries, visual indicators of systems performance, and analytical performance testing. As an example, the overall efficiency of the distribution system is based on occupant comfort, system design and controls, insulation levels, and system leakage. In cases where field staff and modelers are distinct functions, it is important for the field auditor to take detailed notes so that this interpretative information can be transferred.

Photo documentation is a required part of Stage 1 documentation and must consist of a representative sample of the existing conditions of the project. It is important to include photo documentation of existing conditions that will be updated through the scope of work or that diverge from what would be expected in a normal building. As an example, if a baseline assumption of a building model shows a very high infiltration rate that will be reduced with air sealing, a photo is required to document the source of such high baseline infiltration.

6.3 Work Scope Development

The scope of work, as presented in the SAV-IT, should consist of energy savings measures. Geothermal systems and on-site generation improvements (cogeneration, photovoltaics, wind, and submetering systems) may contribute to the 20% energy reduction target. Measures must meet all Program rules and requirements to be eligible for incentives. The recommended scope of work should be developed in consultation with the Participant and should meet the owner's financial and implementation goals for the property.

6.3.1 Utility Cost Analysis

Providers are required to provide energy costs for the purposes of calculating the annual cost savings of the proposed measures. When reporting energy cost, the Provider should use a blended rate analysis in the SAV-IT.

6.3.2 Cost Estimation

The projected cost of installing measures relies on estimates that are based on previous experience and knowledge of current pricing of building materials, equipment and labor. Although there are likely other costs associated with installing measures, these can usually be aggregated into a simple percent increase above the estimated cost of materials and labor. The Provider Portal contains Tech Tips with guidance and best practices for construction cost estimating.

6.3.3 Health and Safety Measures

The Program intends to ensure that energy-related health and safety measures are addressed, even if they do not lead to fuel, electricity, or monetary savings. Where health and safety issues are identified through the building assessment process, the Provider has an obligation to inform the Participant and to encourage them to address these issues prior to the completion of the specified work scope. Special attention should be paid to situations where building code violations are uncovered.

Health and safety improvements with no associated energy savings may not be included in the MPP scope of work.

6.3.4 Operation and Maintenance (O&M) Savings

Cost savings associated with reduced O&M expense can be difficult to predict and quantify and should be claimed only in cases where solid documentation can be provided to substantiate the savings estimate.

An example might involve the removal of a central boiler plant and replacement with building-based boilers. If the central plant involved underground distribution of heated water or steam and the underground piping was in a deteriorated condition, annual repairs could be regular and expensive. In such a case, it may be reasonable to quantify the savings associated with no longer needing to maintain the underground distribution piping based on historical costs for such maintenance and repair.

If O&M savings are claimed, calculations and documentation must be included in the SAV-IT as an Outside Calculation.

6.3.5 Minimum Performance Standards

All recommended improvements shall comply with the Minimum Performance Standards where applicable.

The Provider is responsible for ensuring that all performance assumptions made in the comprehensive energy assessment are translated into bid and construction documents. A work scope should contain performance specifications or references to the specifications for the materials and equipment to be

installed. Additionally, the work scope should include enough information about installation standards to ensure that competitive bidding is fair in scope and pricing and that potential contractors understand the importance of performance contracting.

The Minimum Performance Standards for the Comprehensive Option (version 8.0) are included in the following pages.

Multifamily Performance Program Version 8

Minimum Performance Standards for Existing Buildings - Comprehensive Option

These Minimum Performance Standards establish the measure-by-measure parameters which apply only to those building components or systems for which recommended improvements are being proposed. For projects where one of the specific components listed below is recommended within the proposed energy efficiency work scope, this component must at least meet the indicated performance requirements.

These Minimum Performance Standards are also intended:

- 1) To ensure that buildings are built to the requirements of specific, applicable codes.
- 2) To provide a reference for Providers to describe to owners what will be required to participate in MPP.
- 3) To promote the installation of ENERGY STAR appliances, lighting, and equipment where available.

*All references to ECCC NYS are in reference to the Energy Conservation Construction Code of New York State effective January 1, 2015.

TABLE 6-1: MINIMUM PERFORMANCE STANDARDS FOR EXISTING BUILDINGS

<u>RECOMMENDED MEASURE</u>	<u>MINIMUM PERFORMANCE STANDARD</u>
	Recommended measures shall AT LEAST meet each of these requirements for each indicated measure or system, including BPI, Inc. Technical Standards for MFBA or applicable Local, State, or National Codes, whichever is more stringent. For building components or systems not addressed in this document, the recommended measure must meet or exceed applicable Local, State, or National code.
APPLIANCES	Appliances shall be ENERGY STAR labeled when available. Refrigerators and air conditioning units must be removed and decommissioned in compliance with EPA Clean Air Act and other relevant NY State regulations.
DOMESTIC HOT WATER	
Domestic Hot Water Boiler System	All hot water piping in mechanical room and accessible piping in unconditioned spaces shall be insulated to ECCC NYS 404.5.
Domestic Hot Water Boiler System	Replacement domestic hot water heating plant(s) shall be ENERGY STAR labeled, where applicable. For all other systems where the ENERGY STAR label is not available, the specified heating plant(s) shall have a minimum rated efficiency no less than that required by the ECCC NYS 404.2.
Domestic Hot Water Temperature	The temperature of the stored DHW shall be just sufficient to deliver DHW to the apartments when measured at the tap to within a temperature range 110°-125° F and as required by ECCC NYS 404.3.
ENEVELOPE	
Build Envelope Sealing	Projects with air sealing shall consider and evaluate infiltration reduction via stack effect, wind effect, and bypasses when applying product.
Windows & Exterior Doors	Specified windows & doors shall be ENERGY STAR labeled where available, and comply with ECCC NYS 402.3.

MPP Comprehensive Option Guidelines

HEATING & COOLING	
Boiler & Furnace Systems	Atmospherically vented gas furnaces and boilers shall not be specified. Steam piping, cooling system piping, and all hot water piping in mechanical room and accessible piping in unconditioned spaces shall be insulated to ECCC NYS 403.2.8
Heating Systems Efficiency	Replacement heating plants(s) shall be ENERGY STAR labeled, where applicable. Boiler systems (hot water and steam) larger than 300,000 Btuh input shall have a thermal efficiency of $\geq 80\%$. Exception: steam systems with input capacities between 300,000 Btuh and 2.5 MBtuh shall have a thermal efficiency of $\geq 79\%$. For all other systems where the ENERGY STAR label is not available, the specified heating plant(s) shall have a minimum rated efficiency no less than that required by the ECCC NYS 403.2.3 Tables 1-7.
Steady State Efficiency Testing	Replacement condensing boilers shall provide at a minimum steady state efficiency testing for high and low fire. For replacement condensing boiler(s), provide system in optimal performance (per the design) or operating conditions to minimize return water temperature.
Condensing Boilers	Condensing boiler systems shall be designed, installed and operated in a manner to minimize return water temperature. Condensing furnaces shall be installed with electronically commutated motors (ECMs).
Owner's Manual	When replacing HVAC systems & equipment provide an Owner's Manual that contains (at a minimum) the following: Condensing boilers shall provide a minimum of efficiency testing for high and low fire; As built equipment and control cut sheets; Statement of the system's Sequence of Operations.
Heat Pumps	Equipment shall be ENERGY STAR labeled where appropriate for size of equipment. Where sizing does not allow ENERGY STAR labeling, equipment shall comply with ECCC NYS minimum efficiencies.
Heating System Combustion Air Intake	When replacing heating appliance/plant, provide a motorized damper to the outside "free air" louver that is wired to the burner ignition OR ensure mechanical room (unconditioned space) is compartmentalized from rest of building/conditioned spaces.
Distribution System Replacements	When replacing existing distribution systems or installing new systems, terminal heating & cooling distribution equipment serving an apartment shall be controlled by a thermostat(s) located within the same apartment as per ECCC NYS 403.2.4. Such terminal heating & cooling distribution equipment must be separated from the riser or distribution loop by a control valve, or terminal distribution pump, so that heated or cooled fluid is not delivered to the apartment distribution equipment when there is no call from the apartment thermostats.
Cooling- Room Air Conditioners	Room air conditioners shall be ENERGY STAR labeled (for all model sizes covered by the ENERGY STAR label). Air conditioning units must be removed and decommissioned in compliance with EPA Clean Air Act and other relevant NY State regulations (ECCC NYS 403.2.1 Table 1).
Packaged Terminal Air Conditioners	Equipment shall be ENERGY STAR labeled where appropriate of size of equipment. Where sizing does not allow ENERGY STAR labeling, equipment shall comply with ECCC NYS 403.2.3 Table 3 minimum efficiencies.
Cooling-Chillers	Equipment shall meet the requirements of ECCC NYS 403.2.3 Table 7.

MPP Comprehensive Option Guidelines

LIGHTING	
Lighting - General	Removed fluorescent lamps and ballasts must be disposed of in an environmentally sensitive manner, adhering to a relevant Local, State and National codes.
Lighting Controls	When replacing or upgrading lighting in frequently unoccupied areas, i.e. storage closets, compactor rooms, etc., provide occupancy controls when cost-effective.
Linear Fluorescent Lighting	Linear fluorescent systems shall have the following minimum efficacies: 2 foot- 75 lumens per watt 4-foot (including U-lamps)-79 lumens per watt
Compact Fluorescent Lighting	Compact fluorescent fixtures shall be ENERGY STAR labeled. Screw-in compact fluorescent lamps are not eligible for NYSERDA funding and may not be included in project work scopes.
LED Lighting (general illumination)	Solid State Lighting products must be listed by either ENERGY STAR® or Design Lights™ Consortium's Qualified Projects List (DLCQPL). If neither ENERGY STAR® nor Design Lights™ certifies the type of solid state lighting installed, the following must be submitted: LM-79 test data (for entire luminaire); LM-80 test data (for the LED device or module package); and an unconditional 3-year manufacturer's warranty.
Emergency Lighting	All exit signs shall be specified LED (not to exceed 5W per face) or photo luminescent and shall conform to local building code fixtures located above stairwell doors and other forms of egress shall contain a battery back-up feature.
Outdoor Security & Decorative Lighting	Exterior lighting shall have an efficacy of greater than or equal to 60 lumens/watt per ECCC NYS 405.6.1. Fixtures must include automatic switching on timers or photocell controls except fixtures intended for 24-hour operation, required for security, or located on apartment balconies.
MOTORS	All replacement or newly installed three phase motors 1 HP or larger shall be NEMA Premium efficiency or greater. Motors that are packaged as an integral component of mechanical equipment are exempt from this requirement.
WATER CONSUMPTION	Common area and in-unit faucets and showerheads must not exceed 2.0 gallons per minute (GPM).

6.4 Quality Control

NYSERDA conducts quality control reviews of all submittals. The SAV-IT contains quality control flags that identifies measures falling outside the range of typical measures costs and typical measure savings based on previous multifamily installations and industry standards. NYSERDA reserves the right the request further information about savings calculations and measure costs. Final approval of the SAV-IT is at the discretion of the reviewer.

Providers are subject to the Terms and Conditions of the Provider Application including the Provider Status Designation policy. Providers must conduct a comprehensive review of their deliverables and are responsible for the accuracy, timeliness, and completeness of submittals. Providers who repeatedly provide false, inaccurate, or incomplete information to MPP will be subject to the appropriate disciplinary action as defined in the Provider Status Designation Policy.

6.5 Stage 1 Approval

6.5.1 Stage 1 Deliverables

Stage 1 submittals are due within 90 calendar days following Application Approval after the Scoping Session. The Participant and Provider are notified of this date when the Application Approval is issued.

Required deliverables include:

- Savings Verification and Information Tool (SAV-IT)
- Provider Contract
- Photographs

Incomplete submittals will be returned without review.

The Filename Convention must be followed. File submissions that do not adhere to the Filename Convention will be returned to the Provider without review. With the volume of projects participating in MPP and documents required, strict adherence to the Filename Convention is required. It allows NYSERDA to manage document revisions and maintain accurate project files. Providers are urged to develop a similar requirement internally that aligns with the requirements set forth for this Program.

Document	Filename Convention	Example
SAV-IT	Project Name - SAVIT_rev0.xls	NY Apts SAVIT_rev0.PDF
Provider-Participant Contract	Project Name - Provider Contract.PDF	NY Apts - Provider Contract.pdf
Photographs (using Template)	Project Name - Photos.pdf	NY Apts – Photos.pdf

TABLE 6-2: STAGE 1 DELIVERABLES

Upon resubmission of project documents, the next revision number must be applied to all deliverables (e.g., Rev0 becomes Rev1). See Appendix A for a complete list of deliverables.

6.5.2 Stage 1 Approval

The following procedure explains each step of the Savings Verification and Information Tool approval process. **The SAV-IT must be approved before the project can continue to construction.**

1. The Provider submits Stage 1 Deliverables and all associated files to NYSERDA for review. Email all project submittals to **MultifamilyPrograms@nyserda.ny.gov**.
2. NYSERDA completes a technical and financial review with three options for response:
 - a. Approved as Noted: Stage 1 Deliverables are approved as proposed.
 - b. Revise and Submit: The project is not ready to be approved as proposed. Comments are returned to the Provider and Participant, with direction to resubmit. The revised SAV-IT must be submitted within 30 days.
 - If the resubmittal meets Program requirements and addresses comments, the SAV-IT is approved.
 - If the resubmittal does not present an approvable project as directed in the review comments, it will be returned to the Provider for correction and the Provider's performance file will be noted.
 - c. Rejected: Deliverables contain serious deficiencies and do not meet Program requirements.
 - NYSERDA will notify the Participant and Provider to seek mutually acceptable terms for a fundable project. This discussion occurs primarily with the Participant, with input from the Provider. NYSERDA may choose to allow resubmittal of the Stage 1 deliverables as a result of this discussion.
 - If no agreement is reached, the project is rejected and its participation in MPP is terminated.
3. Once the Stage 1 deliverables are approved, NYSERDA issues a Notice to Proceed to Construction. The Notice to Proceed will include an email that the SAV-IT has been received and approved and that the project may now proceed to installation of the improvements detailed in the SAV-IT. An additional email will be sent that includes a Supplemental Incentive Award letter specifying the project's maximum performance payment.

7 STAGES 2 & 3 | CONSTRUCTION PHASE

Stage 2 approval is an optional incentive for projects with construction managers. Stage 3 approval is required for all projects.

7.1 Provider Responsibilities

Energy saving measures must be implemented per the approved SAV-IT. Providers must remain engaged with the project through the construction phase. Providers are expected to maintain a high level of interaction with the Participant during the development of the scope and construction to ensure that the scope of work is installed on-schedule and in accordance with the SAV-IT.

Providers should work with Participants and design engineers to develop specifications and contracts that address the documentation needs of MPP. For example, a contract for insulation contractors may include a requirement for photo-documentation at various stages of installation.

Providers should review equipment submittals from installing contractors before construction begins to ensure that the installed work meets the intent of the SAV-IT. Submittals may consist of equipment cut sheets, product literature, etc., specifying make/model and energy-related characteristics (for example, kWh/year for refrigerators). Ideally, the submittal should also reference the SAV-IT requirements for the equipment and compare to the proposed equipment to be installed.

7.2 Changes to the Scope of Work

Any changes in the approved work scope that affect the overall project savings or the measures identified in the approved SAV-IT must be communicated to NYSERDA.

Scope Changes may occur at any time after the approval of the SAV-IT. The revised scope of work must meet all rules and requirements for the Comprehensive Option, including energy savings targets. If a change to the scope of work results in a project not meeting all the rules and requirements, the project will be terminated and any unpaid incentives shall be forfeited.

Participant cannot start or continue work on the revised measure(s) until they receive approval from NYSERDA.

7.2.1 Scope Change Document Submission

The following documents are required for consideration of scope changes:

1. Scope Change Cover Sheet
2. Revised SAV-IT

The following Filename Convention must be followed:

Document	Filename Convention	Example
Scope Change Cover Sheet	Project Name – Scope Change #.pdf	NY Apts – Scope Change 1.pdf
SAV-IT	Project Name – SAVIT_rev#.xls	NY Apts – SAVIT_rev3.xls

TABLE 7-1: SCOPE CHANGE DELIVERABLES

7.3 Optional Stage 2: Construction Management Incentive and 50% Complete

Projects are eligible to receive a portion of the project's total construction incentive prior to construction completion. The Construction Management incentive is available to projects that have a construction manager overseeing the project and have completed 50% of construction.

7.3.1 50% Complete

Fifty percent (50%) Complete is defined as the point at which 50% of the energy savings as recorded in the SAV-IT are installed and saving energy. Measures that are designated as Previously Installed as defined in the rules for the MPP Comprehensive Option may not contribute to the required 50% of installed energy savings measures to qualify for this inspection.

7.3.2 Construction Manager

Construction Manager Services must adhere to the American Institute of Architects (AIA) definition of a Construction Manager, who "is responsible for coordinating the work of multiple prime construction contracts and for overseeing quality control." There are two options for complying with the requirements of the Stage 2 incentive.

Option 1: AIA Construction Manager Contract

Projects must provide a copy of a signed contract between the building owner and a Construction Manager whose scope of work is defined in an American Institute of Architects (AIA) Standard Form of Agreement between Owner and Construction Manager as Advisor.

Option 2: Other Construction Manager Contract

Projects must provide a copy of a contract between the building owner and a Construction Manager whose scope of work includes, at a minimum, the following:

1. Review SOW documents and assist in determining contractor requirements for each measure
2. Create Construction Management Plan
 - a. Preliminary evaluation of schedule and budget
 - b. Cost estimations
 - c. Recommendation for project delivery method
 - d. Contractor(s) scope of work
3. Update Construction Management Plan periodically, including schedule updates
4. Prepare and receive bid analysis and make recommendations to the owner for the awarding of contracts
5. As needed, conduct periodic inspections and construction meetings and provide minutes
6. Coordinate activities among contractors and owner in accordance to outlined schedule, including sequencing of operations, allocation of labor and materials, etc.
7. Obtain building permits and special permits for improvements, except those required to be obtained directly by contractors
8. Monitor safety among the contractors
9. When possible, coordinate ordering and delivery of materials

10. Schedule and conduct meetings to discuss procedures, progress, schedule or work
11. Schedule testing and inspections as required
12. Confirm with owner the progress of work in accordance SOW to determine when/if contactors should receive payment
13. Monitor that all work is being done in accordance to SOW outlined in SAV-IT and with Energy Efficiency in mind
14. The Construction Manager shall record the progress of the project. On a monthly, or otherwise as agreed to by the owner, the Construction Manager will provide progress reports.
 - a. Work complete for the project
 - b. Project schedule status
 - c. Remaining and outstanding items
 - d. Request for changes
 - e. Test and inspection reports
 - f. Status of nonconforming and rejected work

7.3.3 Stage 2 Deliverables

Stage 2 deliverables must be submitted to NYSERDA after the Provider has verified completion of energy improvements, in accordance with the SAV-IT, and a Construction Manager is hired. The following deliverables are required for approval of the Stage 2 milestone:

- 50% Complete Verification Workbook
- Signed Construction Manager Contract that meets requirements in Section 7.3.2

The Filename Convention must be followed:

Document	Filename Convention	Example
50% Complete Verification	Project Name – 50% Complete Verification.xls	NY Apts 50% Complete Verification_rev0.xls
Signed Construction Manager Contract	Project Name – Construction Manager Contract.pdf	NY Apts – Construction Manager Contract.pdf

TABLE 7-2: STAGE 2 DELIEVERABLES

7.3.4 Stage 2 Approval

The following procedure explains each step of the Construction Manager and 50% Complete approval process.

1. The Provider submits Stage 2 Deliverables to NYSERDA for review. Email all project submittals to **MultifamilyPrograms@nyserda.ny.gov**.
2. NYSERDA reviews the documents
 - a. If sufficient, NYSERDA approves the Stage 2 incentive and begins the payment process.
 - b. If incomplete, NYSERDA contacts the Provider for more information until the milestone can be approved.

7.4 Stage 3: 100% Construction Complete

Stage 3 is 100% construction complete, meaning that all of the energy improvements are installed and functional (or capable of functioning) to the intent of the measures described in the SAV-IT. An improvement is considered installed when it adheres to the American Institute of Architects (AIA) definition of Substantial Completion, which is the “stage in the progress of the Work when the Work or designated portion thereof is sufficiently complete in accordance with Contract Documents so that the Owner can occupy or utilize the Work for its intended use.” For energy savings measures, the “intended use” is to generate the proposed level of energy savings. All measures must be installed per these Guidelines, including the Minimum Performance Standards, and as outlined by the approved SAV-IT. There is no verification of savings (i.e. utility bill analysis) associated with 100% Completion.

7.4.1 Stage 3 Deliverables

Stage 3 deliverables must be submitted to NYSERDA after the Provider has verified completion of energy improvements, in accordance with the intent of the SAV-IT. Incomplete submissions will be returned to the Provider without review, and incentives will not be paid by NYSERDA. Refer to Section 8 for site inspection protocols, required measure documentation, and Provider responsibilities.

The following deliverables are required for approval of the Stage 3:

- Inspection Request workbook
- Photo Documentation
- Common Area Data Release Authorization Forms (DRAFTs)
- Additional measure documentation as required by Section 8.4

The Filename Convention must be followed.

Document	File Name Convention	Example
Inspection Request	Project Name – 100% Inspection.xls	NY Apts – 100% Inspection_rev0.xls
Photo Documentation	Project Name – Photos _100%.pdf	NY Apts – Photos_100%.pdf
Measure Documentation	Project Name - (per Section 8.4)	NY Apts – Boiler cut sheets.pdf
Common Area DRAFTs	Project Name – DRAFTs	NY Apts - DRAFTs

TABLE 7-3: STAGE 3 DELIEVERABLES

7.4.2 Stage 3 Approval

The following procedure explains each step of the 100% Construction Complete approval process.

1. The Provider submits Stage 3 Deliverables and all associated files to NYSERDA for review. Email all project submittals to MultifamilyPrograms@nyserda.ny.gov.
2. NYSERDA reviews the documents and, if complete, schedules a site inspection. On a case-by-case basis, if the Provider submits quality inspection documentation, NYSERDA will waive the 100% field inspection and will instead conduct a desk review. The building owner will always have the option of requesting a final field inspection if they choose.
3. The site inspection or desk review occurs.

4. NYSDERDA reviews results of the inspection and determines if the project achieved the milestone.
5. If achieved, NYSDERA approves the Stage 3 incentive and begins the payment process.

8 SITE INSPECTION

8.1 Provider Responsibilities

The Provider is responsible for confirming that work is installed according to the scope of work described in the approved SAV-IT. Providers are required to verify the installation of measures with one of the following:

- Performing an on-site inspection of installed measures.

OR

- Obtaining a *Statement of Substantial Completion* from the installation contractor or other qualified representative.

Section 8.4 describes the specific Provider requirements, based on measure type, for the *Statement of Substantial Completion* and the on-site inspection documentation. A *Statement of Substantial Completion* or approved proxy may be submitted to establish completion of the work.

A cut sheet must be provided for each product installed as part of the scope of work. At a minimum, the cut sheet must show the manufacturer, model number, and any relevant energy rating information. The specific model installed must be clearly marked on the cut sheet.

8.2 System Testing

System testing can be performed by the installing contractor, the Provider, the Participant (i.e. owner), or third parties. The individual conducting the specific testing shall be appropriately qualified and trained in the test or have proven experience and expertise. If completion is documented by someone other than the Provider, the Provider shall submit a *Statement of Substantial Completion* signed by the individual who performed the system testing.

8.3 Statement of Substantial Completion

The installation contractor or other qualified representative must complete the Statement of Substantial Completion. When submitting a signed Statement of Substantial Completion, the Provider is still responsible for performing the necessary due diligence to ensure that the Statement of Substantial Completion is accurate and complete. The exact steps taken to gain this assurance will depend on the measure installed and the Provider's experience working with the installation contractor. Steps for due diligence can include, but is not limited to, requesting to see contractor field notes and checklists, random sampling to compare the statement to what is seen on site during an inspection, asking the installation contractor for their quality control techniques.

A signed Statement of Substantial Completion is defined as a written and signed statement from the installing contractor, the owner's general contractor, the commissioning agent, or another third-party inspector. The Statement of Substantial Completion must confirm that the specified measures are fully installed and fulfilling its intended use. For the purpose of energy efficiency measures, the "intended use" is to generate the proposed level of energy savings.

Unless based on industry-standard document such as AIA's G702, this Statement must be on the contractor's letterhead and must include all of the information described below and must cover 100% of the installation.

1. Information Required in the *Statement of Substantial Completion*

- Statement must be made on Contractor/agent's letterhead
- Statement must contain the name and address of the project
- Statement must contain the name and contact information of the individual completing the statement
- Statement must confirm that all fixtures and equipment have been installed and tested to demonstrate confirmation with all construction specifications
- Individual's signature and date signed

In some cases, there may be documents already in use by the contractors or Participant that satisfy some or all of the requirements of the signed Statement of Substantial Completion. In such cases, it is sufficient to submit a copy of such documents in lieu of a separate Statement of Substantial Completion. If there are specific submission requirements for the Statement of Substantial Completion that are not included in the proxy documents, such as are listed in the measure-specific documentation requirements elsewhere in this document, then additional documentation should be submitted with the proxy documents as attachments.

2. Approved Proxy Documents for *Statement of Substantial Completion*

- AIA Documents G702 (Application and Certification for Payment) and G703 (Application and Certification for Payment Continuation Sheet)

The Provider should contact the project's Case Manager if there is documentation used for a specific project which the Provider believes satisfy some or all of the requirements for a Statement of Substantial Completion, but is not currently listed as an eligible proxy.

8.4 Inspection Request Documentation Requirements

APPLIANCES	ENERGY STAR® Appliances
Equipment Covered	Refrigerators, dishwashers, and compactors, etc.
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Confirm that the appliance is ENERGY STAR® labeled. If a label is not present, the following website can be used to check for an ENERGY STAR® rating for a particular make/model: http://www.energystar.gov/index.cfm?c=appliances.pr_appliances • Compare the consumption data of the appliances to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from installing contractor or commissioning agent may reduce the Provider sampling requirements provided it meets at least the stated documentation requirements for 100% of the installed appliances. • Provider should be satisfied that the signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record make, model number, and count of all appliances. • Record location (for example, an apartment number) and serial number for each appliance inspected. • Photograph one representative appliance and ENERGY STAR® label, if visible, of each type of appliance being inspected. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling Requirements	<ul style="list-style-type: none"> • Inspect 10% of appliances of each type and size, but no fewer than five (5) appliances of each type. Sample must be random and statistically representative. • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Record make, model number, and count of inspected appliances. • Record location (for example, an apartment number) and serial number for each appliance inspected. • Photograph one representative appliance and ENERGY STAR® label, if visible, of each type of appliance inspected. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

LIGHTING	Common Area, Apartment and Exterior Lighting
Equipment Covered	Common Area (hallway, stairwells, lobby, etc.), in-unit, exterior decorative and security lighting. LED (solid state) lighting is covered in a separate section.
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the quantities and wattages of the lamps and fixtures to the assumptions made in the SAV-IT and note conformance/deviation. • For retrofitted fixtures, due diligence should include confirmation of electronic ballasts using ballast checker.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from lighting contractor or commissioning agent may reduce the Provider sampling requirements provided it meets at least the stated documentation requirements for 100% of the installed lighting. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record quantities, locations, types, and wattages for all lamps and fixtures. • Record make/model information on all in-unit lighting to confirm ENERGY STAR® label. • Photograph one sample of each fixture type (with ENERGY STAR® label affixed, if visible). • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling Requirements	<ul style="list-style-type: none"> • Inspect all unique common areas (basements, lobbies) and a representative 20% sample (minimum five (5)) of similar, or repetitive, areas (stairwells and stairwell landings, corridors, trash chute rooms, etc.). • Inspect 10% of apartments to include, at a minimum, one representative apartment from each line. A minimum of five (5) apartments must be visited. • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Record quantities, locations, types, and wattages for inspected lamps and fixtures. • Record make/model information on all inspected in-unit lighting to confirm ENERGY STAR® label. • Photograph one sample of each fixture type inspected (with ENERGY STAR® label affixed, if visible). • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

LIGHTING	Exit Signs and Emergency Lighting
Equipment Covered	Exit signs and emergency lighting
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the quantities and wattages of the lamps and fixtures to the assumptions made in the SAV-IT and note conformance/deviation. • Due diligence should include opening fixtures to confirm lamp type and wattage. • Due diligence should include confirming emergency power provision, when applicable, by turning off power or using test buttons on equipment.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from lighting contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed lighting. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record quantities, locations, make/model, types, and wattages of all signs and fixtures. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling Requirements	<ul style="list-style-type: none"> • Inspect all unique common areas (basements, lobbies) and a representative 20% sample (minimum five of similar, or repetitive, areas (stairwells and stairwell landings, corridors, trash chute rooms, etc.). • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Record quantities, locations, make/model, types, and wattages of inspected signs and fixtures. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

LIGHTING	LED Lighting
Equipment Covered	LED (solid state) lamps and fixtures
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the quantities and wattages of the lamps and fixtures to the assumptions made in the SAV-IT and note conformance/deviation. • Due diligence should include opening fixtures to confirm lamp type and wattage. • Due diligence should include confirming emergency power provision, when applicable, by turning off power or using test buttons on equipment.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from lighting contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed lighting. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record quantities, locations, make/model, types, and wattages of all lamps and fixtures. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet. • One of the following: <ol style="list-style-type: none"> 1. Proof of ENERGY STAR® listing; or 2. Proof of DesignLights™ Consortium’s Qualified Products Listing; or 3. LM79 test results for the product from a certified independent test laboratory; LM80 test results for the SSL product or LED module package; AND unconditional three-year warranty on product (from either manufacturer or installer).
Option 2: Provider Sampling	
Provider Sampling Requirements	<ul style="list-style-type: none"> • Inspect all unique common areas (basements, lobbies) and a representative 20% sample (minimum five (5)) of similar, or repetitive, areas (stairwells and stairwell landings, corridors, trash chute rooms, etc.). • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Record quantities, locations, make/model, types, and wattages of all lamps and fixtures. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet. • One of the following: <ol style="list-style-type: none"> 1. Proof of ENERGY STAR® listing; or 2. Proof of DesignLights™ Consortium’s Qualified Products Listing; or 3. LM79 test results for the product from a certified independent test laboratory; LM80 test results for the SSL product or LED module package; AND unconditional three-year warranty on product (from either manufacturer or installer).

LIGHTING	Lighting Controls
Equipment Covered	Occupancy sensors, timers and, photocell controls
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the quantities, types and, settings of the lighting controls to the assumptions made in the SAV-IT and note conformance/deviation. • Due diligence should include confirming that each control type is operable. • For occupancy sensors, step in and out of the zone and confirm that lights switch off within a time period equivalent to the specified ON time. • For timers, set timer to current time and confirm control of fixture. • For photocells, cover or blackout photocell and confirm control of fixture • For switches and dimmers, operate control to confirm control of fixture. • For day lighting controls, dim or blackout location to observe change in fixture light level.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from lighting contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed controls. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section. • The Statement of Substantial Completion should include a description of tests, calibrations, and lighting control settings.
Required Attachments	<ul style="list-style-type: none"> • Record location, make/model, and type of each lighting control. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • Inspect all unique common areas (basements, lobbies) and a representative 20% sample (minimum five (5)) of similar, or repetitive, areas (stairwells and stairwell landings, corridors, trash chute rooms, etc.). <p>Inspect 10% of apartments to include, at a minimum, one representative apartment from each line. A minimum of five (5) apartments must be visited. Problems with installations found during random inspections will require an expanded sample to determine extent of problem.</p>
Required Attachments	<ul style="list-style-type: none"> • Record location, make/model, and type of each inspected lighting control. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

ENVELOPE	Roof and Cavity Insulation
Equipment Covered	Roof insulation, attic insulation and, cavity insulation
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the insulation type, thickness, and R-value to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from insulation/air-sealing contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed insulation. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record insulation type, thickness, and R-value. • Photograph depth of blown insulation using tape measure or other depth measurement, minimum one photograph per attic. • Photograph roof deck insulation before it is covered. • Photograph cavity insulation before it is covered. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • Each unique roof or cavity assembly shall be inspected. For example, if unique sections of the building are constructed differently, all distinct areas must be inspected. If insulation specifications are different for different areas, each different specification shall be inspected. • Sampling may be used to inspect roof or cavity assemblies that are consistent throughout large sections of the building. At each stage of the inspection process, a minimum of 20% of total roof and cavity area must be inspected for each unique roof and cavity type. Problems with installations found during random inspections will require an expanded sample. • An interim inspection (prior to area being enclosed) is required when insulated area will be inaccessible after completion.
Required Attachments	<ul style="list-style-type: none"> • Record insulation type, thickness and, R-value for each area inspected. • Photograph depth of blown insulation using tape measure or other depth measurement, minimum one photograph per inspected attic. • Photograph roof deck insulation before it is covered. • Photograph cavity insulation before it is covered. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

ENVELOPE	Windows
Equipment Covered	Exterior windows, sliding glass doors
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the energy performance specifications and actual installation to the assumptions made in the SAV-IT and note conformance/deviation. • Due diligence should include testing operating sashes, screens, and hardware for a tight fit at contact points and weather stripping for smooth operation and weather-tight closure. • Due diligence should include confirming proper fit and effective connection to building envelope weather and air barriers.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from installing contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed windows. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record quantities and locations of all new windows. • Record energy performance specifications (window type, frame type, U-value, gas fill, SHGC, low-e type, and location) for all windows. • Provide copies of NFRC or other relevant rating agency's label(s). For large jobs, provide certificates from NFRC or other relevant rating agency, which should be on file. • Provide copies of low-e glass from manufacturer's cut sheets. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • At least 10% of new windows (minimum 10) shall be inspected and shall include, at a minimum, one of each different type of window installation based on different window types (fixed, double hung, etc.) and different energy performance specifications (e.g. if low-e glass is specified on part of the building but not all). • The sample set shall include, at a minimum, the inspection of new windows in one representative apartment from each line. • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.

Required Attachments	<ul style="list-style-type: none">• Record quantities and locations of new windows inspected.• Record energy performance specifications (window type, frame type, U-value, gas fill, SHGC, low-e type, and location) for inspected windows.• Provide copies of NFRC or other relevant rating agency's label(s). For large jobs, provide certificates from NFRC or other relevant rating agency, which should be on file.• Provide copies of low-e glass from manufacturer's cut-sheets.• Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
-----------------------------	---

ENVELOPE	Exterior Doors
Equipment Covered	Exterior doors and interior doors opening onto common areas
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the energy performance specifications and actual installation to the assumptions made in the SAV-IT and note conformance/deviation. • Due diligence should include inspecting for proper operation, fit, and weather stripping.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from installing contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed doors. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record quantities and locations of all new doors. • Record make/model, type, and U-value for all new doors. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • Verify proper installation of 50% of all new common area exterior doors. • Inspect 10% of new apartment exterior doors (minimum of 5) where garden style apartments exist. Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Record quantities and locations of inspected doors. • Record make/model, type, and U-value for inspected doors. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

ENVELOPE	Air Sealing
Equipment Covered	Weatherstripping, caulk, thermal barriers, and stops
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Where quantitative measures of air sealing effectiveness are available, compare the actual installation to the assumptions made in the SAV-IT and note conformance/deviation. • For weather stripping of windows or doors, due diligence should include confirming that all latches, hinges, and self-closing mechanisms operate smoothly and properly and confirming that weather stripping is secured with screws.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from insulation/air-sealing contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed air sealing. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section. • Statement should explain how work was performed and what quality control mechanisms were in place. If blower doors were used, statement should list test-in and test-out blower door readings.
Required Attachments	<ul style="list-style-type: none"> • Record location and description of air sealing activities. • Record quantities and description of materials used. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • For elements that provide central services to the building (e.g. entry doors, central duct chases, utility service penetrations, etc.) a minimum 50% sample shall be inspected. • For elements that are repeated throughout the building or occur in every living unit (e.g. windows, wall/floor connections, air conditioner sleeves, etc.) a minimum 10% sample shall be inspected. A minimum of five (5) apartments must be visited. • Problems found during random inspections will require an expanded sample to determine extent of problem. • Where general in-unit air sealing was specified in the SAV-IT, the sample set shall be representative of the variety of apartment types in the building, including end/corner units and inside units; top-floor, middle-floor, bottom-floor units; and at least one unit of each size/type (studios, 1-bed, 2-bed, etc.).
Required Attachments	<ul style="list-style-type: none"> • Record location or areas inspected and description of observed evidence of air sealing activities. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

HVAC & DHW	Combustion, Steam and Hydronic Systems
Equipment Covered	Boilers and furnaces
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the energy performance specifications and actual installation to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from HVAC contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed equipment. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record make and model information on all installed equipment. • Record nameplate efficiency or measured efficiency if nameplate efficiency is not available. • Confirm all applicable operating and specification manuals are delivered to building staff. Where applicable, summarize the training performed and personnel involved. • Provide steady state efficiency testing for high and low fire. • Condensing boilers: Provide outdoor reset curves. • Hot Water Heating Systems: Measure and report supply water temperature, return water temperature, and outdoor air temperature in the shade. Record control set points. For outdoor reset controls, record design set points, and actual settings. • Steam Systems: Record system pressure and control set points. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • All primary equipment (boilers, etc.) should be inspected. • A representative sample of 10% of in-unit terminal devices (radiators, unit heaters, etc.) should be included. A minimum of five (5) apartments must be visited.
Required Attachments	<ul style="list-style-type: none"> • Collect make and model information on inspected equipment. • Record nameplate efficiency, or measured efficiency if nameplate efficiency is not available. • Confirm all applicable operating and specification manuals are delivered to building staff. Where applicable, summarize the training performed and personnel involved. • Provide steady state efficiency testing for high and low fire. • Condensing Boilers: Provide outdoor reset curves. • Hot Water Heating Systems: Measure and report supply water temperature, return water temperature, and outdoor air temperature in the shade. Record control set points. For outdoor reset controls, record design set points and actual settings. • Steam Systems: Record system pressure and control set points.

MPP Comprehensive Option Guidelines V8

	<ul style="list-style-type: none"> • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
HVAC & DHW	Cooling
Equipment Covered	Common area and apartment cooling equipment
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the energy performance specifications and actual installation to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from HVAC contractor or commissioning agent may reduce the Provider sampling requirements provided it meets at least the stated documentation requirements for 100% of the installed equipment. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record make and model information on all installed equipment • Record nameplate efficiency. • Confirm all applicable operating and specification manuals are delivered to building staff. Where applicable, summarize the training performed and personnel involved. • Cooling Systems: Refer to air conditioner test instructions. Follow instructions for 100% of installed equipment. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • All primary equipment (chillers, air handling units, etc.) should be inspected. A representative sample of 10% of in-unit terminal devices (fan coils, PTACs, room air conditioners, etc.) should be included in the process. A minimum of five (5) apartments must be visited. • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Collect make and model information on inspected equipment. • Record nameplate efficiency and efficiency proposed in the SAV-IT. • Confirm all applicable operating and specification manuals are delivered to building staff. Where applicable, summarize the training performed and personnel involved. • Cooling Systems: Refer to air conditioner test instructions. Follow instructions for all inspected equipment. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

Air Conditioner Test Instructions	
All types of air conditioners	The temperature difference between the room air temperature and the supply air temperature should be greater than 20°F. Record measurements.
Central air conditioners	<ul style="list-style-type: none"> • Check the capacity of the equipment against the design cooling load to confirm proper size. If output capacity of the installed cooling plant is more than 10% larger than the modeled design load, record the designer’s justification for over-sizing the cooling plant. • Confirm that duct seams are sealed per the energy code. • Record duct insulation material and thickness. • <u>Optional but recommended</u>: Record outside air temperature, refrigerant superheat and subcooling, and unit amps. Compare to manufacturer’s data at outside air conditions. If measurements do not match manufacturer’s data, adjust refrigerant charge and/or identify airflow obstructions. • <u>Optional but recommended</u>: Measure supply airflow to all zones. Compare to design values, and adjust to within 5%.
Room air conditioners	<ul style="list-style-type: none"> • <u>Optional but recommended</u>: Visually inspect sealing around air conditioner sleeve. No daylight should be visible from indoors. • <u>Optional but recommended</u>: Test for air leakage from outdoors: Shut outside air damper, if any; run unit on fan only (no compressor); measure outdoor air temperature in the shade, supply air temperature, and room temperature. Supply air temperature should equal room air temperature; if not, this indicates air leakage from outdoors. Record measurements.

HVAC & DHW	Ventilation and Heat Recovery
Equipment Covered	Heating, ventilation and air conditioning equipment
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the energy performance specifications and actual installation to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from HVAC contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed equipment. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record make and model information on all installed equipment. • Record nameplate efficiency, or measured efficiency if nameplate efficiency is not available. • Confirm all applicable operating and specification manuals are delivered to building staff. Where applicable, summarize the training performed and personnel involved. • Heat Recovery: Record entering and leaving air temperatures for both intake and exhaust air streams. Measure exhaust and intake air flows. Calculate heat recovery efficiency and compare to manufacturer's rating at measured airflow and temperature conditions. Ensure supply air is 70 F ± 5 F. • Roof Fan Timers: Record timer set points. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • All primary equipment (central fans, air handling units, HRVs, etc.) should be inspected. A representative sample of 10% of in-unit terminal devices (individual room fans, grilles, roof fans, etc.) should be included in the process. A minimum of five (5) apartments must be visited. • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Collect make and model information on installed equipment. • Record nameplate efficiency, or measured efficiency if nameplate efficiency is not available, and efficiency proposed in the SAV-IT. • Confirm all applicable operating and specification manuals are delivered to building staff. Where applicable, summarize the training performed and personnel involved. • Heat Recovery: Record entering and leaving air temperatures for both intake and exhaust air streams. Measure exhaust and intake air flows. Calculate heat recovery efficiency and compare to manufacturer's rating at measured airflow and temperature conditions. Ensure supply air is 70 F ± 5 F. • Roof Fan Timers: Record time of day and whether fan was found on or off. Record timer set points.

MPP Comprehensive Option Guidelines V8

	<ul style="list-style-type: none">• Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
--	--

HVAC & DHW	Domestic Hot Water
Equipment Covered	Domestic hot water systems
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the capacity, efficiency, water temperature, and actual installation to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from HVAC contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed equipment. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • For new equipment, record make/model, nameplate efficiency, or measured efficiency if nameplate efficiency is not available. • Record water temperature at a faucet nearest and a faucet farthest from the water heater (as measured along the distribution system) and the location where that measurement was made. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • All primary equipment (boilers, hot water heaters, etc.) should be inspected. • A minimum of two faucets should be tested for water temperature.
Required Attachments	<ul style="list-style-type: none"> • For inspected equipment, record make/model, nameplate efficiency, or measured efficiency if nameplate efficiency is not available. • Record water temperature at a faucet nearest and a faucet farthest from the water heater (as measured along the distribution system) and the location where that measurement was made. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

HVAC & DHW	Pipe Insulation, Duct Insulation
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the insulation type, thickness, and R-value to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from HVAC contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed insulation. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record insulation type, thickness, and R-value of all insulation. • Photograph insulation in areas that will be hidden at the end of construction. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • Each unique device assembly shall be inspected. For example: DHW pipes, heating pipes, and ductwork should all be inspected independently. • Sampling may be used to inspect device assemblies that are consistent throughout large sections of the building. At each stage of the inspection process, a minimum of 20% of total insulated area must be inspected for each unique device type. • An interim inspection (prior to area being enclosed) is required when insulated area will be inaccessible after completion.
Required Attachments	<ul style="list-style-type: none"> • Record insulation type, thickness, and R-value of inspected insulation. • Photograph insulation in areas that will be hidden at the end of construction. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

OTHER	Energy / Building Management Systems
Equipment Covered	Energy Management Systems, Building Management Systems
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the control sequence, energy performance specifications, and actual installation to the assumptions made in the SAV-IT and note conformance/deviation. • Due diligence could include being present during the EMS/BMS communication and functionality test.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from controls contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed equipment. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record location, make/model, and type of each energy management system device or control. • Printout of submetering communication and functionality test that demonstrates all meters are functioning properly. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	Visually inspect a representative sample of 20% of the installed monitoring points.
Required Attachments	<ul style="list-style-type: none"> • Record location, make/model, and type of each energy management system device or control. • Printout of submetering communication and functionality test that demonstrates all meters are functioning properly.
Communication and Functionality Test	<ul style="list-style-type: none"> • All EMS/BMS contractors must perform a communication and functionality test at the completion of the installation. The test provides proof of communication between the monitoring points, controls, equipment, and the system controller. Most of these systems are tied to a computer on site or to a recording device. The controller can scroll through connection points and provide data (e.g. outside and inside temperatures, set points, run times of equipment, etc.). A print screen of these points confirms connectivity to the sensors and equipment. Successful adjustments to these settings confirm functionality and response of the system. • A copy of these print screens and test would serve as a good commissioning tool. It would also be useful for the Provider or construction manager to be present when the controls company conducts the test. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

HVAC & DHW	Low-Flow Aerators & Showerheads
Equipment Covered	Low-flow aerators and low-flow showerheads
Provider Requirements	<ul style="list-style-type: none"> • Prepare Inspection documentation as required or ensure that the signed Statement of Substantial Completion is accurate and complete. • Compare the rated GPM to the assumptions made in the SAV-IT and note conformance/deviation.
Option 1: Statement of Substantial Completion	
Statement of Substantial Completion	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion from installing contractor or commissioning agent may reduce the Provider sampling requirements, provided it meets at least the stated documentation requirements for 100% of the installed devices. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
Required Attachments	<ul style="list-style-type: none"> • Record location, type, and quantity of all devices. • Record rated GPM of all devices. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.
Option 2: Provider Sampling	
Provider Sampling	<ul style="list-style-type: none"> • A representative sample of 10% of all installed aerators and low-flow devices is required. A minimum of five apartments must be visited. Sample must be random and statistically representative. • Problems with installations found during random inspections will require an expanded sample to determine extent of problem.
Required Attachments	<ul style="list-style-type: none"> • Record location, type, and quantity of inspected devices. • Record rated GPM of inspected devices. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

OTHER	Elevator Drive Systems
<p>Provider Requirements</p>	<ul style="list-style-type: none"> • Ensure that the Statement of Substantial Completion is accurate and complete. • Compare the energy performance specifications and actual installation to the assumptions made in the SAV-IT and note conformance/deviation.
<p>Statement of Substantial Completion</p>	<ul style="list-style-type: none"> • A signed Statement of Substantial Completion or commissioning statement from elevator contractor or commissioning agent is required that meets at least the stated documentation requirements for 100% of the installed equipment. • Provider should be satisfied that signed Statement of Substantial Completion is thorough and accurate. See description of signed Statements of Completion in the introduction of this section.
<p>Required Attachments</p>	<ul style="list-style-type: none"> • Record system type and size. • Record efficiency minimums for elevator drives and motors, where applicable. • Record control system manufacturer and model. • Record elevator drive manufacturer and drive capacity. • Photograph completed installation and drive nameplate. • Basic elevator test results should be provided by installation contractor, including commissioning of control system. • Evidence of elevator safety inspection should be provided. • Cut sheet showing the manufacturer, model number, and relevant energy rating information must be provided for each installed product. The model number that was installed must be clearly marked on the cut sheet.

9 STAGE 4 - PERFORMANCE PAYMENT

The Performance Payment is an incentive available to projects that achieve at least 20% verifiable energy savings. Post-retrofit utility data is compared to pre-retrofit data to determine actual energy savings in the projects.

9.1 Overview

The incentives discussed in Section 4 identify the maximum Performance Payment for which a project would be eligible. The tier is determined by the energy reduction target proposed in a project's SAV-IT, which sets the maximum incentive a project can receive under the Performance Payment.

If a project achieves energy savings within their projected tier or higher one year following the Stage 3 submittal, they will receive the Performance Payment for their projected tier. For example, the approved SAV-IT for a project shows a 20% energy savings. The post-construction utility data analysis shows the project as actually having 34% energy savings. The project will be paid at the Tier 1, 20% level.

If achieved savings fall into a lower tier, the project will receive the Performance Payment associated with that lower tier. If they achieve savings less than Tier 1, a project will have six months to achieve savings within at least Tier 1 and resubmit a request. Please refer to Section 9.3.

9.2 Performance Payment Analysis

The Performance Payment Analysis repeats the utility bill analysis initially performed for the SAV-IT, but using 12 months of post-construction data. The post retrofit monitoring period is the 12-month period following the Stage 3 submittal. NYSERDA will perform the utility bill analysis. The Performance Payment is based on verifying savings realized by the project as compared to projections in from the initial SAV-IT with preconstruction data.

9.3 Non-Achieving Projects

If the energy savings do not achieve a minimum 20% (Tier 1) after 12 months the Provider may request a six-month extension to allow additional energy saving measures to be implemented by the owner to contribute to the savings reduction. NYSERDA will only use the most recent 12 months of energy use and disregard the initial six months post-construction energy use.

9.4 Stage 4 Approval

9.4.1 Stage 4 Deliverables

Stage 4 submittals are due within 14 months of the Stage 3 submittal to NYSERDA. If an extension is granted, the deliverables must be submitted within 20 months of Stage 3 submittal to NYSERDA.

Required deliverables include:

- Utility bill analysis request documentation package.

- Performance Payment Worksheet – completed by the Provider to account for any known changes that would affect the energy use analysis. This includes, but is not limited to, tenant vacancy.

The Filename Convention must be followed.

Document	File Naming Convention	Example
Utility bill analysis request package	Project Name – Utility bill analysis request.zip	NY Aps – Utility bill analysis request.zip
Performance Payment Worksheet	Project Name – PP Worksheet.xls	NY Apts – PP Worksheet.xls

TABLE 9-1: STAGE 4 DELIEVERABLES

9.4.2 Stage 4 Approval

The following procedure explains each step of the Performance Payment approval process.

1. The Provider obtains data required for NYSERDA to perform the utility bill analysis. The data must be from the 12-month period starting upon one full month of metered utility data following the Stage 3 submittal to NYSERDA.
2. The Provider completes and submits the Performance Payment Worksheet and associated deliverables to NYSERDA.
3. NYSERDA reviews documentation and conducts an energy use analysis
 - a. If analysis shows the Performance Payment has been achieved, the payment process will begin and the project is closed.
 - b. If the project achieves an energy savings less than 20%, the project is eligible to request a 6-month extension to achieve savings of at least 20%. Providers will have to resubmit a Performance Payment documentation.
4. If the project does not achieve a minimum 20% energy savings after the 6-month extension, the project is ineligible for the Performance Payment. The project is closed.

10 APPENDIX A – CONSOLIDATED LIST OF DELIVERABLES

	Document	Filename Convention	Example
Application	Terms and Conditions	Project Name – Terms and Conditions.pdf	NY Apts – Terms and Conditions.pdf
	W-9	Project Name – W-9.pdf	NY Apts – W-9.pdf
	Electronic Funds Transfer (EFT) Form	Project Name – EFT.pdf	NY Apts – EFT.pdf
	Affordable Housing Documentation	Project Name - * (as appropriate)	NY Apts – NYSDHCR Contract.pdf
Stage 1	Savings Verification and Information Tool	Project Name – SAVIT_rev0.xls	NY Apts – SAVIT_rev0.PDF
	Provider-Participant Contract	Project Name – Provider Contract.PDF	NY Apts – Provider Contract.pdf
	Photographs (multiple in zip file or Template)	Project Name – Photos.zip Project Name – Photos.pdf	NY Apts – Photos.zip NY Apts – Photos.pdf
Stage 2	50% Complete Verification Workbook	Project Name – 50% Complete Verification.xls	NY Apts – 50% Complete Verification_rev0.xls
	Signed Construction Manager Contract	Project Name – Construction Manager Contract.pdf	NY Apts – Construction Manager Contract.pdf
Scope Change	Scope Change Cover Sheet	Project Name – Scope Change #.pdf	NY Apts – Scope Change 1.pdf
	SAV-IT	Project Name – SAVIT_rev#.xls	NY Apts – SAVIT_rev3.xls
Stage 3	Site Inspection Request	Project Name – 100% Inspection.xls	NY Apts – 100% Inspection_rev0.xls
	Photo Documentation	Project Name – Photos _100%.pdf	NY Apts – Photos_100%.pdf
	Common Area DRAFs	Project Name – Common Area DRAFs	NY Apts – Common Area DRAFs.pdf
	Measure Documentation:	Project Name - * (per Site Inspection Protocols)	NY Apts – Boiler cut sheets.pdf NY Apts – Blower Door.pdf
Stage 4	Utility Bill Analysis Request	Project Name – Utility Bill Analysis Request.zip	NY Apts – Utility Bill Analysis Request.zip
	Performance Payment Worksheet	Project Name – Performance Payment_rev#.pdf	NY Apts – Performance Payment_rev0.pdf