



Energy Efficient Indoor Air Quality (IAQ) Analysis

LaBella Associates

Preliminary Findings Report #5

November 23, 2020

A) Summary of Progress to Date

As of November 23rd, work plans for all (8) sites have been submitted and approved. The table below outlines a summary of approved sites as well as the progress with site investigations and coordination with vendors.

Work Plan #	Client Name	Facility Name	City	Sector	Work Plan Approved	Kickoff Meeting	Utility Analysis	Review Industry Guidance	Review Site Drawings & Controls Sequences	Site Visits Underway	Identify Potential Measures	Energy Calculations	Economic Analysis	Draft Report Submitted to Customer for Review	Draft Submitted to NYSERDA for Review	Estimated Report Completion Date
WP-01	NFTA	Buffalo Niagara International Airport	Buffalo	Airport	✓	✓	✓	✓	✓	✓	✓	✓	✓			Nov. 30
WP-02	City of Rochester	Blue Cross Arena	Rochester	Arena	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Oct. 21
WP-03	The Rosenblum Companies	100 Great Oaks	Albany	Office/ Medical	✓	✓	✓	✓	✓	✓	✓					Dec. 4
WP-04	NFTA	Metro Transportation Center	Buffalo	Offices/ Bus Station	✓	✓	✓	✓	✓	✓	✓	✓	✓			Nov. 30
WP-05	City of Rochester	Rundel Library	Rochester	Library	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		Nov. 30
WP-06	Webster CSD	Dewitt Road E.S.	Rochester	Primary School	✓	✓	✓	✓	✓	✓	✓					Dec. 4
WP-07	OGS	299 Old Niskayuna	Albany	Office	✓	✓	✓	✓	✓	✓	✓	✓	✓			Nov. 30
WP-08	North Tonawanda CSD	NT Middle School	Buffalo	Middle School	✓	✓	✓	✓	✓	✓	✓					Dec. 4


Note: cumulative report is anticipated to be submitted for review at the same time as the latest individual site report.
Boxes highlighted in green indicate progress made in past month since previous progress report.

As indicated on the graph above, all 8 of the approved sites have commenced with kickoff meetings, data collection, utility analyses, site visits, and coordination with vendors. Pathogen mitigation measures and energy conservation measures have been identified for all sites and are in the process of finalizing energy calculations and draft reports.

The estimated report completion dates are listed above and are expected to be submitted to NYSERDA in early December at the latest in order to allow for enough time for NYSERDA to make comments and LaBella to address them before the end of the calendar year. The draft report for Blue Cross Arena has been submitted to both NYSERDA and the City of Rochester for review. [Comments on the Blue Cross Arena have been received from NYSERDA and will be re-submitted with revisions after the City of Rochester submits their comments.](#)

B) Study Findings to Date

A thorough review of ASHRAE safe-operation measures has been conducted. The chart below indicates the main objectives of the HVAC system within its role in mitigating the spread of pathogens, as well as strategies that can be used to achieve these goals.



Based on a variety of site conditions, the strategies outlined above are narrowed down to specific recommendations that will enable the safest operation conditions. In addition to mitigating the spread of pathogens, additional energy conservation strategies are being evaluated, where feasible.

The following table outlines a summary of the recommended measures on a site-by-site basis. Factors limiting the implementation of certain ASHRAE-recommended measures are stated as well as alternate approaches to help mitigate the spread of pathogens. In general, the most common recommended measures are to maximize filtration as much as possible, bring in as much outdoor air as possible in order to increase air changes in the spaces, put UVGI on the cooling coils of air handling units as space allows, and modify controls in order to maintain humidity levels between 40% RH and 60%RH.

Measures >>	Increased OA Ventilation	UVGI	Increased Filtration	Humidification Control	Energy Conservation Opportunities	Current Ventilation	Current Filtration	Current UVGI	# AHUs
Sites  BNIA Terminal	It is recommended that during pandemic mode occupied hours, the percent OA intake is increased from 17% to 40% to increase the number of outdoor air changes per hour.	1) Recommended UVGI inside large Mammoth AHUs. Smaller units do not have sufficient space for UVGI. Typical UVGI layouts in these units are spaced 18" from the cooling coil with 5 rows of 2 lamps.	All units currently have MERV-15 filters. No additional filtration is recommended based on current industry guidance.	In retrofitted unit option, Humidifiers are being recommended in order to maintain 40%-60% RH. Final selection of proposed equipment has been completed.	1) Replacement of DX cooling coils to centralized chilled water system will allow for reduced maintenance, energy cost savings, and the capacity to allow for additional OA ventilation and space for UVGI. Final vendor selection of retrofit options and air-cooled rooftop chillers is completed. Energy analyses are in 2) The supply fan in the unit is nearing the end of its useful life. Replacing the supply fan with a fan wall will present increased energy efficiency as well as increased resiliency. Fan wall and return fan retrofits have been selected.	The facility currently operates bringing in 17% outdoor air.	MERV-15 throughout	None	32
NFTA MTC	1) Increased OA ventilation is recommended. Amount of OA intake will be limited by either cooling coil capacity or ability to meet indoor air setpoints. 2) Each air handling unit has been analyzed to calculate individual unit limitations for treatment of outside air. Outside air temperature ranges to operate with 100% outside air have been defined for each unit. Total impacts on both the chilled water system and hot water system have also been calculated. The limiting factor for most AHUs is the water-side pressure drop through either the cooling or heating coils. The annual energy implications of operating the AHUs with the maximum amount of outside air possible have been calculated.	Cooling coil mounted UVGI has been selected for all (7) AHUs. Economic impacts of purchasing, installing, and operating the UVGI equipment have been calculated. Optimum layouts for each unit have been configured to maximize the UVGI efficiency in mitigating the spread of the virus.	The supply air fans for all (7) air-handling units have been analyzed on their capacity and ability to handle the additional pressure drop of installing MERV-13 filters. AHU-1 and AHU-2 have the ability to accept a 4" M13 filter, with spare BHP to accommodate the additional pressure drop. AHU-3, 4, 5, 6, and 7 are configured to accept a 2" M13 filter; these units also have available BHP to accommodate the additional pressure drop. The annual energy implications of operating each AHU at a slightly higher SP to overcome the additional static of the filters has been calculated.	1) AHU-1 and AHU-2 were originally constructed with DriSteam electric humidifiers to provide space humidification for the tower offices and spaces. The dispersion piping has since been disconnected to both of these units. A measure is currently being analyzed to re-install humidification equipment and dispersion piping to treat these areas. The intent is to provide increased humidification capabilities in the office spaces. Preliminary sizing for each humidifier has been completed, showing a separate 75-100 lb/hr humidifier required for AHU-1 and AHU-2. 2) The remaining (5) AHUs have been assessed for the feasibility of adding humidification. Due to both the nature of these spaces (high traffic, high infiltration, and materials of construction) achieving the desired humidity levels during occupied hours is not feasible. Humidifiers have been selected, as well as budgetary pricing for the materials and installation of the humidification system. Energy calculations are currently being performed to understand the increase in energy required to operate these units.	1) Replacing the existing air-cooled chiller, which is nearing the end of its useful life, will present an opportunity for increased cooling capacity- which will increase the potential for increased OA ventilation. The total increase in tonnage required for operating all (7) AHUs with maximum outside air has been calculated. It is anticipated to increase the required chilled water tonnage by 48 tons. Installing a more efficient air-cooled chiller with higher part-load efficiencies will present an opportunity for energy savings. 2) De-stratification fans in the bus station terminal may present an opportunity for improved HVAC performance, which will allow more opportunity for OA ventilation. Selection of fans, layouts, and pricing is currently being evaluated. De-stratification HVLS fans have been selected for the bus station terminal area. A preliminary layout has been developed, and the energy savings calculations are currently being performed. 3) Sealing ductwork in the catwalk above the bus terminals will result in increased HVAC system efficiency- which will result in energy savings as well as reduced limitations on OA intake. Aeroseal duct sealing is being assessed for economic feasibility. Ductwork sealing has been priced, and the energy savings calculations have been performed. Anticipated payback periods have been defined.	Code-minimum	MERV-8, upgrading to MERV-13	None	7
Blue Cross Arena	1) Additional OA intake is recommended for AHU-(1-4,12). Staff to provide OA to the bowl based on attendance rates. 2) Repairing low-temperature cutoff alarms in AHU-14 and AHU-20 will reduce the amount of return air brought into the space and allow for more OA intake. 3) Repairing operating sequences of the suite fan coil units and AHUs supplying fresh air to them will allow the units to supply fresh air instead of the current 100% recirculated air	Recommended UVGI inside AHUs in cooling coil sections - all units that are not using 100% outside air.	1) Facility is currently using MERV-8 Filters and is capable of upgrading to MERV 9 or 13 Filters.	Blue Cross Arena does not incorporate humidification controls at this time. Due to both the nature of these spaces (high traffic, high infiltration, and materials of construction) achieving the desired humidity levels during occupied hours is not feasible.	1) Resolving low-temperature cutoff alarms in AHU-14 and AHU-20 will reduce the amount of return air brought into the space and allow for more OA intake. 2) Using variable speed drives to adjust return & exhaust fan speeds, will create safer airflow pathways in the arena while reducing overall energy consumption 3) Lower pressure differentials across filters will decrease the energy consumption of the supply fans.	Code-minimum. Economizer is used when OA is between 40 and 65 deg F.	MERV-8	None	26

Blue text indicated additions in past month since previous progress report.

Measures >>	Increased OA Ventilation	UVGI	Increased Filtration	Humidification Control	Energy Conservation Opportunities	Current Ventilation	Current Filtration	Current UVGI	# AHUs
Sites  Webster CSD - Dewitt Road Elementary	Increased OA ventilation is recommended for pandemic mode as much as the air handling units can handle with their current cooling & heating capacities. The magnitude of this ventilation increase has yet to be determined.	UVGI is currently being evaluated for the air handler cooling coil sections that serve high capacity areas such as the cafeteria. Other units without cooling coils are being evaluated for in-duct UVGI.	Upgraded MERV filters will be considered for major air handlers. The feasibility of upgrading these units has yet to be determined based on the fan's ability to overcome increased pressure drop.	Humidity controls are not currently incorporated or recommended at this time due to the lack of heating and cooling capacity.	1) Energy recovery in centrum new unit. 2) Post pandemic mode high efficiency MERV 9 filter with lower pressure drop compared to existing MERV 8 filters. 3) Modify AHU controls in cafetorium to run fans at variable speeds instead of constant speed, based on discharge air temperatures.	Code- minimum in most spaces. Repurposed spaces may require additional fresh air.	MERV-8, changing 2x per year, or upon positive test in classroom	More information required.	3
299 Niskayuna	Current OA intake is being overridden in order to satisfy the humidity control issue in the building. Upgraded controls sequencing and CO2 sensors in spaces is being investigated in order to better control OA ventilation as well as maintain humidity in space below required threshold. In most areas, OA ventilation appears to be excessive, resulting in energy waste and uncontrolled humidity levels.	1) Coil-mounted UVGI is not possible in some areas due to limited space and accessibility to units for maintenance. Office areas have been identified as candidates for UVGI in return ducts. 2) In-duct UVGI and upper-room UVGI for the warehouse space is not recommended due to limited space occupancy and space size.	Owner is currently in process of upgrading to MERV-13 filters. Higher rated filters are not recommended due to pressure drop issues in the units. Calculations have been prepared showing the increased costs associated with the higher performing filters.	Strict humidity requirements were already in-place in this facility to accommodate paper storage requirements. OA Ventilation recommendations will take into account relative humidity in the space.	Incorporating an economizer function into the air handling units will allow for significant savings as well as increased outdoor air ventilation. Issues have been identified with economizer controls and unintended economizer leakage. Controls upgrades are recommended to incorporate/repair economizer functions in the units. Demand Control Ventilation is recommended in training rooms and cafeteria space to reduce energy consumption and help aid the space in maintaining strict humidity setpoints. This will help reduce humidity issues related to overventilation as well as help maintain minimum outdoor ventilation rates.	Units are controlled by combination of CO2 sensors and standard economizer controls. Some units do not currently bring in OA into the space, except as a result of leakage, which appears to be very high. CO2 levels in all spaces with sensors remain very low at all times.	MERV-8, upgrade to MERV-13 is completes	None	28
100 Great Oaks	The existing units ventilate outdoor air based on CO2 levels in the building. Their unit's ability to incorporate additional ventilation has yet to be determined and will depend on either the cooling coil capacity or unit's ability to meet space setpoints. There may be issues with lack of sufficient CO2 sensors to maintain levels in all areas served by common RTUs.	There is very limited space in AHUs for UVGI. UVGI is recommended in the airstream in the ducts.	There is currently a 2" filter rack in the AHUs. The feasibility of upgrading to higher-rated MERV filters has yet to be determined based on the fan's ability to overcome the pressure drop.	Humidity controls are not currently incorporated into the building's design. The feasibility of adding humidity control has yet to be determined.	The reduction of recommended increase in OA ventilation when paired with UVGI is in the process of being evaluated.	Unit ventilation is controlled by CO2 sensors within space.	MERV-8	None	10
NT Intermediate School	More information required before site-specific recommendations are made.	1) UVGI is currently being evaluated for the air handler cooling coil sections that serve high capacity areas such as the cafeteria. Other units are being reviewed for potential installations.	Upgraded MERV filters will be considered for major air handlers. The feasibility of upgrading these units has yet to be determined based on the fan's ability to overcome pressure drop.	Humidity controls are not currently incorporated or recommended at this time due to the lack of steam or DX cooling (and gas reheat) in most systems.	1) Low Pressure drop filters may be considered as a means to reduce energy consumption while maintaining or increasing overall filtration efficiency.	Code-minimum	MERV-8, changing 2x per year, or upon positive test in classroom	More information required.	11
COR Library	1) Outside air to the public spaces is primarily supplied by the main penthouse air handler (AHU-1) Office and storage areas (closed to the public) are supported through natural ventilation and various zone air handlers. Potential improvements are still being evaluated. 2) Most spaces were designed to use natural ventilation via windows which creates a conflict of interest during extreme temperature conditions where staff will close windows to maintain space temperatures but lose some of their fresh air intake. Additional mechanical ventilation is being considered to provide better control of space temperatures while maintaining code required fresh air rates.	1) UVGI is currently being evaluated for the main penthouse air handler's cooling coil section as this provides the majority of fresh air to the building. Other units are being reviewed for potential installations.	1) The penthouse and tunnel AHUs are considering being upgraded to MERV 9 or 13 filtration and will likely be capable of the increased static pressure. Fan Coils that provide localized cooling likely don't have capacity to support a MERV-13 filter.	1) Humidification control is not currently implemented and is not recommended due to the cost and difficulty in maintaining humidification setpoints in open spaces. Hot gas reheat could be installed at minimal cost if future DX cooling is installed.	1) Low Pressure drop filters may be considered as a means to reduce energy consumption while maintaining or increasing overall filtration efficiency.	The building has been designed for a combination of natural and mechanical ventilation. This is currently being compared to 2020 code to evaluate potential improvements.	Air Handlers currently use MERV-8 filters. Fan Coils used for local cooling support MERV 4 (estimated)	None	10

Blue text indicated additions in past month since previous progress report.

C) Lessons Learned/ Barriers Encountered

Barrier Encountered: Some school districts have expressed concern with safety regarding UVGI lighting. The NYSED published reopening guidance in late August permitting UV lighting in central air systems as well as in classrooms or nurses offices, but only during unoccupied hours and with appropriate safety measures such as disconnects, etc. No use of UVGI in classrooms during occupied hours (such as upper-room UVGI) is permitted to reduce risk of exposing UV light to students or faculty. Recommendations for the IAQ studies at this facility will entail UVGI downstream of the cooling coil and/or in the airstream where applicable. A description of all necessary safety measures associated with the technology will be provided in order to better inform the users on potential risks as well as measures to counteract those risks.

D) Proposed Work Plan Adjustments

N/A

E) Next Steps

- Complete energy calculations & feasibility analyses
- Complete draft reports
- Submit draft reports for review

F) Study Findings

The following indicates preliminary findings from the Blue Cross Arena study as well as the Buffalo Niagara International Airport study. It should be noted that this report is currently under review and may be subject to change. None of the recommendations listed below are required by code.

-Blue Cross Arena

-Buffalo Niagara International Airport



Blue Cross Arena

259,000 sf sports arena located in Rochester, NY

Site-Specific Proposed Measures	Description	Annual Electric Savings (kWh)	Annual Steam Savings (MMBtu)	Net Annual Cost Savings	Estimated Cost of Installation
UVGI on Cooling Coils	Install UVGI lights on downstream side of cooling coils in (16) AHUs and (36) fan coil units. Installation costs equate to \$2,646 per units.	-11,793	0	\$ (2,818)	\$ 137,600
Filter Upgrades	Upgrade from existing MERV 8 filters to high-efficiency MERV-9 filters with increased filtration and reduced pressure drop as well as rebalancing of airside systems. Installation costs equate to \$530 per unit.	12,985	0	\$ 1,066	\$ 13,800
Outdoor Air Ventilation Improvements	Incorporate demand control ventilation to ensure that sufficient OA is supplied during high-occupancy events. This will also limit exorbitant energy consumption. A re-balancing of the air handling units is also recommended in order to refine airflow measurements.	0	-5	\$ (100)	\$ 9,400
Purge Fan Exhaust	Equip large fans with variable speed drives and allow the fans to operate as exhaust in lieu of current return air located in the stands. Doing so will improve airflow patterns in the arena bowl when occupied as well as reduce the number of return fans operating during events.	12,948	0	\$ 1,096	\$ 25,600
AHU Low Temperature Cutoff Repair	It is recommended that (2) AHUs are repaired in order to resolve low temperature cutoff alarms. Doing so will enable the units to bring in increased outdoor air.	-280	-146	\$ (2,849)	\$ 16,300
Suite AHU Controls Modifications	Change operating sequence of fan coil units in suites to economize when the outdoor air temperature is between 45° and 65°. Doing so will allow (2) AHUs to shut down and conserve energy as well as increase outdoor air ventilation.	-1,679	0	\$ (280)	\$ 3,700

Buffalo Niagara International Airport

462,225 sf airport terminal located in Buffalo, NY

Site-Specific Proposed Measures	Description	Annual Electric Savings (kWh)	Annual Natural Gas Savings (MMBtu)	Net Annual Cost Savings	Estimated Cost of Installation
Option 1: UVGI on Cooling Coils	Install UVGI lights on downstream side of cooling coils in all AHUs. The facility already uses MERV-15 filtration and does not have the heating and cooling capacity to increase OA ventilation.	-471,117	0	\$ (27,412)	\$ 580,000
Option 2A: AHU Component Retrofits (Pandemic Mode)	Retrofit components in AHUs that are in need of replacement in order to facilitate increased OA ventilation, UVGI downstream of the cooling coil and	2,310,039	-64,869	\$ 125,184	\$ 21,936,001
Option 2B: AHU Component Retrofits (Post-Pandemic Mode)	in airstream, heat recovery, increased supply fan and return fan efficiencies, and humidity control.	2,447,930	157,387	\$ 243,560	