

## Changes to MPP-NC Technical Requirements V6.1 – ASHRAE 2010

- Added language replacing ASHRAE standard references with new 2010 references.
- Updated baseline ventilation modeling guidance to no longer allow the baseline ventilation rates to exceed ASHRAE 62.1 or 62.2 by up to 50%. The baseline ventilation rates must now match ASHRAE 62.1 or 62.2.
- Added revision to the Simulation Guidelines language for garage demand control ventilation as it is now a mandatory requirement for garages in ASHRAE 90.1-2010.