

## Changes to Modified Prescriptive Path Requirements document

- Added note to duct leakage requirement that allows for an alternative method of meeting total duct leakage requirements post-construction.
- Updated requirement for central duct leakage, based on EPA program update, which allows a higher maximum leakage allowance if multiple registers are used per floor.