

6. Tech Tip: eQUEST Modeling – Ventilation Approaches



ENERGY STAR MFHR Guidelines

Section 3.14.1 (aligned with 90.1 Section G3.1.2.9):

- Baseline Systems 1 & 2 fan **electrical power for supply, return, exhaust, and relief fans** shall be 0.3 W/CFM

Section 3.14.2 (aligned with 90.1 Table G3.1 Section 4)

- Baseline System 1 & 2 fans must be **modeled as running continuously**

MFHR Guidelines Section 3.14 includes 3 examples of typical designs; in all cases, the baseline PTAC fans run continuously.



Modeling Baseline PTAC Fans in eQUEST

The screenshot displays the eQUEST software interface with the following details:

- Toolbar:** Project & Site, Building Shell, Internal Loads, Water-Side HVAC, Air-Side HVAC (selected), Utility & Economics.
- Component Tree:** Project: 'Multifamily Fan Pow', Global Parameters, Extra UWall Insulation, Apartment PTAC, and various zone components (EL1 ESE Perim Zn, EL1 East Perim Zn, etc.).
- Air-Side HVAC System Parameters Dialog:**
 - Currently Active System: Apartment PTAC
 - Fan Power and Control tab is active.
 - Fan Power Parameters for single-duct systems:**

Supply:	Delta T	Static	Tot Eff	Mech Eff
kW/cfm	°F	in WG	Frac	Frac
0.000300	0.93	n/a	n/a	n/a
Unused:	n/a	n/a	n/a	n/a
Return:	n/a	n/a	n/a	n/a
 - Fan Control and Placement:**
 - Cooling: - undefined -
 - Unused: n/a
 - Return: n/a
 - Exhaust: - undefined -
 - Fan Control:** Constant Volume (highlighted with a red box)

Modeling Baseline PTAC Fans in eQUEST

The screenshot shows the eQUEST software interface with the 'Air-Side HVAC System' tab selected. The 'Component Tree' on the left lists various project components, including 'Global Parameters', 'Apartment PTAC' (with 23 sub-zones), 'Corridor PTAC', 'Lobby Zn', and 'El1 Core Zn (G.CS)'. The main spreadsheet table has columns for 'Zone Name', 'Parent System', 'OA Flow/Person (cfm)', 'OA Air Flow (cfm)', and 'OA Changes'. The 'OA Air Flow (cfm)' column for all 23 zones is highlighted with a red border and contains the value '63.33'. A callout bubble on the right provides two key pieces of advice:

- Enter OA flow on zone level to have PTACs running continuously instead of cycling with load
- Ventilation rate must be based on Section 3.12.2 of HRMF Guidelines

	Zone Name	Parent System	OA Flow/Person (cfm)	OA Air Flow (cfm)	OA Changes
1	EL1 ESE Perim Zn (G.ESE1)	Apartment PTAC	n/a	63.33	n/a
2	EL1 East Perim Zn (G.E2)	Apartment PTAC	n/a	63.33	n/a
3	EL1 East Perim Zn (G.E3)	Apartment PTAC	n/a	63.33	n/a
4	EL1 WSW Perim Zn (G.WSW)	Apartment PTAC	n/a	63.33	n/a
5	EL1 West Perim Zn (G.W7)	Apartment PTAC	n/a	63.33	n/a
6	EL1 West Perim Zn (G.W8)	Apartment PTAC	n/a	63.33	n/a
7	EL1 WNW Perim Zn (G.WNW)	Apartment PTAC	n/a	63.33	n/a
8	EL1 ESE Perim Zn (M.ESE10)	Apartment PTAC	n/a	63.33	n/a
9	EL1 East Perim Zn (M.E11)	Apartment PTAC	n/a	63.33	n/a
10	EL1 East Perim Zn (M.E12)	Apartment PTAC	n/a	63.33	n/a
11	EL1 ENE Perim Zn (M.ENE13)	Apartment PTAC	n/a	63.33	n/a
12	EL1 WSW Perim Zn (M.WSW)	Apartment PTAC	n/a	63.33	n/a
13	EL1 West Perim Zn (M.W16)	Apartment PTAC	n/a	63.33	n/a
14	EL1 West Perim Zn (M.W17)	Apartment PTAC	n/a	63.33	n/a
15	EL1 WNW Perim Zn (M.WNW)	Apartment PTAC	n/a	63.33	n/a
16	EL1 ESE Perim Zn (T.ESE19)	Apartment PTAC	n/a	63.33	n/a
17	EL1 East Perim Zn (T.E20)	Apartment PTAC	n/a	63.33	n/a
18	EL1 East Perim Zn (T.E21)	Apartment PTAC	n/a	63.33	n/a
19	EL1 ENE Perim Zn (T.ENE22)	Apartment PTAC	n/a	63.33	n/a
20	EL1 WSW Perim Zn (T.WSW)	Apartment PTAC	n/a	63.33	n/a
21	EL1 West Perim Zn (T.W25)	Apartment PTAC	n/a	63.33	n/a
22	EL1 West Perim Zn (T.W26)	Apartment PTAC	n/a	63.33	n/a
23	EL1 WNW Perim Zn (T.WNW)	Apartment PTAC	n/a	63.33	n/a

Example 1: Proposed Design w/Cycling PTACs and Exhaust Ventilation

The screenshot shows the 'Parametric Run Definitions' dialog box. On the left, under 'Existing Parametric Runs', there is a tree view with two main categories: '1 - Ventilation via exhaust fans' and '2 - Baseboards'. The first category has a single item, 'Parameter #1', which is highlighted with a red box. On the right, the 'Name:' field is set to 'Parameter #1', 'Type:' is 'BDL Command', and 'Component Type:' is 'Thermal Zone'. A checked checkbox 'Sort Component Type' is also visible. Under 'References:', a list of various zones is shown, with most items checked. Below this is a 'Data Modifications' table with four rows, each containing a category, keyword, value, and units. These rows are also highlighted with a red box. The categories are numbered 1 through 4.

Category	Keyword	value	Units
1 Outside Air & Exhaust	OA Air Flow	0.0000	cfm
2 Outside Air & Exhaust	Exhaust Flow	63.0000	cfm
3 Outside Air & Exhaust	Source	Balanced Infiltration	
4 Outside Air & Exhaust	Exhaust kW/Flow	0.0004	kW/cfm

- 1:** PTACs no longer provide ventilation, and cycle with heating/cooling load
- 2&3:** Exhaust flow equal to baseline OA CFM or as specified, whichever is greater; make-up via infiltration (e.g. trickle vents)
- 4:** Exhaust fan power as specified

Example 2: Proposed Design with HW Baseboards and Exhaust Ventilation

Parametric Run Definitions

Existing Parametric Runs

- 1 - Ventilation via exhaust fans
- 2 - Baseboards
- Added HW Baseboards**
- Baseboards controled by space Thermo

Run Based On: Ventilation via exhaust fans

Run Based On Separate Building Description (DOE=)

Proposed Design 1: Added HW Baseboards


Name:	Added HW Baseboards	
Type:	BDL Command	
Component Type:	HVAC System	
References:	<input checked="" type="checkbox"/> Apartment PTAC <input type="checkbox"/> Corridor PTAC	
<input type="button" value="Select All"/> <input type="button" value="Clear All"/>		
Data Modifications:		
Category	Keyword	Value
Heating - Coil Capacity	Heat Source	Not Installed
Heating - Baseboard	Baseboard Source	Hot Water Loop

Proposed Design 2: Baseboards controled by space Thermostat

Name:	Baseboards controled by space Thermostat	
Type:	BDL Command	
Component Type:	Thermal Zone	
References:	<input checked="" type="checkbox"/> EL1 ESE Perim Zn (G.ESE1) <input checked="" type="checkbox"/> EL1 East Perim Zn (G.E2) <input checked="" type="checkbox"/> EL1 East Perim Zn (G.E3) <input checked="" type="checkbox"/> EL1 WSW Perim Zn (G.WSW6) <input checked="" type="checkbox"/> EL1 West Perim Zn (G.W7) <input checked="" type="checkbox"/> EL1 West Perim Zn (G.W8) <input checked="" type="checkbox"/> EL1 WNW Perim Zn (G.WNW9) <input checked="" type="checkbox"/> EL1 ESE Perim Zn (M.ESE10) <input checked="" type="checkbox"/> EL1 East Perim Zn (M.E11) <input checked="" type="checkbox"/> EL1 East Perim Zn (M.E12) <input checked="" type="checkbox"/> EL1 ENE Perim Zn (M.ENE13)	
<input type="button" value="Select All"/> <input type="button" value="Clear All"/>		
Data Modifications:		
Category	Keyword	Value
Heating	Baseboard Control	Thermostatic
Heating	Baseboard Coil DT	20.0000

STATE OF OPPORTUNITY. INTELIGUA

Impact on Fan Energy May be Significant



Easy Baseline Fan Energy QC Check

Internal Loads		Water-Side HVAC		Air-Side HVAC		Utility & Economics	
Air-Side HVAC System							
... EL1 Core Zn (G.C5)		Corridor		C	836	199	0.24 100%
... EL1 Core Zn (M.C14)		Corridor		C	6,688	1,671	0.25 100%
... EL1 Core Zn (T.C23)		Corridor		C	836	347	0.42 100%
Sum of Zones		2,817
Sum of Zones / System Total		100%
Project Totals							
System & Zone Name		System Type		Type*	Design Flow		Design V
Principal Zone Activity		Ret Zn	Area sqft	Supply cfm	Supply cfmsf	Min Flow	Off cfm
Sum of SYSTEMs		84,360	49,446	0.59	100%
Sum of ZONEs		49,446	0.59	..
Sum of Zones / System Total		100%

50,000 [CFM] X 0.3 [W/CFM] X 8760 [hr/yr] ~ 130,000 kWh

REPORT- BEPU Building Utility Performance										WEATHER FILE- New York CityNY TMY2				
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLM	DOMEST HOT WTR	EXT USAGE	TOTAL	
EM1 ELECTRICITY KWH	105806.	0.	190456.	0.	82603.	0.	2613.	128626.	0.	0.	0.	0.	510104.	
FM1 NATURAL-GAS THERM	0.	0.	0.	17627.	0.	0.	0.	0.	0.	0.	8871.	0.	26498.	



Common Mistakes

Modeling continuously running exhaust fans in addition to 0.3 W/CFM baseline PTAC fan power allowance

Electric Meter Properties

Currently Active Electric Meter: EM1 Type: Utility

Basic Specifications | Building and/or Submeters | Direct Loads

Interior Direct Loads

	Load (kW)	Schedule	Enduse
1	0.19 LT_ON_Yrly	Task Lighting	
2	n/a	n/a	
3	n/a	n/a	
4	n/a	n/a	

Exterior Direct Loads

	Load (kW)	Schedule	Enduse
1	2.00 LT_ON_Yrly	Exterior Usage	
2	0.19 LT_ON_Yrly	Ventilation Fans	
3	0.17 LT_ON_Yrly	Ventilation Fans	
4	1.14 LT_ON_Yrly	Ventilation Fans	

The exterior loads (2.00, 0.19, 0.17, 1.14 kW) are crossed out with a large red X.

Common Mistakes

Exaggerated baseline design flow due to Design Day sizing and
....incorrect Design Day settings





TABLE D-1 U.S. and U.S. Territory Climatic Data (*Continued*)

State/City	Latitude	Longitude	Elev., ft	HDD65	CDD50	Heating Design	Cooling Design Temperature
						Temperature	Dry-Bulb
<hr/>							
(New York cont.)						99.6%	1.0%
NY Central Pk WSO City	40.78 N	73.97 W	132	4805	3634	NA	NA
NY Kennedy WSO AP	40.65 N	73.78 W	16	5027	3342	11	88
NY La Guardia WSO AP	40.77 N	73.90 W	11	4910	3547	13	89
							72
							73




Common Mistakes

Exaggerated baseline design flow due to Design Day sizing and
...modeling internal loads at 100% during Cooling Design Day



Baseline Fan Flow Sizing Tip 1

- DO NOT enter Cooling DD / Heating DD, to have eQUEST size the flow based on the annual peak load



Baseline Fan Flow Sizing Tip 2

Baseline system design supply airflow rates must be based on a supply-air-to-room-air temperature difference of 20°F (G3.1.2.9.1)

Air-Side HVAC System Parameters

Currently Active System: PTAC_Apt_North System Type: Pkgd Terminal AC

Basics | Fans | Outdoor Air | Cooling | Heating | Preconditioner | Meters | Refrigeration |

Coil Capacity / Control | Unitary Power | Condenser | Capacity Curves | Evaporative Cooling | Economizer | Staged-Volume |

Cooling Capacity

Cool Source: n/a Zone Entering Min Supply Temp: 55.0 °F Cold Deck Min Leaving Temp: n/a °F

Internal Loads Water-Side HVAC **Air-Side HVAC** Utility & Economics

75F-55F=20F

	Zone Name	Parent System	Space	Zone Type	Floor Multiplier (ratio)	Multiplier (ratio)	Cool Design T (°F)
1	FL2_AptA_2br_Zn	PTAC_Apt_North	FL2_AptA_2br	Conditioned	1		75.0
2	FL3_AptA_2br_Zn	PTAC_Apt_North	FL3_AptA_2br	Conditioned	1		75.0
3	FL3_AptF_1br_Zn	PTAC_Apt_North	FL3_AptF_1br	Conditioned	1		75.0
4	FL4_AptA_2br_Zn	PTAC_Apt_North	FL4_AptA_2br	Conditioned	1		75.0
5	FL4_AptB_1br_Zn	PTAC_Apt_North	FL4_AptB_1br	Conditioned	1		75.0
6	FL4_AptC_0br_Zn	PTAC_Apt_North	FL4_AptC_0br	Conditioned	1		75.0
7	FL4_AptE_1br_Zn	PTAC_Apt_North	FL4_AptE_1br	Conditioned	1		75.0