

PROPOSED LOCATIONAL SYSTEM RELIEF VALUE (LSRV) AREAS

NYSEG and RG&E

Project Name	Company	Division	LSRV MW Limit	Circuits
Station 117 - Replace #1 Transformer Bank and convert 3 circuits to 12kV operation	RG&E	Rochester	1.34	2130, 2131, 2156, 5186, 5187, 5188
Station 46 - Replace #1 and #3 Transformer Banks	RG&E	Rochester	3.28	2548, 0583, 0584, 0261, 0262, 0297, 2507, 2508
Hilldale 115kV source, xfrmr bank upgrade, 2nd 12kV dist circ	NYSEG	Liberty	2.68	225
Holland Transformer Replacement	NYSEG	Lancaster	1.59	320, 321
Orchard Park - Add a 2nd Transformer Bank	NYSEG	Lancaster	2.39	285, 286, 287
West Davenport Sub - Replace sub transformer with non-LTC 7.5/10.5MVA unit.	NYSEG	Oneonta	1.28	12, 22