

# BASELINE BUILDINGS -REV2 EQUIPMENT SCHEDULE

## WATER-TO-AIR EQUIPMENT

Zone	Manufacturer	Model	Tons (nom)	QTY	Head Loss (ft H <sub>2</sub> O)	Cooling			Heating			
						Unit Flow (gpm)	EAT <sub>db</sub> (°F)	EAT <sub>wb</sub> (°F)	Air Flow (cfm)	Unit Flow (gpm)	EAT <sub>db</sub> (°F)	Air Flow (cfm)
ISC_Lib	Waterfurnace	NB038 (ECM)	3.00	20	7.9	9.0	80.0	67.0	1,250.0	9.0	70.0	1,250.0
	Waterfurnace	NB049 (ECM)	4.00	20	8.9	12.0	80.0	67.0	1,550.0	12.0	70.0	1,550.0
	Waterfurnace	NB026 (ECM)	2.00	25	6.4	6.0	80.0	67.0	900.0	6.0	70.0	900.0
YEL Buildings-Rev2	Waterfurnace	NB049 (ECM)	4.00	20	8.9	12.0	80.0	67.0	1,550.0	12.0	70.0	1,550.0
	Waterfurnace	NB026 (ECM)	2.00	25	6.4	6.0	80.0	67.0	900.0	6.0	70.0	900.0
	Waterfurnace	NB038 (ECM)	3.00	20	7.9	9.0	80.0	67.0	1,250.0	9.0	70.0	1,250.0
ORG Buildings-Rev2	Waterfurnace	NB038 (ECM)	3.00	20	7.9	9.0	80.0	67.0	1,250.0	9.0	70.0	1,250.0
	Waterfurnace	NB026 (ECM)	2.00	50	6.4	6.0	80.0	67.0	900.0	6.0	70.0	900.0
	Waterfurnace	NB049 (ECM)	4.00	50	8.9	12.0	80.0	67.0	1,550.0	12.0	70.0	1,550.0
RED Buildings-Rev2	Waterfurnace	NB049 (ECM)	4.00	55	8.9	12.0	80.0	67.0	1,550.0	12.0	70.0	1,550.0
	Waterfurnace	NB038 (ECM)	3.00	30	7.9	9.0	80.0	67.0	1,250.0	9.0	70.0	1,250.0
	Waterfurnace	NB026 (ECM)	2.00	80	6.4	6.0	80.0	67.0	900.0	6.0	70.0	900.0
<b>Total</b>			1,210.00	415.0								

# BASELINE BUILDINGS -REV2 EQUIPMENT SCHEDULE

## WATER-TO-WATER EQUIPMENT

Zone	Manufacturer	Model	Tons (nom)	QTY	Head Loss <sub>s</sub> (ft H <sub>2</sub> O)	Head Loss <sub>L</sub> (ft H <sub>2</sub> O)	Cooling				Heating			
							Unit Source Flow (gpm)	Unit Load Flow (gpm)	EWT <sub>L</sub> (°F)	LWT <sub>L</sub> (°F)	Unit Source Flow (gpm)	Unit Load Flow (gpm)	EWT <sub>L</sub> (°F)	LWT <sub>L</sub> (°F)
ISC_Lib	Waterfurnace	NXW120	10.00	5	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
YEL Buildings-Rev2	Waterfurnace	NXW120	10.00	10	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
	Multistack	MS050XN	50.00	7	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
ORG Buildings-Rev2	Multistack	MS050XN	50.00	2	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
	Waterfurnace	NXW120	10.00	4	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
RED Buildings-Rev2	Waterfurnace	NXW120	10.00	10	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
	Multistack	MS050XN	50.00	6	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
<b>Total</b>			1,040.00	44.0										

# FUTURE INDIVIDUAL BUILDINGS -REVO

---

## ENTERING WATER TEMPERATURES

---

The Entering Water Temperatures defined for all of the equipment operating in this Zone Group are as follows.

**EWT<sub>min</sub>** 30 °F

**EWT<sub>max</sub>** 90 °F

---

## ZONE GROUP DESIGN DAY

---

The Zone Group Design Day is the aggregated load including all constituent zones and hot water elements in the zone group. The Zone Group Design Day is the loading profile for which the ground loop is sized.

	Cooling (kBtuh)	Heating (kBtuh)
<b>8:00AM-12:00PM</b>	13,412.3	20,165.4
<b>12:00PM-4:00PM</b>	15,866.0	17,553.5
<b>4:00PM-8:00PM</b>	14,750.7	17,732.1
<b>8:00PM-8:00AM</b>	9,768.9	18,897.7

---

## SPACE SENSIBLE HEAT FACTOR

---

The zone group space sensible heat factor is the weighted average space sensible heat factor for all zones in the zone group.

**Space Sensible Heat Factor (SHF)** 0.90

---

## ZONE GROUP CAPACITY

---

Zone Group Capacity is the aggregated equipment performance defined across all load elements in the Zone Group. These values represent the performance and efficiency of the entire system connected to the loopfield.

	Cooling	Heating
<b>Total Capacity (kBtuh)</b>	32,500.1	29,573.3
<b>Sensible Capacity (kBtuh)</b>	3,223.0	---
<b>Percent Total Sizing</b>	204.8	146.7
<b>Efficiency (EER/COP)</b>	16.9	3.2
<b>Demand (kW)</b>	940.6	1,818.9

## FUTURE INDIVIDUAL BUILDINGS -REVO ENERGY SUMMARY

---

### ANNUAL ENERGY REQUIREMENTS

---

The following table describes the annual energy requirements of the Zone Group organized by use.

	<b>Cooling</b>	<b>Heating</b>
<b>Space Conditioning (kBtu)</b>	24,492,096	18,838,760
<b>Hot Water Generation (kBtu)</b>	---	0
<b>Total (kBtu)</b>	24,492,096	18,838,760

---

### ENERGY SOURCES AND SINKS

---

The following table describes how the annual energy requirements of the Zone Group are distributed across system sources and sinks.

	<b>Cooling</b>	<b>Heating</b>
<b>Ground Energy (kBtu)</b>	24,492,096	18,838,760
<b>Net Ground Energy (kBtu)</b>	5,653,336	

# FUTURE INDIVIDUAL BUILDINGS -REVO ACTIVE GHEX

---

## VERTICAL BORE 1

Active GHEX Type Vercally Bored

---

### GEOMETRY

---

Rows 24

Bores Per Row 22

Number of Bores 528

Average C-C Spacing 20.00 ft

#### *Length Per Bore*

The required active length for each bore are calculated as follows. The design length is always the longest of the four.

	Cooling	Heating
Y1 LENGTH/BORE (ft)	498	461
Y25 LENGTH/BORE (ft)	528	431
DESIGN LENGTH/BORE (ft)	528	

#### *Length Total*

The required active total bore lengths are calculated as follows. The design length is always the longest of the four.

	Cooling	Heating
Y1 TOTAL LENGTH (ft)	262,835	243,313
Y25 TOTAL LENGTH (ft)	278,711	227,505
TOTAL DESIGN LENGTH (ft)	278,711	

### FORMATION PROPERTIES

---

Deep Earth Temperature 58.0 °F

Thermal Conductivity 1.40 Btu/hr ft °F

Thermal Diffusivity 1.05 Btu/hr ft °F

---

**U-BEND CONFIGURATION**

---

The U-Bend Configuration defines the number and position of u-bends within the bore.

**U-Bend Configuration** Single U-Bend Typical (B/C)

---

**BOREHOLE DEFINITION**

---

**Bore Diameter** 6.00 in

***Design Path Piping***

The design path piping describes the defined type and size of pipe used within the active section of the ground heat exchanger design.

**Material** HDPE 4710

**Dimension Ratio** 11

**Nominal Diameter** 1.50 in

***Thermal Grout Conductivity***

The installed bore is assumed to have an annulus filled from bottom to top with a grouting material with the following thermal conductivity.

**Thermal Grout Conductivity** 1.20 Btu/hr ft °F

---

**TEMPERATURE PENALTIES**

---

Temperature penalty describes the change in the deep earth temperature immediately surrounding the installed loopfield after extended periods of system operation.

**Y1 Penalty** 0.37 °F

**Y25 Penalty** 2.05 °F

---

**CIRCULATING FLUID**

---

**Antifreeze Type** Propylene Glycol

**Antifreeze Concentration** 20 %

**Freezing Temperature** 19.4 °F

---

**OPERATING TEMPERATURES**

---

**EWT<sub>max</sub>** 90.0 °F

**EWT<sub>min</sub>** 30.0 °F

**LWT<sub>max</sub>** 99.6 °F

**LWT<sub>min</sub>** 24.5 °F

---

---

**LOOPFIELD DESIGN FLOW**

---

Future Individual Buildings -Rev0 assumes flow is based on Peak Block (Primary-Secondary). Which means, flow is a function of the block flow per ton and the aggregated peak block load for the entire zone group. The interior building loop will be decoupled from the exterior GHEX piping (i.e. - inside flow rate can differ from the outside flow rate).

**Block Flow Per Ton 3 gpm**

	<b>Cooling</b>	<b>Heating</b>
<b>Total Loopfield Flow (gpm)</b>	3966.5	5041.4
<b>Flow Per Path (gpm)</b>	7.5	9.5
<b>Velocity Per Path (ft/s)</b>	1.3	1.6
<b>Reynold's Number</b>	11,835	4,403
<b>Head Loss /100ft (ft)</b>	0.57	1.23

A head loss table for a Step-Down Step-Up Reverse-Return (SDSU-RR) header is provided in the appendix.

# Future Individual Buildings -Rev0

## Appendix A: Equipment Schedules

# FUTURE INDIVIDUAL BUILDINGS -REV0 EQUIPMENT SCHEDULE

## WATER-TO-AIR EQUIPMENT

Zone	Manufacturer	Model	Tons (nom)	QTY	Head Loss (ft H <sub>2</sub> O)	Cooling				Heating		
						Unit Flow (gpm)	EAT <sub>db</sub> (°F)	EAT <sub>wb</sub> (°F)	Air Flow (cfm)	Unit Flow (gpm)	EAT <sub>db</sub> (°F)	Air Flow (cfm)
<b>GRN Townhouses Future-Rev0</b>	Samsung	AM055KXW (VRF)	5.00	27	8.4	15.0	80.0	67.0	N/A	15.0	70.0	N/A
<b>YEL NH-North Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	18	5.0	18.0	80.0	67.0	N/A	18.0	70.0	N/A
<b>ORG CHEM-Chemistry Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	7	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>RED Pantas-LJP Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	8	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>RED Dekalb-DKLB Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	7	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>ORG MACH-Machinery Future-Rev0</b>	Waterfurnace	NB026 (ECM)	2.00	50	6.4	6.0	80.0	67.0	900.0	6.0	70.0	900.0
	Waterfurnace	NB038 (ECM)	3.00	20	7.9	9.0	80.0	67.0	1,250.0	9.0	70.0	1,250.0
	Waterfurnace	NB049 (ECM)	4.00	50	8.9	12.0	80.0	67.0	1,550.0	12.0	70.0	1,550.0
<b>ORG ENG-Engineering Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	12	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>ORG ELJ-</b>	Samsung	AM096HXW	8.00	8	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A

<b>Jones Future-Rev0</b>		(VRF)										
<b>ORG THRF- Thrift Future-Rev0</b>	Samsung	AM072HXW (VRF)	6.00	3	5.2	18.0	80.0	67.0	N/A	18.0	70.0	N/A
<b>ORG ISC Building Future-Rev0</b>	Samsung	AM072HXW (VRF)	6.00	10	5.2	18.0	80.0	67.0	N/A	18.0	70.0	N/A
<b>ORG LIB- Library Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	10	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>YEL MEM- Memorial Future-Rev0</b>	Samsung	AM072HXW (VRF)	6.00	6	9.2	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>YEL SU- Student Union Future-Rev0</b>	Samsung	AM072HXW (VRF)	6.00	6	9.2	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>YEL MAIN Future-Rev0</b>	Samsung	AM096HXW (VRF)	8.00	12	8.9	24.0	80.0	67.0	N/A	24.0	70.0	N/A
<b>YEL EAST Future-Rev0</b>	Samsung	AM072HXW (VRF)	6.00	14	5.2	18.0	80.0	67.0	N/A	18.0	70.0	N/A
<b>YEL SH- South Hall Future-Rev0</b>	Samsung	AM072HXW (VRF)	6.00	6	5.2	18.0	80.0	67.0	N/A	18.0	70.0	N/A
<b>Total</b>			1,421.00	274.0								

# FUTURE INDIVIDUAL BUILDINGS -REV0 EQUIPMENT SCHEDULE

## WATER-TO-WATER EQUIPMENT

Zone	Manufacturer	Model	Tons (nom)	QTY	Head Loss <sub>s</sub> (ft H <sub>2</sub> O)	Head Loss <sub>L</sub> (ft H <sub>2</sub> O)	Cooling				Heating			
							Unit Source Flow (gpm)	Unit Load Flow (gpm)	EWT <sub>L</sub> (°F)	LWT <sub>L</sub> (°F)	Unit Source Flow (gpm)	Unit Load Flow (gpm)	EWT <sub>L</sub> (°F)	LWT <sub>L</sub> (°F)
YEL DHW-Rev0	Waterfurnace	NXW120	10.00	3	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
RED DHW-Rev0	Waterfurnace	NXW120	10.00	12	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
RED Stable-SBL Future-Rev0	Multistack	MS050XN	50.00	2	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
	Waterfurnace	NXW120	10.00	2	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
GRN ARC Future-Rev0	Multistack	MS050XN	50.00	5	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
	Waterfurnace	NXW120	10.00	5	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
RED Steuben-STE Future-Rev0	Multistack	MS050XN	50.00	4	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
	Waterfurnace	NXW120	10.00	2	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
GRN DHW-Rev0	Waterfurnace	NXW120	10.00	4	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
RED Pratt Studios-PS Future-Rev0	Waterfurnace	NXW120	10.00	2	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5
	Multistack	MS050XN	50.00	3	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5
ORG	Waterfurnace	NXW120	10.00	3	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5

<b>DHW- Rev0</b>															
<b>ORG MACH- Machinery Future- Rev0</b>	Waterfurnace	NXW120	10.00	4	4.9	4.4	30.0	30.0	56.0	44.7	30.0	30.0	115.0	119.5	
	Multistack	MS050XN	50.00	2	21.3	21.3	150.0	150.0	56.0	45.7	150.0	150.0	115.0	119.5	
<b>Total</b>			1,170.00	53.0											