

**CITY OF ONEIDA  
MOBILIZED FILM TECHNOLOGY  
PILOT STUDY REPORT**

**FINAL REPORT 07-10  
FEBRUARY 2007**

**NEW YORK STATE  
ENERGY RESEARCH AND  
DEVELOPMENT AUTHORITY**





The New York State Energy Research and Development Authority (NYSERDA) is a public benefit corporation created in 1975 by the New York State Legislature. NYSERDA's responsibilities include:

- Conducting a multifaceted energy and environmental research and development program to meet New York State's diverse economic needs.
- Administering the **New York Energy Smart<sup>SM</sup>** program, a Statewide public benefit R&D, energy efficiency, and environmental protection program.
- Making energy more affordable for residential and low-income households.
- Helping industries, schools, hospitals, municipalities, not-for-profits, and the residential sector, including low-income residents, implement energy-efficiency measures.
- Providing objective, credible, and useful energy analysis and planning to guide decisions made by major energy stakeholders in the private and public sectors.
- Managing the Western New York Nuclear Service Center at West Valley, including: (1) overseeing the State's interests and share of costs at the West Valley Demonstration Project, a federal/State radioactive waste clean-up effort, and (2) managing wastes and maintaining facilities at the shut-down State-Licensed Disposal Area.
- Coordinating the State's activities on energy emergencies and nuclear regulatory matters, and monitoring low-level radioactive waste generation and management in the State.
- Financing energy-related projects, reducing costs for ratepayers.

NYSERDA administers the **New York Energy Smart<sup>SM</sup>** program, which is designed to support certain public benefit programs during the transition to a more competitive electricity market. Some 2,700 projects in 40 programs are funded by a charge on the electricity transmitted and distributed by the State's investor-owned utilities. The **New York Energy Smart<sup>SM</sup>** program provides energy efficiency services, including those directed at the low-income sector, research and development, and environmental protection activities.

NYSERDA derives its basic research revenues from an assessment on the intrastate sales of New York State's investor-owned electric and gas utilities, and voluntary annual contributions by the New York Power Authority and the Long Island Power Authority. Additional research dollars come from limited corporate funds. Some 400 NYSERDA research projects help the State's businesses and municipalities with their energy and environmental problems. Since 1990, NYSERDA has successfully developed and brought into use more than 170 innovative, energy-efficient, and environmentally beneficial products, processes, and services. These contributions to the State's economic growth and environmental protection are made at a cost of about \$.70 per New York resident per year.

Federally funded, the Energy Efficiency Services program is working with more than 540 businesses, schools, and municipalities to identify existing technologies and equipment to reduce their energy costs.

For more information, contact the Communications unit, NYSERDA, 17 Columbia Circle, Albany, New York 12203-6399; toll-free 1-866-NYSERDA, locally (518) 862-1090, ext. 3250; or on the web at [www.nyserda.org](http://www.nyserda.org)

**STATE OF NEW YORK**  
Eliot Spitzer  
Governor

**ENERGY RESEARCH AND DEVELOPMENT AUTHORITY**  
Vincent A. DeIorio, Esq., Chairman  
Peter R. Smith, President and Chief Executive Officer

**CITY OF ONEIDA**  
**MOBILIZED FILM TECHNOLOGY**  
**PILOT STUDY REPORT**

**FINAL REPORT**

Prepared for the  
**NEW YORK STATE**  
**ENERGY RESEARCH AND**  
**DEVELOPMENT AUTHORITY**

Albany, NY  
www.nyserda.org

Kathleen O'Connor  
Project Manager

Prepared by:  
**CITY OF ONEIDA**  
Oneida, NY

Dan Ramer  
Project Manager

and

**ECOVATION, INC.**  
Victor, NY

Bob Hickey, PhD  
Project Manager

and

**O'BRIEN & GERE**  
Syracuse, NY

Mark Greene  
Project Manager

## **NOTICE**

This report was prepared by the team of The City of Oneida, O'Brien & Gere, Ecovation, Inc. and the HP Hood Company in the course of performing work contracted for and sponsored by the New York State Energy Research and Development Authority (hereafter "NYSERDA"). The opinions expressed in this report do not necessarily reflect those of NYSERDA or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it. Further, NYSERDA, the State of New York, and the contractor make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, or other information contained, described, disclosed, or referred to in this report. NYSERDA, the State of New York, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately owned rights and will assume no liability for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

## ABSTRACT

A three-month pilot test was conducted at the City of Oneida Wastewater Treatment Plant (WWTP) to evaluate the potential of using Ecovation's Mobilized Film Technology (MFT) anaerobic pretreatment system at the WWTP to treat both the high-strength waste and process wastewater received from HP Hood Company (HP Hood). The incorporation of anaerobic pretreatment into the WWTP's overall treatment process would 1) reduce the organic load to the WWTP's aeration tanks, 2) increase the volume of biogas produced by the WWTP, which could be used to generate electricity, thereby reducing their overall costs, and 3) provide a more sustainable waste management practice for HP Hood's Oneida facility.

Both the high-strength waste and a mixture of the high-strength waste and the process wastewater were found to be effectively treated in the MFT anaerobic pretreatment system. The processing scheme included pretreating the streams in a dissolved air flotation (DAF) unit to remove the bulk of the fats, oils and grease (FOG) and suspended solids. The DAF float solids were sent directly to the WWTP's existing anaerobic digesters, while the DAF supernatant was sent for treatment in the MFT reactor. Extrapolating the amount of biogas that was produced by the pilot system to a full-scale system, it is estimated that 78.5 MMBTU per day could be produced, which would be enough to run a 250 kilowatt (kW) generator.

**Key words:** Anaerobic treatment, dissolved air flotation, dairy waste, wastewater treatment

## TABLE OF CONTENTS

<u>Section</u> .....	<u>Page</u>
SUMMARY .....	S-1
1 CHARACTERIZATION OF HIGH-STRENGTH WASTE AND PROCESS WASTEWATER ..1-1	
Results of five-Day High Strength Waste Sampling and Analysis.....	1-1
Results of BMP Testing .....	1-2
Results of DAF Bench-Scale Testing.....	1-3
2 DESCRIPTION OF THE PILOT DEMONSTRATION SYSTEM.....	2-1
System Summary.....	2-1
Details of the MFT Anaerobic Pilot System .....	2-4
3 RESULTS OF PILOT-SCALE DAF PRETREATMENT .....	3-1
4 DEMONSTRATION TEST RESULTS.....	4-1
Results of Startup and Acclimation (Phase 1).....	4-2
Results of Testing with High-Strength Waste (Phase 2) .....	4-2
Overall Phase 2 Results.....	4-2
Results for the Phase 2 Evaluation Period.....	4-4
Results of Testing with Combined Process Wastewater and High-Strength Waste (Phase 3) .....	4-8
Overall Phase 3 Results.....	4-3
Results for Phase 3A Evaluation Period.....	4-11
Results for Phase 3B Evaluation Period.....	4-11
Bed Volatile Solids (BVS) .....	4-12
Summary .....	4-13
5 FULL-SCALE BASIS OF DESIGN .....	5-1
Development of COD Mass Loading Basis of Design.....	5-1
Expected Biogas Production .....	5-2
<b>APPENDIX</b>	
Oneida-Hood Pilot - MFT Daily Log .....	A-1

## FIGURES

<u>Figure</u>	<u>Page</u>
1-1 Results of BMP Assay Testing.....	1-2
1-2 Samples of Process Wastewater Before (a) & After (b) DAF, High Strength Waste Before (c) and After (d), and Combination of the Two Before (e) and After (f).....	1-5
2-1 Process Flow Scheme for Oneida/HP Hood Pilot .....	2-1
2-2 Picture of the Building, Influent Holding Tank and Anaerobic Influent Tanks .....	2-2
2-3 Picture of the Pilot DAF Unit.....	2-3
2-4 Recycled Flow Pressurization System – Krofta Supracell .....	2-3
2-5 Picture of the Pilot Anaerobic MFT System.....	2-5
4-1 Influent and Effluent COD Concentrations during Overall Demonstration Period.....	4-1
4-2 Influent and Effluent COD Concentrations Observed During Startup Phase .....	4-2
4-3 COD and sCOD Removal Efficiencies Observed During Phase 1 .....	4-3
4-4 Effect of Temperature on Effluent Quality (sCOD) During Phase 1.....	4-4
4-5 Influent and Effluent COD Final Four Weeks (Evaluation Period) of Phase 1 .....	4-5
4-6 Influent and Effluent Soluble COD during Evaluation Period of Phase 1.....	4-6
4-7 Scatter Plot of COD Removal Efficiency as a Function of Temperature .....	4-9
4-8 Influent and Effluent COD During Phase 2 Testing.....	4-9
4-9 Influent and Effluent Soluble COD During Phase 2 Testing.....	4-10
4-10 Bed Volatile Solids (BVS) over Time .....	4-13
4-11 Scatter Plot of COD Removal Efficiency vs. Applied OLR for Phase 1 Testing.....	4-14
4-12 Scatter Plot of Soluble COD vs. OLR for Phase 1 Testing .....	4-14
5-1 Probability Plot of BOD <sub>5</sub> in Process Wastewater.....	5-1

## TABLES

<u>Table</u>	<u>Page</u>
1-1 Results of Five-Day Sampling and Characterization of the High-Strength Waste Stream.....	1-1
1-2 Results of Flotation Testing using the Process Wastewater .....	1-3
1-3 Results of Flotation Testing with the High-Strength Waste Sample .....	1-3
1-4 Bench-Scale Testing Results for Combined Process and High-Strength Wastewater.....	1-4
1-5 Results of Testing with Drewfloc 2249 (DAF 1) and 2270 (DAF 2) .....	1-5
3-1 DAF Performance Treating the High-Strength Waste.....	3-1
3-2 DAF Performance Treating the Combined High-Strength Waste and Process Wastewater.....	3-1
4-1 Summary of COD and sCOD Data for the Entire Phase 1 Test Period.....	4-3
4-2 Summary of COD, sCOD, TSS and VSS Concentrations for the Evaluation Portion of Phase 1 Testing .....	4-5
4-3 Summary of Influent and Effluent BOD <sub>5</sub> Data Taken During the Evaluation Period of Phase 1 Testing .....	4-6
4-4 Summary of Nitrogen Data Taken During Evaluation Period of Phase 1 .....	4-7
4-5 Summary of Total and Ortho Phosphorus Data for Entire Phase 1 Test Period.....	4-8
4-6 Phase 2 Overall Results for COD, sCOD, TSS and VSS .....	4-10
4-7 Phase 2A Results for COD, sCOD, TSS and VSS .....	4-11
4-8 Phase 2B Results for COD, sCOD, TSS and VSS.....	4-12

## SUMMARY

In January 2005, the City of Oneida and Bricar Engineering Associates completed an energy reduction feasibility study, which was co-funded by NYSERDA. The study identified six energy conservation measures, including the installation of an anaerobic pretreatment system dedicated to treating wastewater from the HP Hood Company Oneida milk processing plant (HP Hood). HP Hood currently contributes 40-60% of the BOD<sub>5</sub> and TKN load to the city's wastewater treatment plant (WWTP). The predicted annual energy savings for the WWTP associated with this measure was 32,850 MMBTU of natural gas and the predicted annual cost savings was \$328,500 due to usage of biogas produced from the anaerobic system to generate heat and electricity. The estimate capital cost to implement this measure was \$6,660,000.

The city decided to take a preliminary step in implementing the measure by pilot testing Ecovation's Mobilized Film Technology (MFT) anaerobic pretreatment system. In addition to energy and cost savings for the WWTP, drivers for the project included:

- Improved performance of the WWTP;
- The ability of the WWTP to accommodate regional residential, commercial and industrial growth, which is anticipated as the Turning Stone Casino Resort expands;
- The ability of the HP Hood Oneida plant to expand, which is currently limited in part by wastewater treatment capacity;
- A desire to improve the sustainability of the HP Hood Oneida plant, so it remains competitive with other HP Hood plants (and can maintain/expand production); and
- Public health concerns over failing septic systems in neighboring villages, which may ultimately be incorporated into the city's sewer system.

The pilot demonstration project was conducted at the WWTP from September 2 - December 5, 2006. The objectives of the project were to 1) demonstrate that 90-95% of the five-day biochemical oxygen demand (BOD<sub>5</sub>) of the wastewater could be converted to biogas and 2) develop a basis of design for a full-scale facility. The project was performed in three phases:

- Startup and acclimation of the MFT reactor, including an initial characterization of HP Hood's process wastewater and high-strength waste;
- Steady operation of the MFT reactor treating only high-strength waste; and
- Steady operation of the MFT reactor treating both high-strength waste and process wastewater.

During the wastewater characterization, startup and acclimation, it was determined that the concentration of fats, oils and grease (FOG) in the high-strength waste were well above the tolerable level for high-rate anaerobic systems, and would require pretreatment. A dissolved air floatation (DAF) system was added to the pilot system treatment train, prior to the MFT reactor. Upon conclusion of pilot testing, it was

determined that both the high-strength waste DAF supernatant and the combined high-strength waste and process wastewater stream could be effectively treated in a high-rate MFT at a reasonable organic loading rate (OLR).

Based on the results of pilot testing, a full-scale basis of design (for treatment of the combined process wastewater/high-strength waste stream) was selected at average and maximum OLRs of 15 kg COD/m<sup>3</sup>-d and 25 kg COD/m<sup>3</sup>-d, respectively. It was estimated that this would produce approximately 33 million BTU (MMBTU)/d (at a methane yield of 5.6 scf/lb COD). In addition to biogas generated by the MFT reactor, considerable energy could be recovered from digestion of the DAF float, which was estimated at 45.5 MMBTU/d. At a conservative 28% conversion efficiency, this 78.5 MMBTU/d translates to 6,443 kWh/d of electricity and 268 kW.

## Section 1

### CHARACTERIZATION OF THE HIGH-STRENGTH WASTE AND PROCESS WASTEWATER

HP Hood generates two waste streams at its Oneida facility, which are both potential candidates for anaerobic treatment; process wastewater and high-strength waste (“slop material”). The process wastewater is stored in an equalization tank at the HP Hood site, then discharged to the City of Oneida WWTP via a dedicated pipeline.

Samples of both waste streams were sent to Ecovation’s Technology Development Center and a NYS Certified Contract Laboratory (Life Sciences of Dewitt, NY) for chemical and physical characterization, and to conduct biochemical methane potential (BMP) analysis. (Since there was no data available on the composition of the high-strength waste, the waste stream was sampled for five days and an intensive characterization of this stream was performed.) BMP analysis was performed to determine the maximum amount of the chemical oxygen demand (COD) that could potentially be converted to biogas (methane). Due to the high level of fats, oils and grease (FOG) in the samples, samples were also sent to Ecovation’s subsidiary, Krofta Technologies (Dalton, MA), to determine if dissolved air flotation (DAF) should be used prior to anaerobic treatment for removal of FOG and total suspended solids (TSS).

### RESULTS OF FIVE-DAY HIGH-STRENGTH WASTE SAMPLING AND ANALYSES

The five-day high-strength waste sampling program was conducted from May 15-19, 2006. The results are presented in Table 1-1. The high-strength waste stream had an average COD of 210,000 mg/L, with a standard deviation of 60,000 mg/L (range of 140,000 - 296,000 mg/L). The soluble COD (sCOD) averaged 32,800 mg/L (range of 24,000 – 40,000 mg/L), or 16.3% of the total COD.

**Table 1-1. Results of Five-Day Sampling and Characterization of the High-Strength Waste Stream**

Parameter	Units	15-May	16-May	17-May	18-May	19-May	Average	Stdev.
<b>COD</b>	mg/L	296,000	174,000	140,000	176,000	222,000	<b>201,600</b>	60,289
<b>sCOD</b>	mg/L	40,000	32,000	24,000	28,000	40,000	<b>32,800</b>	7,155
<b>TSS</b>	mg/L	39,000	36,300	32,400	46,600	52,200	<b>41,300</b>	8,006
<b>VSS</b>	mg/L	37,500	32,300	28,800	39,800	44,600	<b>36,600</b>	6,212
<b>TKN</b>	mg/L	1,080	1,620	1,640	1,810	1,740	<b>1,578</b>	289
<b>sTKN</b>	mg/L	448	285	398	286	252	<b>334</b>	84
<b>NH<sub>4</sub>-N</b>	mg/L	11.5	3.3	2.0	2.2	2.9	<b>4.4</b>	4.0
<b>TP</b>	mg/L	1,180	318	268	401	369	<b>507</b>	379
<b>Soluble P</b>	mg/L	237	261	188	194	374	<b>251</b>	75
<b>FOG</b>	mg/L	5,000	3,700	5,000	8,300	21,000	<b>8,600</b>	7,138
<b>Ca</b>	mg/L	446	412	375	792	480	<b>501</b>	167
<b>Mg</b>	mg/L	43	43	<50	<50	<50	<b>43</b>	

Parameter	Units	15-May	16-May	17-May	18-May	19-May	Average	Stdev.
<b>TDS</b>	mg/L	17,100	18,500	11,500	7,590	17,800	<b>14,498</b>	4,754
<b>Alkalinity</b>	mg/L as CaCO <sub>3</sub>	406	-	196	230	876	<b>342</b>	332

The TSS and volatile suspended solids (VSS) averaged 41,300 mg/L and 36,600 mg/L, respectively. The ratio of VSS to TSS of 0.89 indicated that the solids were highly degradable.


The high-strength waste had a relatively high total Kjeldahl nitrogen (TKN), averaging 1,578 mg/L. The soluble TKN, by contrast, was only 334 mg/L or 17.8% of the total, which indicates that most of the TKN is in the solids portion of the high-strength waste. The ammonium nitrogen (NH<sub>4</sub>-N) was low, averaging 4.4 mg/L; virtually all of the nitrogen was organic nitrogen in nature.

Of particular concern were the high concentrations of FOG, which averaged 8,600 mg/L, with a peak concentration of 21,000 mg/L. These concentrations are well above the tolerable level for high-rate anaerobic systems. Therefore, pretreatment to reduce FOG levels was deemed necessary for the high-strength waste stream.

### RESULTS OF BMP TESTING

The result of the BMP testing is shown in Figure 1-1. The control (i.e., sucrose) averaged 99.8% conversion to methane. The high-strength waste averaged 96.6%, and the process wastewater averaged 66.2% (after two weeks' incubation at 35°C).

Figure 1-1. Results of BMP Assay Testing



## RESULTS OF DAF BENCH-SCALE TESTING

The results of the bench-scale DAF testing are presented in Table 1-2 and Table 1-3 for the process wastewater and high-strength waste, respectively.

**Table 1-2. Results of DAF Testing on Process Wastewater**

Parameter	Units	Process Wastewater	DAF Effluent	Percent Reduction
pH	s.u.	8.17	4.55	—
TSS	mg/L	407	168	59
COD	mg/L	2,337	954	59
FOG	mg/L	410	90	78
Recycled Flow	%		25	
Rise Rate	inch/1 <sup>st</sup> min.		9	
Sludge Volume	ml/L		40	

The bench-scale DAF testing on process wastewater was performed under the following conditions:

- pH adjustment with 375 mg/L sulfuric acid to pH 4.52;
- Coagulant dose of 200 ppm SRL Sumalchlor 50;
- Mixing for 2 sec at 304 rpm followed by mixing for 60 sec at 31 rpm;
- Flocculant addition of 5 mg/L Cytec Superfloc C-1596; and
- Mixing for 2 sec at 307 rpm followed by mixing for 10 sec at 30 rpm using a Phipps & Bird 7790-400 jar tester.

**Table 1-3. Results of DAF Testing on High-Strength Waste**

Parameter	Units	High-Strength Waste	DAF Effluent	Percent Reduction
pH	s.u.	4.46	4.68	—
TSS	mg/L	31,640	2,070	93
COD	mg/L	85,300	13,950	84
FOG	mg/L	10,000	950	91
Recycled Flow	%		400	
Rise Rate.	inch/1 <sup>st</sup> min.		8	
Sludge Volume	ml/L		200	

For the high-strength waste test, neither pH adjustment nor coagulant addition was necessary. Only flocculant (Cytec Superfloc A-1883RS; 75 mg/L; mixing for 2 sec at 312 rpm followed by 10 sec at 29 rpm; Phipps & Bird 7790-400 jar tester) was required to remove the majority of TSS and FOG from the high-strength waste stream; however, COD was also removed.

A combination of process wastewater and high-strength waste (at 6% by volume) was also tested. The results are presented in Table 1-4.

**Table 1-4. Bench-Scale Testing Results for Combined Process Wastewater and High-Strength Waste**

Parameter	Units	Process & High-Strength Waste	DAF Effluent	Percent Reduction
pH	s.u.	6.49	4.47	—
TSS	mg/L	916	155	83
COD	mg/L	8,020	1,400	83
FOG	mg/L	680	39	94
Recycled Flow	%		25	
Rise Rate.	inch/1 <sup>st</sup> min.		12	
Sludge Volume	ml/L		40	


The bench-scale DAF testing on combined process wastewater and high-strength waste was performed under the following conditions:

- pH adjustment with 300 mg/L sulfuric acid to pH 4.56;
- Coagulant dose of 300 ppm SRL Sumalchlor 50;
- Mixing for 2 sec at 306 rpm followed by mixing for 60 sec at 34 rpm;
- Flocculant addition of 10 mg/L Cytec Superfloc A-1883RS; and
- Mixing for 2 sec at 307 rpm followed by mixing for 10 sec at 30 rpm

High removal efficiencies for FOG, TSS, and COD were obtained; however, the amount of polymer required was higher than for the process wastewater alone. High COD removal was also observed, which is atypical for dairy wastewater. Generally COD removal of <50% is observed.

Figure 1-2 shows the process wastewater before and after DAF treatment, the high-strength waste before and after DAF treatment, and the combined streams before and after DAF treatment.

**Figure 1-2. Samples of Process Wastewater Before (a) and After (b) DAF, High-Strength Waste Before (c) and After (d), and Combination of the Two Before (e) and After (f)**



As was previously discussed, it was not possible to treat the process wastewater or the combined streams without pH adjustment. It was also not possible to partially treat the samples; no removal of FOG was observed until the critical polymer dose was reached, and at this point any FOG that could be removed was removed.

Concerns over high sludge production led to a second round of testing with emulsion polymers, which have proven successful with similar types of wastes. Both Drewfloc 2249 and 2270 (Ashland Chemical) were tried. The results are presented in Table 1-5.

**Table 1-5. Bench-scale DAF Testing with Drewfloc 2249 (DAF 1) and 2270 (DAF 2)**

Parameter	Units	Process & High-Strength Waste	DAF Effluent 1	Percent Reduction	DAF Effluent 2	Percent Reduction
pH	s.u.	3.97	4.16	--	4.19	--
TSS	mg/L	44,345	10,029	77	1,066	98
COD	mg/L	108,500	47,800	56	16,700	85
Recycled Flow	%		510		520	
Rise Rate.	inch/1 <sup>st</sup> min.		4		10	
Sludge Volume	m/L		140		110	

The bench-scale DAF testing with alternative polymers were performed under the following conditions:

- Drewfloc 2249 at 160 mg/L
- Drewfloc 2270 at 149 mg/L
- Mixing for 2 sec at 310 rpm followed by mixing for 10 sec at 35 rpm

The sludge volume produced with Drewfloc 2270 was half that produced in the earlier tests. A decision was made to use Drewfloc 2270 for the pilot demonstration.


## Section 2

### DESCRIPTION OF THE PILOT DEMONSTRATION SYSTEM

#### SYSTEM SUMMARY

Since DAF pretreatment was required, the larger pilot Mobilized Film Technology (MFT) unit originally identified by Ecovation for use on the Oneida project was replaced by a smaller MFT unit. (This was due to the fact that the DAF pretreatment lead to decreased COD concentrations, which meant that larger than anticipated volumes of high-strength waste would need to be shipped and stored on-site at the Oneida facility if the larger pilot unit were to be used.) A diagram showing the process flow scheme is presented in Figure 2-1. The high-strength waste was delivered by truck to a holding tank of approximately 750 gallons. The material was stored for at least one day before processing, which was done to ensure that the pH level was at or below 4.6, necessary for effective processing, as dictated by bench-scale testing. A picture of the building, raw influent holding tank and anaerobic influent tank is provided as Figure 2-2.

Figure 2-1. Process Flow Scheme for Oneida/HP Hood Pilot



**Figure 2-2. Picture of the Building, Influent Holding Tank and Anaerobic Influent Tanks**




Every other day, approximately 300 to 400 gallons of high-strength waste was batch processed in the pilot DAF unit shown in Figure 2-3. A three-foot diameter, pilot-scale Krofta Technologies Supracell DAF unit was used. A schematic of the system is shown in Figure 2-4. Ashland Drewfloc 2270 was added to the unit at approximately 150 mg/L. The pilot DAF float was pumped to a sludge storage tank, then to the WWTP's existing DAF, and then to the WWTP's existing anaerobic sludge digesters.

The supernatant from the DAF unit was pumped to the MFT influent tank, a stainless steel 700 gallon tank (Figure 2-2). The MFT tank was mixed using a recirculation pump that drew liquid out of the bottom of the tank and fed it back into the top of the tank. The influent feed to the MFT unit was metered from the tank to the MFT unit by feed pump and recycle loop pump, which provided expansion of the reactor bed in a “trickle and bump” mode of operation. The MFT system and its operation are described in detail in the following section.

Figure 2-3. Picture of the Pilot DAF Unit



Figure 2-4. Recycled Flow Pressurization System – Krofta Supracell



## **DETAILS OF THE MFT ANAEROBIC PILOT SYSTEM**

The pilot MFT system was a 20 inch diameter by 12 feet tall cylindrical reactor constructed using 304 stainless steel (Figure 2-5). The reactor had a maximum working bed height of seven feet, resulting in an empty bed volume of approximately 108 gallons. The reactor was covered with an insulating blanket to reduce heat loss.

The system was initially seeded with biologically active sand (i.e., sand with a biofilm coating) from an Ecovation project site in Canandaigua (Centerra Wine Company) in order to minimize the time required for startup. The initial bed volatile solids (BVS) were measured to be 17,700 mg/L. The starting operating bed height under flowing conditions was approximately six feet.

Flow was pumped into the bottom of the vessel using a two-pump configuration. A “trickle” pump delivered flow just below or at the incipient media fluidization level. The flow rate was maintained between 3.0 and 3.5 gallons per minute (gpm). This pump was operated continuously. The “bump” pump cycled on and off every 30 seconds. During the “on” period, the flow to the reactor was increased to approximately 5.0 gpm, which fully fluidized the media.

Flow exited the reactor through a submerged port into a 12-inch diameter small “swirl” tank (that created a tangential swirl pattern). This allowed capture of media particles exiting the MFT reactor due to gas attachment. The media were returned to the MFT using a positive displacement pump to a point just above the incipient media fluidization level. (In the larger MFT reactors, this is normally accomplished internally using a baffling system.) Recycle flow for the “trickle and bump” pumps was taken from a port about mid height in the swirl tank. Wastewater flow was added to the recycle flow stream just before entering the MFT. Additionally, a bicarbonate solution (0.5 lb/gallon) was added to the recycle flow stream at this point for alkalinity control. Effluent flow exiting the swirl tank via a gravity overflow was captured in a 1,500 gallon effluent tank; flow volume into this tank was measured and recorded daily.

Heating of the wastewater to an optimal mesophilic temperature (95° to 97°F) was achieved by withdrawing a stream of several gallons a minute from the swirl tank, passing it through a submersion heater and sending this flow back into the liquid volume above the media bed in the MFT reactor.

Figure 2-5. Picture of the Pilot Anaerobic MFT System



**Section 3**

**RESULTS OF PILOT-SCALE DAF PRETREATMENT**

Upon commencement of the pilot demonstration, additional analyses for COD, sCOD, TSS and VSS were conducted on four batches of high-strength waste. Results are presented in Table 3-1. The raw high-strength waste had an average COD of 124,250 mg/L. This is considerably less than was observed during the five-day sampling period where the COD averaged approximately 200,000 mg/L. Pretreatment via DAF reduced the COD in the DAF subnatant by almost 72%, to 35,100 mg/L. TSS and VSS in the DAF subnatant averaged 503 and 475 mg/L, respectively.

**Table 3-1 Pilot-scale DAF Performance Treating High-Strength Waste**

Parameter	Units	Raw High-Strength Waste	DAF Subnatant	Removal Efficiency
COD	mg/L	124,250	35,143	72%
sCOD	mg/L	46,525	32,729	29%
TSS	mg/L		503	
VSS	mg/L		475	

Additional testing was performed during Phase 3 of the project (treatment of the combined high-strength waste and process wastewater). During Phase 3, the DAF was operated 3-4 times per week due to the larger volumes required to feed the anaerobic system. Results from this phase are presented in Table 3-2.

**Table 3-2 DAF Performance Treating the Combined High-Strength Waste and Process Wastewater**

Parameter	Units	Influent	Subnatant	Float Material	Removal Efficiency
COD	mg/L	8,326	6,864	33,218	18%
sCOD	mg/L	5,472	4,873	8,482	11%
TSS	mg/L	2,118	1,103	18,213	48%
VSS	mg/L	1,885	1,028	17,068	46%

As is observed, TSS removal efficiency was just under 50%. (Note: The TSS in the subnatant were colloidal in nature.) COD was reduced by 18% and sCOD by 11%, which is typical for dairy wastewater. The float solids averaged approximately 1.8% (18,213 mg/L), which is low compared to the 4-6% TSS typically observed. A mass balance was performed using COD, TSS, and VSS data and even at this low float solids concentration, the volume of the float accounted for 5.6% of the total flow to the DAF. Treating the DAF subnatant in the MFT reactor was done without issue, as is detailed in Section 4.

**Section 4**  
**DEMONSTRATION TEST RESULTS**

Results of the three-phase demonstration project are presented below. The three phases were as follows:


- Startup and acclimation (Phase 1)
- Testing with high-strength waste (Phase 2)
- Testing with combined process wastewater and high-strength waste (Phase 3)

The MFT reactor was placed into service on September 2, 2006. The reactor was seeded with a sand media from an existing reactor used to treat winery wastewater. For the first several days of the pilot test, primary effluent from the WWTP was used to help “reactivate” the microbial population on the media. (The seeded media had been stored onsite for approximately 3 months.) Beginning September 8, high-strength DAF subnatant was fed to the MFT reactor system.

Results from each phase of the demonstration project are presented below. The results are divided into two sections: (1) data gathered during the entire testing phase, and (2) data gathered once quasi-steady-state conditions were achieved (referred to herein as the “evaluation period”).


The influent and effluent COD data for the duration of the demonstration project are presented graphically in Figure 4-1. A complete data set is provided as Appendix A.

**Figure 4-1. Influent and Effluent COD Concentrations during Overall Demonstration Period**



## RESULTS OF STARTUP AND ACCLIMATION (PHASE 1)

Figure 4-2. Influent and Effluent COD Concentrations Observed During Phase 1




The MFT reactor was started on September 5, 2006, and operated in a recycle mode for the day. On September 6, primary effluent from the WWTP was fed to the reactor to “reactivate” the microbial population on the sand media. On September 8, high-strength waste DAF subnatant was added to the MFT feed tank. From September 8 - September 11, a mixture of WWTP primary effluent and high-strength DAF subnatant was fed to the MFT reactor. Beginning September 11, only high-strength waste DAF subnatant was fed to the MFT reactor. The system was operated under these conditions through September 23, at which point startup and acclimation were considered complete. Influent and effluent COD data collected during Phase 1 are presented graphically in Figure 4-2.

## RESULTS OF TESTING WITH HIGH-STRENGTH WASTE (PHASE 2)

### Overall Phase 2 Results

Data on high-strength waste treatment were collected from September 24 to November 14, 2006. The results for COD and sCOD removal efficiency are presented graphically in Figure 4-3, and summarized in Table 4-1. Due to a malfunctioning in-line heater, the temperature of the reactor varied quite a bit during the initial part of Phase 2, as is evidenced in the plot presented in Figure 4-4. As a result, the evaluation period for Phase 2 is defined as the time period between October 19 and November 14, when the reactor temperature maintained a constant value in the mesophilic range (97°F (+/-1°F)).

**Figure 4-3. COD and sCOD Removal Efficiencies Observed During Phase 2**




**Table 4-1. Summary of all COD and sCOD Data for Phase 2**

Parameter	Units	Influent	Effluent	% Removal
COD	mg/L	27,555	5,692	80.7
sCOD	mg/L	25,321	4,219	84.3
OLR	kg COD/m <sup>3</sup> -d	21.2		

Despite the difficulty with maintaining an optimum mesophilic temperature, COD and sCOD removal efficiencies averaged 80.7% and 84.3%, respectively, at an average applied OLR of 21.2 kg COD/m<sup>3</sup>-d for the entire period, which included a considerable number of days when the reactor temperature was below 90°F. As shown in Figure 4-4, the effluent sCOD concentration increased quickly once the temperature fell below the optimal range. Results for total COD (not shown) produced essentially the same correlation. For this reason, the evaluation period for Phase 2 is defined as the period when the heater was fully operational and capable of delivering optimal and stable temperature control.

**Figure 4-4. Effect of Temperature on Effluent Quality (sCOD) During Phase 1**



**Results for Phase 2 Evaluation Period**

A summary of data collected during the Phase 2 evaluation period (October 19 to November 14, 2006) is presented in Table 4-2. Influent and effluent COD and sCOD data are presented as Figure 4-5 and Figure 4-6, respectively.

Bicarbonate was used for alkalinity control during the study. Since the alkalinity in the bicarbonate solution is dilute (0.5 lb/gal), a fairly large volume was required. Therefore, the volume of bicarbonate solution fed to the reactor had to be taken into account when analyzing the data. To do this, the total volume of effluent was measured and the volume of bicarbonate solution was subtracted from this volume to obtain the actual flow of the high-strength waste. The influent concentrations were then corrected based on the ratio of corrected effluent volume to actual effluent volume (that averaged 0.87 and ranged from 0.78 to 0.92).


COD and sCOD removal efficiencies, based on corrected volume, averaged 82.7% and 87.8%, respectively, during this period at an average applied OLR of 23.7 kg COD/m<sup>3</sup>-d. Note: The actual daily removal efficiencies were calculated based on an MFT mass balance that included mass of COD in, mass of COD out, and the change in reactor concentration (change in the “storage” term).

**Table 4-2. Summary of COD, sCOD, TSS, and VSS Concentrations for the Phase 2 Evaluation Period**

Parameter	Units	Influent	Corrected Influent	Effluent	Removal (%) <sup>*</sup>
COD	mg/L	29,141	25,754	4,807	82.7
sCOD	mg/L	26,743	23,654	3,168	87.8
TSS	mg/L	1,667	1,378	3,462	
VSS	mg/L	1,443	1,207	1,648	
OLR	kg COD/m <sup>3</sup> -d		23.7		


*\* Note: the removal efficiencies were calculated based on daily mass balance that included influent and effluent COD values and the change in the reactor concentration (storage term)*

**Figure 4-5. Influent and Effluent COD from the Final Four Weeks of the Phase 2 Evaluation Period**



*\*Note: influent COD values are corrected for dilution due to addition of bicarbonate for pH control*

**Figure 4-6. Influent and Effluent Soluble COD during the Phase 2 Evaluation Period**



There are several other interesting observations concerning the Phase 2 COD, sCOD, TSS, and VSS results. The ratio of sCOD to COD averaged 92% for the influent and 66% for the effluent. This indicates that a greater fraction of the effluent COD was due to suspended solids. The ratio of VSS to TSS (% volatile solids) was 87% for the influent. The ratio in the effluent was 48%, which indicates that a significant fraction of the TSS in the effluent were non-volatile. As will be discussed later, it is believed that this was due to precipitation of inorganic compounds, most likely as calcium phosphate and calcium carbonate compounds. There were eight days during the Phase 2 evaluation period when BOD<sub>5</sub> analyses on the influent and effluent were performed. The data are presented in Table 4-3.

**Table 4-3. Summary of Influent and Effluent BOD<sub>5</sub> Data During the Phase 2 Evaluation Period**

Date	Influent (mg/L)	Corrected Inf. (mg/L)	Effluent (mg/L)	Soluble Effluent (mg/L)
10/26	8,300	7,470	1,100	320
10/27	13,000	11,100	590	350
10/31	17,000	15,560	1,900	1,300
11/2	18,000	14,150	2,500	440
11/6	12,000	10,030	1,700	410
11/7	24,000	21,400	2,900	1,200
11/10	20,000	17,600	860	570
11/13	10,000	8,940	560	240
<b>Average</b>	<b>15,290</b>	<b>13,280</b>	<b>1,510</b>	<b>604</b>

As shown, the influent BOD<sub>5</sub> concentrations averaged 15,290 mg/L and the corrected values (accounting for dilution) averaged 13,280 mg/L. The effluent total and soluble BOD<sub>5</sub> concentrations averaged 1,510 mg/L and 604 mg/L, respectively. BOD<sub>5</sub> removal efficiency in the MFT averaged 88.6% for total influent to total effluent and 95.5% for the total influent to soluble effluent. The ratios of BOD<sub>5</sub> to COD averaged 0.50 for the influent and 0.31 for the effluent.

The soluble BOD<sub>5</sub> concentrations averaged 604 mg/L, ranging from 240 mg/L to 1,300 mg/L. This indicates approximately 60% of the residual BOD<sub>5</sub> was particulate in nature and could potentially be removed, if desired, using a post anaerobic solids removal process such as DAF or perhaps feeding the effluent to the primary clarification system. This could further reduce the load on the Oneida WWTP, by sending more organics directly to the existing anaerobic sludge digesters for biogas production.

Limited information was also collected on the concentrations and forms of the major macronutrients, nitrogen (N) and phosphorus (P), during the Phase 2 evaluation period. Three sample sets were processed for TKN and ammonium (NH<sub>4</sub><sup>+</sup>-N). These data are summarized in Table 4-4. The increase in ammonium indicates degradation of a portion of the proteins in the high-strength waste. The loss of TKN and organic N is likely due to accumulation of biomass in the reactor during this period. As will be discussed later in this section, the bed volatile solids (BVS) concentration, a measure of the amount of biomass in the MFT reactor, increased significantly during this period.

**Table 4-4. Summary of Nitrogen Data Taken During the Phase 2 Evaluation Period**

Parameter	Units	Influent	Inf. Corrected	Effluent	Difference
TKN	mg/L	551	485	371	(104)
NH <sub>4</sub> <sup>+</sup> -N	mg/L	16	14	59	45
Organic N	mg/L	535	471	312	(159)

The concentrations of total phosphorous (TP) and ortho-phosphate (OP) observed during the entire Phase 2 test period are presented in Table 4-5. Although some of the P was likely consumed as a result of cell growth, the amount should be approximately 1/6<sup>th</sup> of that observed for nitrogen. Based on loss of organic N, this would translate to approximately 27 mg/L of P. The measured difference for average influent (corrected for dilution) and effluent for TP and OP were 119 mg/L and 147 mg/L, respectively. Therefore, it is believed that most of the P loss was due to precipitation reactions (as calcium phosphates), which is common in dairy wastewater under anaerobic conditions. The fact that the reduction in OP and TP are approximately the same indicates that OP was the phosphorus species that was primarily removed.

**Table 4-5. Summary of Total and Ortho Phosphorus Data for Entire Phase 2 Test Period**

Date	Influent TP (mg/L)	Influent TP Corrected (mg/L)	Effluent TP (mg/L)	Influent OP (mg/L)	Influent OP Corrected (mg/L)	Effluent OP (mg/L)
10/03	750	581	500	302	234	118
10/10	253	206	104	242	197	91
10/17	300	251	150	281	235	120
10/24	350	318	150	288	262	81
10/31	313	286	138	284	260	67
11/7	400	356	240	281	250	83
<b>Average</b>	<b>394</b>	<b>333</b>	<b>214</b>	<b>284</b>	<b>240</b>	<b>93</b>

**RESULTS OF TESTING WITH COMBINED PROCESS WASTEWATER AND HIGH-STRENGTH WASTE (PHASE 3)**

Beginning November 15, 2006, a combination of process wastewater and high-strength waste was fed to the MFT reactor. HP Hood mixed the high-strength waste and process wastewater in approximately 5,000 gallon batches, and trucked the material to the Oneida WWTP, where it was pumped into an existing empty sludge storage tank. The original plan was to dilute the high-strength waste with primary effluent from the WWTP. However, HP Hood subsequently offered to provide the actual mixture of the two streams generated at the HP Hood facility to ensure that any effect due to cleaning agents present in the process wastewater was captured during the project. The two waste streams were mixed in proportion to the average volumetric production at the plant, which is approximately 6% high-strength waste. Approximately 600 to 700 gallons of the mixture was processed through the DAF unit, with the supernatant subsequently fed to the MFT reactor.


**Overall Phase 3 Results**

Phase 3 operations extended from November 15 to December 4, 2006. During the final days of testing, the low ambient temperatures, coupled with the high volume of wastewater being fed, resulted in the reactor temperature decreasing precipitously; the heating system was unable to maintain temperatures in the optimal mesophilic range. These days were not included in the Phase 3 evaluation period but all data are included in Appendix A.

A plot showing the effect of temperature on system performance is provided as Figure 4-7. The removal efficiency, in general, varied between the mid-60% to mid-70% range. When the temperature decreased to below 80°F, the removal efficiency fell to below 50%. Since a full-scale system would not be operated


outside of the mesophilic range, these data were excluded from the evaluation period as mentioned above. The average temperature maintained during the Phase 3 evaluation period was 93°F.

**Figure 4-7. Scatter Plot of COD Removal Efficiency as a Function of Temperature**




The influent and effluent concentrations for COD and sCOD over the entire Phase 3 testing period are depicted in Figure 4-8 and Figure 4-9. During this period, the OLR averaged 17.1 kg COD/m<sup>3</sup>-d and the empty bed hydraulic retention time was 12.9 hours.

**Figure 4-8. Influent and Effluent COD During Phase 3 Testing**



**Figure 4-9. Influent and Effluent Soluble COD During Phase 3 Testing**



As can be seen in Figures 4-8 and 4-9, the inlet COD concentrations varied widely during Phase 3. Because of this, the data was evaluated for the overall period and then separately for the higher concentration period (Phase 3a) and lower concentration period (Phase 3b). The results for COD and suspended solids for Phase 3 are presented in Table 4-6. During Phase 3, bicarbonate powder was added directly to the MFT feed tank to eliminate any dilution.

**Table 4-6. Phase 3 Overall Results for COD, sCOD, TSS and VSS**

Parameter	Units	Influent	Effluent	% Removal
COD	mg/L	7,717	2,231	71.1
sCOD	mg/L	5,399	1,639	69.6
TSS	mg/L	1,701	733	56.9
VSS	mg/L	1,410	438	68.6
OLR	kg COD/m <sup>3</sup> -d	17.1		

The COD removal efficiency averaged 71% and sCOD removal efficiency averaged 70%. Considering that the majority of COD is likely associated with the process wastewater, this represents a relatively high efficiency for the degradable fraction of the COD for the mixture. For example, if it is assumed that the DAF treated portion of the mixture associated with the high-strength waste had a COD of 30,000 mg/L (29,100 mg/L was the Phase 2 average), and the process wastewater had a COD of 6,000 mg/L after DAF, the composite would be 7,440 mg/L, with 76% of the COD from the process wastewater. The degradable fractions for the high-strength waste and the process wastewater from the characterization study BMP

testing were 96.6% and 66.2%, respectively. The composite of the two can be calculated to be approximately 73.5% degradable using the above scenario. This agrees well with the 71% observed removal efficiency achieved.

Unlike Phase 2 testing, where TSS and VSS increased due to the high COD concentrations and associated biomass growth, a significant reduction in both TSS and VSS was observed during Phase 3 testing: 57% and 69%, respectively. The ratio of VSS to TSS changed from 0.83 in the influent to 0.60 in the effluent. This indicates that some of the effluent TSS was mineral in nature (i.e. precipitated P species).

**Results for Phase 3A Evaluation Period**

From November 22 to 25, 2006, the post-DAF mixed wastewater had a COD concentration that was more than double the typical levels. To evaluate whether or not the system could handle a concentration spike, the flow rate was maintained at a more-or-less constant rate; the hydraulic retention time (HRT) was 14.1 hours versus 12.9 hours overall, which led to an increased average OLR of 23.5 kg COD/m<sup>3</sup>-d. Results for this evaluation period are presented in Table 4-7.

**Table 4-7. Phase 3A Results for COD, sCOD, TSS and VSS**

Parameter	Units	Influent	Effluent	Removal
COD	mg/L	13,708	3,185	76.8%
sCOD	mg/L	9,417	2,452	74.0%
TSS	mg/L	3,251	856	73.7%
VSS	mg/L	2,703	439	83.8%
OLR	kg COD/m <sup>3</sup> -d	23.5		

Despite the high OLR and low temperature (averaged 88°F), removal efficiencies were quite high, averaging 76.8% and 74.0% for COD and sCOD, respectively. The TSS and VSS removal averaged 73.7% and 83.8%, respectively. No analyses were performed for BOD<sub>5</sub> or nutrients during this period.

**Results for Phase 3B Evaluation Period**

From November 27 to December 1, 2006, the COD and sCOD concentrations were considerably lower than typical levels. These results, along with TSS and VSS data, are presented in Table 4-8. Note the OLR averaged 15.6 kg COD/m<sup>3</sup>-d and the HRT was 10.5 hours. The average temperature was 96°F.

**Table 4-8. Phase 3B results for COD, sCOD, TSS and VSS**

Parameter	Units	Influent	Effluent	Removal
COD	mg/L	5,574	2,032	63.5%
sCOD	mg/L	4,181	1,756	58.0%
TSS	mg/L	1,286	663	48.4%
VSS	mg/L	1,026	390	62.0%
OLR	kg COD/m <sup>3</sup> -d	15.6		


The reduction in COD and sCOD averaged 63.5% and 58%, respectively. The initial BMP testing conducted on the process wastewater indicated that the degradable fraction was 66.2%. The TSS and VSS concentrations during Phase 3B were reduced by 48% and 62%, respectively.

Samples were collected for BOD<sub>5</sub> analyses on the final three days of the period. Unfortunately errors were made at the contract laboratory and no data are available for the influent BOD<sub>5</sub>. The effluent BOD<sub>5</sub> and effluent soluble BOD<sub>5</sub> concentrations averaged 253 mg/L (240, <200, 320) and 108 mg/L (84, 120, 120), respectively. This represents a significant reduction in what would be the loading from HP Hood on the Oneida WWTP if anaerobic pretreatment were to be installed.

#### **BED VOLATILE SOLIDS (BVS)**

The BVS, a measure of the active biomass in the reactor, were analyzed over the course of the study. The increase in BVS over time is presented in Figure 4-10 for samples taken at the six-foot level in the MFT reactor (measured from the bottom of the bed up). The BVS increased dramatically during the study from approximately 16 g/L to over 50 g/L in the two month period. Samples were also taken at the four-foot level near the end of the study, which averaged between 30 and 40 g/L. The total biomass in the MFT was estimated to be 5.82 kilograms at the start. This increased to 12.15 kilograms by the end of November, which represents a more than doubling of the biomass in the system. Since the biomass levels in the MFT continued to increase over the course of the pilot testing, results generated in the earlier phases have to be considered conservative since they were generated with lower biomass levels. This indicates that the “trickle and bump” flow scheme was effective in increasing biomass in the MFT system.

Figure 4-10. Bed Volatile Solids (BVS) over Time



## SUMMARY

### Phase 2


High-strength waste DAF supernatant can be effectively treated in a high rate MFT reactor. During the Phase 2 evaluation period, COD removal efficiency averaged 82.9% and sCOD removal efficiency averaged 87.8%, at an average applied OLR of 23.7 kg COD/m<sup>3</sup>-d. The corresponding total and soluble BOD<sub>5</sub> removal efficiencies were 88.6% and 95.5%, respectively. On four occasions, the OLR was greater than 30 kg COD/m<sup>3</sup>-d, with a peak day of 47.5 kg COD/m<sup>3</sup>-d on October 23, 2006. These high spike loading rates resulted in the COD removal efficiency decreasing for that day, but no long-term reduction in removal was observed. When the OLR returned to the normal range, removal efficiencies returned to normal levels. The effect of applied OLR versus removal efficiency for COD and sCOD are presented in Figure 4-11 and Figure 4-12, respectively. Based on the data developed, a conservative OLR for the high-strength waste would be on the order of 20 kg COD/m<sup>3</sup>-d.

### Phase 3


During the Phase 3 evaluation period, removal efficiencies averaged 71%. During the period when the COD was quite high, averaging 13,700 mg/L after DAF pretreatment, the removal efficiency averaged just below 77% at an OLR of 23.5 kg COD/m<sup>3</sup>-d. When the COD was lower, 5,570 mg/L, the removal efficiency averaged 63.5%; the OLR during this period was 15.6 kg COD/m<sup>3</sup>-d. Effluent BOD<sub>5</sub> averaged 250 mg/L during this period and sBOD<sub>5</sub> averaged 110 mg/L. The effluent TSS averaged 663 mg/L, a 48%

decrease from the influent TSS, indicating a significant fraction of the influent TSS were degraded during anaerobic treatment. Overall results indicate that a combined high-strength waste and process wastewater stream can be effectively treated in a high-rate MFT at a reasonable OLR. This would significantly reduce the overall loading on the Oneida WWTP, while concurrently generating significant biogas that could be used to generate electricity.

**Figure 4-11. Scatter Plot of COD Removal Efficiency vs. Applied OLR for Phase 2 Testing**



**Figure 4-12. Scatter Plot of Soluble COD vs. OLR for Phase 2 Testing**




**Section 5**  
**FULL-SCALE BASIS OF DESIGN**

**DEVELOPMENT OF COD MASS LOADING BASIS OF DESIGN**

Weekly BOD<sub>5</sub> data of the process wastewater collected over a 105 week period were evaluated. A probability plot of the data is shown in Figure 5-1. The 95th percentile BOD<sub>5</sub> loading was selected as the basis of design for a full-scale system, which is 5,348 lb BOD<sub>5</sub>/d. This was converted to COD using a BOD<sub>5</sub>/COD ratio of 0.5 (typical for dairy wastewater and observed during the pilot study), which results in a maximum COD design load of 10,696 lb/d. The average BOD<sub>5</sub> loading rate was 2,990 lb/d, which translates to 5,980 lb COD/d for average loading rate from the process wastewater. The average and maximum flow rates were 194,000 gpd and 233,000 gpd, respectively.

**Figure 5-1. Probability Plot of BOD<sub>5</sub> in Process Wastewater**



Weekly high-strength waste data collected from December 2004 through March 2006 were evaluated. The average flow rate, based on flow averaging for 7 days-per-week, was 76,500 lb/d or 9,170 gpd (calculated at 8.34 lbs per gallon). The 95<sup>th</sup> percentile was approximately 12,000 gpd. The COD of the post-DAF high-strength waste was 30,000 mg/L. This results in 3,000 lb COD/d contribution from the high-strength waste at the 95<sup>th</sup> percentile and 2,300 lb COD/d at the average loading condition.

Combining the two streams, the maximum total OLR to the anaerobic MFT would be 13,700 lb COD/d. Based on a total flow of 212,000 gpd, the resulting COD concentration is 7,750 mg/L. Note: The average COD measured during Phase 3 was 7,717 mg/L, which includes the four days of very high COD observed around Thanksgiving. The average after that period (Phase 3B) was 5,770 mg/L. The average loading rate comes out to 8,280 lb COD/d, or 60% of the maximum loading rate. Therefore, an average and maximum

OLR of 15 kg COD/m<sup>3</sup>-d and 25 kg COD/m<sup>3</sup>-d, respectively, were selected for the full-scale basis of design (for a combined process wastewater/high-strength waste stream).

Note: The COD mass loadings presented herein are somewhat conservative in that the loss of COD in the process wastewater from DAF pretreatment was not taken into account. This is minor, and accounts for approximately 5 to 10% of the load associated with the process wastewater.

#### **Mass Loading with the Inclusion of Whey Permeate from HP Hood's Vernon Facility**

HP Hood also wanted to consider the case where 6,000 gallons of whey permeate from the Vernon facility would be trucked to the Oneida treatment plant and treated in the MFT. During the course of the study, three samples of whey permeate and two samples of skim permeate were analyzed for COD, sCOD, TSS, and VSS. The COD averaged 50,440 mg/L, while the sCOD averaged 49,460 mg/L. One load per week of this material would increase the total load to the MFT system by 361 lb/d assuming the permeate is held in a storage tank and metered into the system over the course of the week. Note: Ecovation has considerable experience treating whey permeate including a full-scale system at Breyers Yogurt Company in North Lawrence, NY. Removal efficiencies of approximately 95% are typical. It was calculated that addition of the whey permeate would increase the average and maximum OLR to 8,540 lb COD/d and 14,060 lb COD/d, respectively.

#### **EXPECTED BIOGAS PRODUCTION**

Based on the pilot test results, a COD removal efficiency of 71% is assumed for the combination of the high-strength waste and process wastewater and 95% for the whey permeate. Using this assumption, the total COD available for conversion to biogas would be 6,139 lb/d. At a methane yield of 5.6 scf/lb COD, this translates into 33 million BTU (MMBTU)/d.

In addition to biogas generated by the MFT reactor, considerable energy could be recovered from digestion of the DAF float. Using a conservative influent average of the high-strength waste to the DAF unit of 124,250 mg COD /L and an effluent subnatant COD of 35,170 mg/L, removal of COD in the DAF was calculated at 71.7%. Therefore, the total COD of the float removed from the DAF system and sent directly to the anaerobic digesters would be 8,916 lb/d (based on 12,435 lb/d COD at a flowrate of 12,000 gpd). Assuming 95% conversion of this highly degradable material, the amount of methane generated would be an additional 47,430 scf/d or 45.54 MMBTU/d.

The combined total of methane generated would be 81,810 scf/d or 78.5 MMBTU/d. At a 28% conversion efficiency, this translates to 6,443 kwh/d of electricity potential. If a 250 generator were installed by the WWTP (the amount of gas generated could support a 268 kW generator, but these are not commercially

available), 6,000 kWh/d of electricity could be produced, which, at a unit price of \$0.12/kWh, translates to \$262,800 per year.

## APPENDIX A Oneida-Hood Pilot - MFT Daily Log

Date	Time	Trickle Rate (gpm)	Trickle Total (gal)	Bump Rate (gpm)	Bump Total (gal)	Flow VOL (gal)	Temp (F)	pH (SU)	EC (mS/cm)	TCOD (mg/L)	EPA 405.1 TBOD (mg/L)	SCOD (mg/L)	EPA 351.3 TKN (mg/L)	NH3-N <sub>F</sub> (mg/L)	EPA 365.3 TP (mg/L)	OP (mg/L)	TSS (mg/L)	VSS (mg/L)	CHEMICALS ADDED	
																			Alk NaHCO3 (gal)	Micros Solution (g)
09/05/06	9:00					120	70	8.38	33			2					56		0.10	0
09/06/06	9:00					60	70	8.50	173			108					58		0.10	0
09/07/06	9:30					60	70	7.89	422			183					158		0.10	0
09/08/06	9:00					60	70	8.41	107			40					48		0.10	0
09/09/06	9:00					0	70	4.14	6,720			2,620								0
09/11/06	9:00					0	70	6.15	6,310			1,840					930			26
09/12/06	10:00					0	70	3.99	30,000			14,430					21100		10.0	0
09/13/06	8:00					0	70	3.92	16,200			11,200					19000		8.0	0
09/14/06	10:00					60	70	3.78	4,89			18,100					2160		15.0	0
09/15/06	9:00					0	70	3.81	17,700			14,900					787		10.0	0
09/16/06	8:30					0	70	3.89	17,600			14,900					1520		15.0	0
09/18/06	9:30					120	70	4.30	3,22			9,200					1660		10.0	0
09/19/06	10:00					75	70	4.25	3,11			8,100					1100		14.0	0
09/20/06	10:00					100	70	4.27	13,600			9,800					1220		12.0	0
09/21/06	9:00					0	70	4.19	13,200			9,200					1310		14.0	0
09/23/06	9:30					75	70	4.23	2,86			7,700					1380		10.0	0
09/24/06	15:00					75	70	4.22	5,76			25,500					1240		0.0	0
09/25/06	9:00					45	70	3.96	6,60			26,100					1340		11.0	0
09/27/06	9:30					85	70	3.83	6,54			30,600					1790		13.0	0
09/28/06	9:30					50	70	3.76	6,67			26,300					1720		13.0	0
09/29/06	9:30					50	63	3.69	5,78			26,100					1730		12.0	0
09/30/06	9:30					59	65	3.54	5,78			23,600					1810		12.0	0
10/02/06	9:30					30	68	3.55	32,700			22,800					1960		2.0	0
10/03/06	9:30					53	71	3.40	6,61			25,800					2250		12.0	0
10/04/06	9:00					57	70	3.40	6,47			18,200					1690		10.0	0
10/05/06	9:00					57	69	3.88	5,16			21,500					1390		10.0	0
10/06/06	9:30					65	60	3.83	4,56			20,100					1070		12.0	0
10/08/06	13:00					122	72	3.44	4,74			22,900					1190		10.0	0
10/09/06	9:30					49	66	3.44	4,89			21,800					1350		12.5	0
10/10/06	9:30					65	68	3.29	5,33			25,900					1370		10.0	0
10/11/06	9:30					76	65	3.32	4,64			19,700					1410		12.0	0
10/13/06	9:30					160	55	3.44	4,55			14,000					1930		20.0	0
10/14/06	12:30					76	63	3.64	4,78			14,200					2460		11.0	0
10/16/06	9:30					114	67	4.23	4,79			29,500					980		20.0	0
10/17/06	10:00					61	60	4.08	5,19			31,100					890		10.0	0
10/18/06	10:00					27	62	3.96	4,97			28,000					1040		2.0	0
10/19/06	9:00					72	63	3.95	5,14			26,400					1120		4.0	0
10/20/06	9:30					72	57	3.72	4,78			22,900					1190		5.0	0
10/21/06	10:30					70	55	3.80	4,99			25,400					1210		7.5	0
10/23/06	9:30					196	51	3.55	11,09			28,000					1830		3.5	0
10/24/06	9:30					110	53	4.02	5,23			25,200					940		10.0	0
10/25/06	9:00					122	51	4.05	4,25			24,700					1210		13.0	0
10/26/06	9:30					129	52	3.98	4,73			20,900					1470		13.0	0
10/27/06	10:00					68	58	4.04	4,53			31,900					1660		10.0	0
10/28/06	10:00					118	56	4.02	3,95			18,500					1950		16.0	0
10/30/06	8:45					194	57	4.05	4,80			20,000					2460		21.0	0
10/31/06	7:30					106	56	4.00	4,87			29,200					1890		9.0	0
11/01/06	8:00					118	69	3.90	5.10			29,200					2150		12.5	0
11/02/06	9:00					61	59	6.80	9.50			31,200					3830		13.0	0
11/03/06	9:00					76	48	6.15	14.24			27,400					2780		12.0	0
11/04/06	9:30					76	52	4.40	12.88			31,400					940		13.0	0

## APPENDIX A Oneida-Hood Pilot - MFT Daily Log

Date	Time	Trickle		Bump		Flow VOL (gal)	Temp (F)	pH (SU)	EC (mS/cm)	TCOD (mg/L)	EPA 405.1 TBOD (mg/L)	SCOD (mg/L)	EPA 351.3 TKN (mg/L)	NH3-N <sub>F</sub> (mg/L)	EPA 365.3 TP (mg/L)	OP (mg/L)	TSS (mg/L)	VSS (mg/L)	CHEMICALS ADDED		
		Rate (gpm)	Total (gal)	Rate (gpm)	Total (gal)														Alk NaHCO <sub>3</sub> (gal)	Micros Solution (g)	
11/06/06	9:30	2.80	253507	3.80	254136	152	60	4.12	4.85	32,700	31,600						940	850	25.0	0.60	26
11/07/06	8:00	3.76	255922	4.60	257740	91	60	3.93	4.78	33,500	33,500			19.0	400.0	281.0	1260	1150	10.0	0.60	0
11/08/06	9:00	3.25	258413	4.00	261624	84	62	3.97	4.72	31,900	27,900						1670	1400	11.0	0.60	26
11/09/06	9:00	3.38	261080	4.00	265326	84	65	3.77	4.88	28,600	24,500						2200	2040	10.0	0.50	0
11/10/06	9:00	3.22	263339	3.91	269089	84	62	3.90	3.55	28,600	27,300						1010	900	10.0	0.50	26
11/11/06	9:45	6.43	266127	7.50	272885	114	64	3.61	3.71	31,000	28,600						910	580	9.0	0.50	0
11/13/06	8:45	6.58	271249	7.68	280183	179	59	3.65	3.52	26,400	26,800						1450	1240	19.0	0.50	0
11/14/06	8:45	3.34	273884	4.00	283912	57	60	3.78	3.60	24,750	22,600					18.8	2150	1970	8.0	0.50	0
11/15/06	9:30	3.53	276311	4.30	287710	129	59	6.85	5.02	8,300	4,090						815	770	8.5	0.50	26
11/16/06	9:00	3.47	278670	4.20	291409	312	63	7.43	5.09	8,500	7,400						1180	990	1.5	0.50	0
11/17/06	9:00	3.57	280976	4.30	295051	327	63	7.60	5.44	6,090	5,410						1220	990	2.0	0.50	26
11/18/06	7:30	3.42	281481	4.20	295830	76	56	7.72	5.98	6,270	4,160						1140	970	0.0	0.50	0
11/19/06	13:00	3.61	284513	4.50	300456	426	56	7.46	3.85	4,200	2,930						970	870	0.0	0.50	0
11/20/06	8:00	3.60	286461	4.45	303427	304	49	8.08	3.92	4,180	2,380						1300	1120	4.0	0.50	0
11/21/06	8:00	4.00	289623	4.96	307216	372	48	8.28	7.50	3,230	1,430						1160	910	7.0	0.50	26
11/22/06	8:30	3.82	292715	4.99	310926	228	51	6.64	6.46	13,480	9,560					118.0	2980	2550	5.0	0.50	0
11/23/06	9:30	3.79	295480	4.98	314948	175	51	7.02	6.36	13,940	9,920			6.0			3200	2760	8.0	0.50	26
11/24/06	9:30	3.69	297992	4.79	318682	182	53	7.10	6.37	13,650	9,250						3625	2800	0.0	0.50	0
11/25/06	11:00	3.81	301078	4.97	322725	198	57	7.46	7.50	13,760	8,937						1480	2700	0.0	0.50	26
11/27/06	8:30	6.71	305940	7.81	329914	410	57	7.55	5.70	7,720	5,400					44.0	1560	1210	0.0	0.50	26
11/28/06	9:00	3.81	308804	4.97	333786	304	62	8.00	6.93	6,590	6,420			9.0	100.0		1130	900	0.0	0.50	0
11/29/06	8:45	3.92	311689	4.98	337531	106	62	8.07	6.01	4,330	3,150						1360	1060	0.0	0.50	0
11/30/06	8:30	3.81	314529	4.99	341348	445	66	7.80	5.30	5,130	3,230						900	740	6.0	0.50	26
12/01/06	10:30	3.79	317500	4.98	345467	524	60	8.05	5.88	4,100	2,720						900	800	0.0	0.50	0
12/02/06	9:30	6.91	318201	7.97	346391	160	53	7.93	5.30	3,760	2,290						1470	1230	0.0	0.50	26
12/03/06	10:15	3.65	321147	4.95	350254	494	51	8.11	5.49	4,630	2,850						1250	1080	0.0	0.50	0
12/04/06	9:00	3.98	323912	4.97	353850	555	44	7.72	2.85	4,120	2,240								0.0	0.50	0
12/05/06	7:30	4.05	326807	4.99	357490	502	40	8.04	3.31	3,290	2,050			6.0		37.0			0.0	0.50	0





For information on other  
NYSERDA reports, contact:

New York State Energy Research  
and Development Authority  
17 Columbia Circle  
Albany, New York 12203-6399

toll free: 1 (866) NYSERDA  
local: (518) 862-1090  
fax: (518) 862-1091

[info@nysesda.org](mailto:info@nysesda.org)  
[www.nysesda.org](http://www.nysesda.org)

# **CITY OF ONEIDA MOBILIZED FILM TECHNOLOGY PILOT STUDY REPORT**

---

**FINAL REPORT 07-10**

**STATE OF NEW YORK**  
**ELIOT SPITZER, GOVERNOR**

**NEW YORK STATE ENERGY RESEARCH AND DEVELOPMENT AUTHORITY**  
**VINCENT A. DEIORIO, ESQ., CHAIRMAN**  
**PETER R. SMITH, PRESIDENT, AND CHIEF EXECUTIVE OFFICER**

